

AMERICAN NATIONAL STANDARD
REACTOR PLANTS AND THEIR MAINTENANCE

Self-Operated and Power-Operated
Safety-Related Valves
Functional Specification Standard

ANSI N278.1 - 1975

REAFFIRMED 1992

FOR CURRENT COMMITTEE PERSONNEL
PLEASE SEE ASME MANUAL AS-11

SECRETARIAT

THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS

PUBLISHED BY

THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS

United Engineering Center 345 East 47th Street New York, N. Y. 10017

AMERICAN NATIONAL STANDARD

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether he has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review, and users are cautioned to obtain the latest editions.

CAUTION NOTICE: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from date of publication. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute.

This standard was approved by the American National Standards Committee N45 and its Secretariat, and it was subsequently approved and designated N278.1-1975 by the American National Standards Institute on September 18, 1975.

No part of this document may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

FOREWORD

(This foreword is not part of American National Standard Self-operated and Power-operated Safety-Related Valves Functional Specification Standard)

This standard is one of a series of power plant equipment standards provided to assure that safety-related equipment will function as specified. The standard was developed under sponsorship of the American Society of Mechanical Engineers (ASME) as an effort by the American National Standards Committee N45 on Reactor Plants and Their Maintenance. This committee has been chartered to promote the development of standards for the location, design, construction, and maintenance of nuclear reactors and plants embodying nuclear reactors, including equipment, methods, and components specifically for this purpose.

In October of 1972, the N45 Committee of ANSI established a task force to prepare a series of standards to assure that safety-related valves would function as specified. This standard provides for the specification of the required functional characteristics of these valves. Utilization of this standard will provide assurance that the functional requirements of valves are fully described so that valves can be designed to provide safe, reliable operation for all foreseeable conditions including preoperational tests and extreme limits of plant design conditions.

Suggestions for improvement gained in the use of this standard will be welcomed. They should be sent to the secretary, American National Standards Committee N45, The American Society of Mechanical Engineers, United Engineering Center, 345 East 47th Street, New York, New York 10017.

AMERICAN NATIONAL STANDARDS COMMITTEE N45*
Reactor Plants and Their Maintenance

OFFICERS

Sol Burstein, Chairman **S. A. Bernsen, Vice-Chairman**
Manuel Gutierrez, Secretary

COMMITTEE PERSONNEL

AMERICAN FEDERATION OF LABOR AND CONGRESS OF INDUSTRIAL ORGANIZATIONS
P. R. Shoop, International Brotherhood of Electrical Workers, Washington, D.C.

AMERICAN NUCLEAR SOCIETY
J. S. Moore, Westinghouse Electric Corporation, Pittsburgh, Pennsylvania
J. R. Rohlf, North American Rockwell, Canoga Park, California

AMERICAN SOCIETY OF CIVIL ENGINEERS
A. A. Ferlito, Ebasco Services, New York, New York
C. B. Miczek, Stone and Webster Engineering Corporation, Boston, Massachusetts

AMERICAN SOCIETY OF MECHANICAL ENGINEERS, THE
E. C. Beiley, Commonwealth Edison Company, Chicago, Illinois
V. S. Boyer, Philadelphia Electric Company, Philadelphia, Pennsylvania
H. F. Brush, Bechtel Corporation, San Francisco, California
S. Burstein, Wisconsin Electric Power Company, Milwaukee, Wisconsin

AMERICAN WELDING SOCIETY
J. R. Mc Guffey, Union Carbide Corporation, Oak Ridge, Tennessee
H. E. Broadbent, alternate, American Welding Society, Miami, Florida

ATOMIC INDUSTRIAL FORUM, INC.
D. W. Montgomery, Babcock & Wilcox, Lynchburg, Virginia

EDISON ELECTRIC INSTITUTE—ELECTRIC LIGHT AND POWER GROUP
R. W. Clement, Consolidated Edison Company of New York, Incorporated, New York, New York
K. P. Baskin, alternate, Southern California Edison Company, Rosemead, California
G. A. Olson, alternate, Edison Electric Institute, New York, New York

HEALTH PHYSICS SOCIETY
T. J. Burnett, Oak Ridge National Laboratory, Oak Ridge, Tennessee

INSTITUTE OF ELECTRICAL AND ELECTRONICS ENGINEERS
M. I. Olken, American Electric Power Service Corporation, New York, New York
J. C. Russ, General Electric Company, San Jose, California

INSTRUMENT SOCIETY OF AMERICA
H. C. Copeland, United Nuclear Industries, Incorporated, Richland, Washington
T. M. Clement, alternate, United Nuclear Industries, Incorporated, Richland, Washington

MANUFACTURING CHEMISTS' ASSOCIATION, INCORPORATED
****J. Haaga**, Exxon Nuclear Company, Incorporated, Bellevue, Washington

*Effective November 1973

**Deceased

NUCLEAR ENERGY PROPERTY INSURANCE ASSOCIATION

R. P. Day, Nuclear Energy Liability-Property Insurance Association, Hartford, Connecticut

J. J. Carney, *alternate*, Nuclear Energy Liability-Property Insurance Association, Hartford, Connecticut

TRAVELERS INSURANCE COMPANY, THE

F. W. Catudal, The Travelers Insurance Company, Hartford, Connecticut

U.S. ENVIRONMENTAL PROTECTION AGENCY

J. E. Martin, U.S. Environmental Protection Agency, Rockville, Maryland

E. D. Harward, *alternate*, U.S. Environmental Protection Agency, Rockville, Maryland

U.S. NUCLEAR REGULATORY COMMISSION

R. B. Minogue, U.S. Nuclear Regulatory Commission, Washington, D.C.

Wilbur Morrison, *alternate*, U.S. Nuclear Regulatory Commission, Washington, D.C.

U.S. ENERGY RESEARCH AND DEVELOPMENT ADMINISTRATION

R. E. Yoder, U.S. Energy Research and Development Administration, Washington, D.C.

M. P. Norin, U.S. Energy Research and Development Administration, Washington, D.C.

INDIVIDUAL MEMBERS

S. A. Bernsen, Bechtel Power Corporation, San Francisco, California

W. F. Ferguson, Oak Ridge National Laboratory, Oak Ridge, Tennessee

D. L. Leone, Sargent & Lundy, Chicago, Illinois

H. Lichtenberger, Combustion Engineering, Incorporated, Windsor, Connecticut

I. H. Mandil, MPR Associates, Incorporated, Washington, D.C.

Donald Vanderburg, Yankee Atomic Electric Company, Westboro, Maryland

ASMENORMDOC.COM : Click to view the full PDF of ASME N278.1 1975

The Task Force responsible for this standard included the following personnel during its development:

Name of Representative	Organization Represented
<i>W. A. Bush, Chairman</i>	Oak Ridge National Laboratory
<i>P. R. Burroughs</i>	Atomic Energy of Canada Limited
<i>F. Clemenson</i>	Atomic Energy Commission
<i>G. A. Jolley</i>	Henry Vogt Machine Company
<i>G. W. Knieser</i>	Anchor/Darling Valve Company
<i>R. Koester</i>	Wm. Powell Company
<i>B. H. Leonard</i>	Bechtel Power Corporation
<i>W. N. McLean, Advisor</i>	Crane Company
<i>G. McNutt</i>	Tennessee Valley Authority
<i>B. J. Milleville, Advisor</i>	Rockwell International
<i>G. Paptzun</i>	Lunkenheimer Valve Company
<i>R. S. Peterson</i>	United Nuclear Industries
<i>J. L. Renehan</i>	NUS Corporation
<i>S. N. Shields</i>	Walworth Company
<i>R. J. Smith</i>	Xomox Corporation

ASME N278.1 1975
Click to view the full PDF of ASME N278.1 1975

TABLE OF CONTENTS

SECTION		PAGE
1.	SCOPE	1
2.	DESIGN SPECIFICATION RELATIONSHIP	1
3.	FUNCTIONAL SPECIFICATION	1
	3.1 Valve Application Characteristics	1
	3.2 Structural Requirements	1
	3.3 Operational Requirements	2
	3.4 Seat Leakage Limits	2
	3.5 Pressure Relief Valve Characteristics	2
	3.6 Special Material Requirements	3
	3.7 Installation Requirements	3
	3.8 Maintenance Requirements	3

AMERICAN NATIONAL STANDARD

FUNCTIONAL SPECIFICATION STANDARD

1 SCOPE

This standard establishes requirements for functional specification for safety-related self-operated and power-operated valves for applications in a nuclear power plant.

2 DESIGN SPECIFICATION RELATIONSHIP

This standard provides detailed definition of functional requirements that supplements piping and valve codes and standards applicable to valves in safety-related piping systems whose safety-related function is to open, close, or regulate fluid flow. The requirements of this standard may be provided as part of the Valve Design Specification or as a separate document. Compliance with the requirements of this standard is intended to assure that the operating conditions and safety-related functions of the valve have been adequately defined, permitting valve and actuator manufacturers to identify designs of products and materials to be used in the manufacture of those products that will be adequate for the service.

3 FUNCTIONAL SPECIFICATION

It is the responsibility of the Owner who intends a valve to be in compliance with this standard to provide or cause to be provided a Functional Specification which identifies the safety-related function of the valve and provides for the delineation of the following.

- a. Structural Requirements, see Section 3.2
- b. Operational Requirements, see Section 3.3
- c. Seat Leakage Limits, see Section 3.4
- d. Pressure Relief Valve Characteristics, see Section 3.5
- e. Special Material Requirements, see Section 3.6
- f. Installation Requirements, see Section 3.7
- g. Maintenance Requirements, see Section 3.8

3.1 Valve Application Characteristics

The application characteristics of each valve shall be identified by listing whichever of the following descriptive terms are appropriate.

- a. Power-operated
- b. Self-operated
- c. Pressure relief
- d. Frequent use
- e. Infrequent use
- f. Low leakage
- g. Nominal leakage
- h. Normally open
- i. Normally closed

3.1.1 *Frequent use* is defined as requiring functional operation, including exercising and testing, in excess of 500 times over the life of the valve.

3.1.2 *Low leakage* is defined as valves in which the Manufacturer's main seat leakage acceptance test limit is 2 cubic centimeters of water per hour per inch of diameter of nominal valve size.

3.1.3 *Nominal leakage* is defined as valves in which the Manufacturer's main seat leakage acceptance test limit is 10 cubic centimeters of water per hour per inch of diameter of nominal valve size.

3.1.4 The leakage definitions described above are not applicable to those flow-control valves which are not intended to also serve as isolation or stop valves.

3.2 Structural Requirements

The following information shall be specified.

- a. The design pressure and temperature.
- b. The normal operating pressure and temperature.
- c. The flow capacity at a stated pressure differential.
- d. Time-temperature data for significant thermal transients, with number of cycles (see ASME Boiler and Pressure Vessel Code, Section III NB 3500).
- e. The seismic acceleration and dynamic loadings that the valve assembly shall be capable of withstanding without loss of functional capability.
- f. Loadings from structural supports and restraints acting directly on valve, if any.
- g. Fundamental frequency of valve assembly.