

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Semiconductor die products –
Part 2: Exchange data formats**

**Produits de puces de semiconducteurs –
Partie 2: Formats d'échange de données**

IECNORM.COM : Click to view the full PDF of IEC 62258-2:2011



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2011 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Semiconductor die products –
Part 2: Exchange data formats**

**Produits de puces de semiconducteurs –
Partie 2: Formats d'échange de données**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

XB

ICS 31.080.99

ISBN 978-2-88912-496-1

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope and object.....	8
2 Normative references.....	8
3 Terms and definitions	9
4 Requirements	9
5 Device Data eXchange format (DDX) file goals and usage.....	9
6 DDX file format and file format rules	9
6.1 Data validity.....	10
6.2 Character set.....	10
6.3 SYNTAX RULES.....	10
7 DDX file content.....	11
7.1 DDX file content rules.....	11
7.1.1 Block structure.....	11
7.1.2 Parameter types	11
7.1.3 Data types	11
7.1.4 Forward references.....	12
7.1.5 Units.....	12
7.1.6 Co-ordinate data	12
7.1.7 Reserved words.....	12
7.2 DDX DEVICE block syntax.....	13
7.3 DDX data syntax.....	14
8 Definitions of DEVICE block parameters	14
8.1 BLOCK DATA	15
8.1.1 DEVICE_NAME Parameter	15
8.1.2 DEVICE_FORM Parameter	16
8.1.3 BLOCK_VERSION Parameter	16
8.1.4 BLOCK_CREATION_DATE Parameter	16
8.1.5 VERSION Parameter	16
8.2 DEVICE DATA.....	16
8.2.1 DIE_NAME Parameter	16
8.2.2 DIE_PACKAGED_PART_NAME Parameter	16
8.2.3 DIE_MASK_REVISION Parameter	17
8.2.4 MANUFACTURER Parameter	17
8.2.5 DATA_SOURCE Parameter	17
8.2.6 DATA_VERSION Parameter	17
8.2.7 FUNCTION Parameter	17
8.2.8 IC_TECHNOLOGY Parameter.....	18
8.2.9 DEVICE_PICTURE_FILE Parameter	18
8.2.10 DEVICE_DATA_FILE Parameter	18
8.3 GEOMETRIC DATA.....	19
8.3.1 GEOMETRIC_UNITS Parameter	19
8.3.2 GEOMETRIC_VIEW Parameter	19
8.3.3 GEOMETRIC_ORIGIN Parameter	19
8.3.4 SIZE Parameter	20
8.3.5 SIZE_TOLERANCE Parameter.....	20

8.3.6	THICKNESS Parameter	21
8.3.7	THICKNESS_TOLERANCE Parameter	21
8.3.8	FIDUCIAL_TYPE Parameter	21
8.3.9	FIDUCIAL Parameter	23
8.4	TERMINAL DATA	24
8.4.1	TERMINAL_COUNT Parameter	24
8.4.2	TERMINAL_TYPE_COUNT Parameter	24
8.4.3	CONNECTION_COUNT Parameter	24
8.4.4	TERMINAL_TYPE Parameter	25
8.4.5	TERMINAL Parameter	26
8.4.6	TERMINAL_GROUP Parameter	29
8.4.7	PERMUTABLE Parameter	31
8.5	MATERIAL DATA	32
8.5.1	TERMINAL_MATERIAL Parameter	32
8.5.2	TERMINAL_MATERIAL_STRUCTURE Parameter	32
8.5.3	DIE_SEMICONDUCTOR_MATERIAL Parameter	32
8.5.4	DIE_SUBSTRATE_MATERIAL Parameter	33
8.5.5	DIE_SUBSTRATE_CONNECTION Parameter	33
8.5.6	DIE_PASSIVATION_MATERIAL Parameter	33
8.5.7	DIE_BACK_DETAIL Parameter	34
8.6	ELECTRICAL AND THERMAL RATING DATA	34
8.6.1	MAX_TEMP Parameter	34
8.6.2	MAX_TEMP_TIME Parameter	34
8.6.3	POWER_RANGE Parameter	34
8.6.4	TEMPERATURE_RANGE Parameter	34
8.7	SIMULATION DATA	35
8.7.1	Simulator MODEL FILE Parameter	35
8.7.2	Simulator MODEL FILE DATE Parameter	35
8.7.3	Simulator NAME Parameter	35
8.7.4	Simulator VERSION Parameter	35
8.7.5	Simulator COMPLIANCE Parameter	36
8.7.6	Simulator TERM_GROUP Parameter	36
8.8	HANDLING, PACKING, STORAGE and ASSEMBLY DATA	36
8.8.1	DELIVERY_FORM Parameter	36
8.8.2	PACKING_CODE Parameter	36
8.8.3	ASSEMBLY Parameters	36
8.9	WAFER SPECIFIC DATA	37
8.9.1	WAFER_SIZE Parameter	37
8.9.2	WAFER_THICKNESS Parameter	37
8.9.3	WAFER_THICKNESS_TOLERANCE Parameter	37
8.9.4	WAFER_DIE_STEP_SIZE Parameter	38
8.9.5	WAFER_GROSS_DIE_COUNT Parameter	38
8.9.6	WAFER_INDEX Parameter	38
8.9.7	WAFER_RETICULE_STEP_SIZE Parameter	38
8.9.8	WAFER_RETICULE_GROSS_DIE_COUNT Parameter	39
8.9.9	WAFER_INK Parameters	39
8.10	BUMP TERMINATION SPECIFIC DATA	39
8.10.1	BUMP_MATERIAL Parameter	39

8.10.2 BUMP_HEIGHT Parameter	40
8.10.3 BUMP_HEIGHT_TOLERANCE Parameter.....	40
8.10.4 BUMP_SHAPE Parameter.....	40
8.10.5 BUMP_SIZE Parameter	40
8.10.6 BUMP_SPECIFICATION_DRAWING Parameter.....	41
8.10.7 BUMP_ATTACHMENT_METHOD Parameter	41
8.11 MINIMALLY PACKAGED DEVICE (MPD) SPECIFIC DATA.....	41
8.11.1 MPD_PACKAGE_MATERIAL Parameter	41
8.11.2 MPD_PACKAGE_STYLE Parameter	41
8.11.3 MPD_CONNECTION_TYPE Parameter.....	42
8.11.4 MPD_MSL_LEVEL Parameter	42
8.11.5 MPD_PACKAGE_DRAWING Parameter.....	42
8.12 QUALITY, RELIABILITY and TEST DATA	42
8.12.1 QUALITY Parameters	42
8.12.2 TEST Parameters	43
8.13 OTHER DATA.....	43
8.13.1 TEXT Parameters	43
8.14 CONTROL DATA.....	43
8.14.1 PARSE Parameters	43
Annex A (informative) An example of a DDX DEVICE block.....	47
Annex B (informative) Groups and Permutation	49
Annex C (informative) A Typical CAD view from the DDX file block example given in Annex A.....	52
Annex D (informative) Properties for Simulation.....	53
Annex E (informative) TERMINAL and TERMINAL_TYPE graphical usage for CAD/CAM systems	55
Annex F (informative) Cross-reference with IEC 61360-4.....	58
Annex G (informative) Notes on VERSION and NAME parameters.....	61
Annex H (informative) Notes on WAFER parameters	62
Annex I (informative) Additional notes	64
Annex J (informative) DDX Version history	65
Annex K (informative) Parse Control.....	68
Figure 1 – Relationship between geometric centre and geometric origin.....	20
Figure C.1 – CAD representation of DDX example from Annex A	52
Figure E.1 – Highlighting the MX and MY orientation properties	56
Figure E.2 – Highlighting the angular rotational orientation properties	57
Figure H.1 – Illustrating the WAFER parameters.....	63
Table 1 – Terminal shape types.....	25
Table 2 – Terminal shape co-ordinates.....	26
Table 3 – Terminal IO types	28
Table 4 – Substrate Connection Parameters.....	33
Table F.1 – Parameter List.....	58
Table J.1 – Parameter Change History List.....	65

INTERNATIONAL ELECTROTECHNICAL COMMISSION

SEMICONDUCTOR DIE PRODUCTS –**Part 2: Exchange data formats**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62258-2 has been prepared by IEC technical committee 47: Semiconductor devices.

This standard shall be read in conjunction with IEC 62258-1.

This second edition cancels and replaces the first edition published in 2005, and constitutes a technical revision.

With respect to the first edition, the following parameters have been updated for this edition:

Subclause	Parameter name
8.2.9	DEVICE_PICTURE_FILE
8.2.10	DEVICE_DATA_FILE
8.4.6	TERMINAL_GROUP
8.4.7	PERMUTABLE
8.5.1	TERMINAL_MATERIAL (was DIE_TERMINAL_MATERIAL)
8.5.2	TERMINAL_MATERIAL_STRUCTURE
8.6.2	MAX_TEMP_TIME
8.7.6	SIMULATOR_simulator_TERM_GROUP
8.8.3	ASSEMBLY
8.9.2	WAFER_THICKNESS
8.9.3	WAFER_THICKNESS_TOLERANCE
8.9.9	WAFER_INK
8.10.4	BUMP_SHAPE
8.10.5	BUMP_SIZE
8.10.6	BUMP_SPECIFICATION_DRAWING
8.10.7	BUMP_ATTACHMENT_METHOD
8.11.4	MPD_MSL_LEVEL
8.11.5	MPD_PACKAGE_DRAWING
8.12.1	QUALITY
8.12.2	TEST
8.13.1	TEXT
8.14.1	PARSE

The text of this standard is based on the following documents:

FDIS	Report on voting
47/2085/FDIS	47/2095/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INTRODUCTION

This International Standard is based on the work carried out in the ESPRIT 4th Framework project GOODDIE which resulted in publication of the ES 59008 series of European specifications. Organisations that helped prepare this document include the ESPRIT ENCAST and ENCASIT projects, the Die Products Consortium, JEITA, JEDEC and ZVEI.

The structure of this International Standard as currently conceived is as follows:

Under main title: IEC 62258: Semiconductor die products

- Part 1: Procurement and use
- Part 2: Exchange data formats
- Part 3: Recommendations for good practice in handling, packing and storage (Technical report)
- Part 4: Questionnaire for die users and suppliers (Technical report)
- Part 5: Requirements for information concerning electrical simulation
- Part 6: Requirements for information concerning thermal simulation
- Part 7: XML schema for data exchange (Technical report)
- Part 8: EXPRESS model schema for data exchange (Technical report)

Further parts may be added as required.

IECNORM.COM : Click to view the full PDF of IEC 62258-2:2011

SEMICONDUCTOR DIE PRODUCTS –

Part 2: Exchange data formats

1 Scope and object

This Part of IEC 62258 specifies the data formats that may be used for the exchange of data which is covered by other parts of the IEC 62258 series, as well as definitions of all parameters used according to the principles and methods of IEC 61360. It introduces a Device Data Exchange (DDX) format, with the prime goal of facilitating the transfer of adequate geometric data between die manufacturer and CAD/CAE user and formal information models that allow data exchange in other formats such as STEP physical file format, in accordance with ISO 10303-21, and XML. The data format has been kept intentionally flexible to permit usage beyond this initial scope.

It has been developed to facilitate the production, supply and use of semiconductor die products, including but not limited to:

- wafers,
- singulated bare die,
- die and wafers with attached connection structures,
- minimally or partially encapsulated die and wafers.

This standard reflects the DDX data format at version **1.3.0**

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 62258-1, *Semiconductor die products – Part 1: Procurement and use*

IEC 61360-4:2005, *Standard data element types with associated classification scheme for electric components – Part 4: IEC reference collection of standard data element types, component classes*

ISO 8601:2004, *Data elements and interchange formats – Information interchange – Representation of dates and times*

ISO 6093:1985, *Information processing – Representation of numerical values in character strings for information interchange*

IPC/JEDEC J-STD-033B:2007, *Handling, Packing, Shipping and Use of Moisture/Reflow Sensitive Surface Mount Devices*

ISO 10303-21:2002, *Industrial automation systems and integration – Product data representation and exchange – Part 21: Implementation methods: Clear text encoding of the exchange structure*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 62258-1 apply.

4 Requirements

Specific reference for parameter variables is made to the IEC 61360 data element type (DET) codes, which are defined in Part 4 of IEC 61360.

5 Device Data eXchange format (DDX) file goals and usage

5.1 To facilitate the transferral of data by electronic media from the device vendor to the end-user for use within a CAD or CAE system, a data file format, **Device Data eXchange, (DDX)**, shall be used. This data file format has been deliberately kept flexible, to permit further enhancements and additions for future use.

5.2 It is strongly recommended that **Device Data eXchange** files have the three letter **DDX** file extension, and a **Device Data eXchange** file shall hereon be referred to as a **DDX** file.

5.3 Data that are to be transferred from a device vendor to a user shall be contained in a single computer-readable DDX file, and the minimum contents of this file shall suffice a geometric CAD/CAE software design system. The file shall be textually readable, to permit simple manual verification.

5.4 The DDX file and its data contents shall be independent of both computer machine and operating system.

5.5 The DDX file contents shall include mechanical and interconnectivity information, but may additionally include electrical and functional data.

5.6 The DDX file may contain data for one or more devices, and shall be capable of being used as a library file by a CAD/CAE software design system. The file may contain one or more sets of data for the same device type, each having different delivery forms, such as bumped die, bare die, and Chip-Scale packaging.

5.7 The DDX file shall be capable of being simply or automatically generated, such as by an ASCII text editor or a spreadsheet.

5.8 The DDX file shall be capable of referencing additional external files, such as simulation and thermal model files.

5.9 All data shall be defined in such a way that conversion to or from other exchange formats is possible, such as GDSII and CIF for geometric data of die. As close compatibility to the existing DIE (Die Information Exchange) data as possible is desired, to facilitate simple translation of partial DIE data files.

5.10 Definitions of parameters shall be in conformity with IEC 61360 (refer to Clause 5 of IEC 62258-1).

6 DDX file format and file format rules

NOTE 1 Version 1.2.1 of DDX supersedes version 1.0.0 contained in ES 59008-6-1.

NOTE 2 Version 1.3.0 of DDX supersedes version 1.2.1 contained in IEC 62258-2:2005.

Refer to Clause 1 for the DDX version of this standard.

6.1 Data validity

6.1.1 All data not complying with the data syntax (refer to 7.3) shall be treated as a remark and, as such, ignored.

6.1.2 All mandatory data shall be present. Missing data shall be flagged as an error, rendering that data unusable.

6.1.3 Mathematical operations, calculations or formulae shall not be permitted within numeric data.

6.2 Character set

6.2.1 The DDX file shall be an ASCII compatible text file with suitable line termination. Line termination will depend upon the operating system. DOS/Windows[®] generally uses a carriage/line-feed <CR/LF> terminator (ASCII 0Dh/0Ah), whereas UNIX[®] invariably relies solely upon a line-feed <LF> (ASCII 0x0A) terminator, the carriage return <CR> (ASCII 0x0D) being present by implication.

6.2.2 ASCII characters 0x00 to 0x7F are permitted, ASCII characters 0x80 to 0xFF shall be ignored.

6.2.3 All text data shall be case independent.

6.2.4 Space characters (ASCII 20h) and tab characters (ASCII 09h) shall both be treated as space separators, multiple space and tab characters will syntactically be treated as a single space separator.

6.3 SYNTAX RULES

6.3.1 All data lines shall be terminated with a semicolon: “;”.

6.3.2 A comma “,” shall be used as a data separator.

6.3.3 Lines beginning with a hash “#” shall be treated as an intentional comment. All data on that line shall be ignored.

6.3.4 Underscores “_” shall be ignored in a variable or property name, and may be used as intermediate name separators. Underscores are valid within textual string and name data.

6.3.5 Braces are used to open and close structures or BLOCKs. An open brace “{” shall be used to begin a structure or block, and a close brace “}” shall be used to terminate a structure or block.

6.3.6 Brackets “()” shall be permitted, then ignored, in numeric data for clarity (e.g. in co-ordinate pairs).

6.3.7 To accommodate typical spreadsheet CSV (Comma Separated Variable) format outputs, textual data may be inside double quotes “”, and matching pairs of double quotes shall be ignored.

6.3.8 There is no specific line continuation character. A textual string opened with a double quote “” shall close with a matching double quote “”, irrespective of the number of line breaks within that text. As all DDX commands terminate with a semicolon, the non-textual data will be

deemed to have ended at that semicolon. Textual data will be deemed to have ended at the semicolon following the closing double quote. Textual data not enclosed within double quotes may not include line break or control characters, and shall terminate at the first occurrence of a semicolon. Textual data following this semicolon will be treated as erroneous data and discarded.

6.3.9 For practicality, readability and ease of line parsing, it is recommended that the line length (between line termination characters) does not exceed 255 characters. It is further strongly recommended that a maximum limit of 1 023 characters per line be imposed to prevent other parsing software from having an input buffer overrun error.

7 DDX file content

7.1 DDX file content rules

7.1.1 Block structure

Data shall only exist within a block structure, referred to as a DEVICE block, and one or more DEVICE blocks, each containing data, may exist within a single file. Each DEVICE block is unique, and shall only contain data relevant to a single device, having a specific device form. All data within each DEVICE block shall be treated as being local and unique only to that block. (Refer to 6.3.4)

7.1.2 Parameter types

There are two types of parameters use for data, structures and variables, and these parameters shall only exist with a DEVICE block:

- a structure determines a set or multiple sets of data having different data types.
- a variable is equated to a single or multiple data of a single data type.

7.1.3 Data types

Data types are as follows.

7.1.3.1 Textual string data

All ASCII characters from ASCII 20h to ASCII 7Fh are permitted within textual data, characters including and above ASCII 80h shall be ignored. Consideration may be given to special print and display control characters to permit the printing of underscore or overscore characters. It is advised that textual string data is placed within pairs of double quotes, refer to 6.3.7.

7.1.3.2 Textual name data

All names shall be unique, and shall only consist of the following characters from the ASCII character set: -

A-Z a-z 0-9 \$ - % & ! @ _ .

When textual name data are used to form a file name, it is advisable for the name to be limited to eight characters for the file name and to three characters for the file extension, with a point “.” used as the name/extension delimiter, in line with many common operating systems. It is advisable for textual name data to be placed within pairs of double quotes (refer to 6.3.7).

Note that all textual name data is case independent, and spaces are not permitted within a textual name.

7.1.3.3 Real numeric data

Real numeric data shall comply with ISO 6093:1985, and shall consist of the characters: -

0-9 + - . E e

The data values may be signed, and use engineering or scientific notation, but shall not include dimensional units, e.g.

90008, 9000.80, 9.0008E5, -5207, -5.207E3, 0.102, 102E-3

Note that a comma “,” is used as a data separator, and therefore shall not be used as a replacement for a decimal point “.”.

7.1.3.4 Integer numeric data

Integer numeric data values shall comply to ISO 6093:1985, and only the characters **0** to **9** are permitted. Integers shall be unsigned, and shall not include dimensional units.

For practical purposes, an integer shall be limited to 16-bit resolution, i.e. integer values between and including 0 to 65536 only are acceptable.

7.1.3.5 Date data

Date data values shall comply with ISO 8601:2004 format, and may include time information as well, e.g.

“YYYY-MM-DD”, “YYYYMMDD”, “YYYY-MM-DDTHH:MM:SS”.

7.1.4 Forward references

To permit single-pass parsing, no variable identifier or variable name shall be referenced prior to being defined.

7.1.5 Units

All units shall belong to the SI system, apart from the geometric unit of the micron (10^{-6}m), the inch and the mil (10^{-3} inch). Only one unit of dimension shall be permitted within a single **DEVICE** block. Note that the inch and the mil are non-preferred units, and are only present due to continued common usage.

7.1.6 Co-ordinate data

In all co-ordinate data, the **X** co-ordinate shall precede the **Y** co-ordinate and the **Y** co-ordinate shall precede the **Z** co-ordinate (i.e. **X,Y** or **X,Y,Z**).

The **X** co-ordinate shall be the horizontal axis (numerically left to right), the **Y** co-ordinate shall be the vertical axis (numerically bottom to top), and the **Z** co-ordinate shall be depth axis (numerically near to far).

7.1.7 Reserved words

All parameter names shall be considered as reserved and no variable identifier or variable name shall be permitted to have the same name. This restriction does not apply to free form textual data within quotes or double quotes (as 7.1.3.1 and 7.1.3.2).

7.2 DDX DEVICE block syntax

```

DEVICE device_name device_form {
    relevant die data .....
}

```

The **DDX** file may contain one or more **DEVICE** blocks, all data pertaining to a particular device shall be embedded within the relevant block. (Refer to clause 6.1.1 and clause 7.1.1).

A **DEVICE** block is opened by the **DEVICE** keyword and opening brace "{", (as shown), and the **DEVICE** block is closed by the matching closing brace "}".

Data not within a **DEVICE** block structure shall be treated as a remark, permitting the future addition of checksum information, file creation date and historical data etc., within the **DDX** file, without affecting the actual device data.

The **device_name** is the given name by which the device shall be referred, and the **device_form** is the mechanical form of the device to which the block data pertains.

Valid data for the **device_form** variable are:

- **bare_die**,
- **bumped_die**,
- **lead_frame_die**
- **minimally_packaged_device** (or **MPD**).

Further **device_form** types may be added at a later stage, refer to IEC 61360-4:2005, AAD004-001, "die type code", for further details.

Only one **DEVICE** block having **device_name** of type **device_form** shall be present within the **DDX** file, but duplication of either **device_name** or **device_form** is permissible.

An example of a typical **DDX** file arrangement of **DEVICE** blocks:-

```

DEVICE name1 bare_die {
    relevant data for device "name1" as a bare die..
}
DEVICE name1 bumped_die {
    relevant data for device "name1" as a bumped die..
}
DEVICE name2 mpd {
    relevant data for device "name2" as a minimally packaged device..
}
DEVICE name2 bare_die {
    relevant data for device "name2" as a bare die..
}
DEVICE name1 mpd {
    relevant data for device "name1" as a minimally packaged device..
}
DEVICE name3 bare_die {
    relevant data for device "name3" as a bare die..
}

```

In the above example, there are three occurrences of a **DEVICE** block for device "name1", and two occurrences of a **DEVICE** block for device "name2", but each of these **DEVICE** blocks specify a different **device_form**. The order or sequencing of the **DEVICE** blocks has no relevance.

7.3 DDX data syntax

Property = value [, value];

<property>*[equate separator]***<value/variable {separator <value/variable> }>***[data terminator][line terminator]*

<property>	::=	Parameter name
[space]	::=	{space character (20h) or tab character (09h)}0+
[equate separator]	::=	[space]{equal =}[space]
[separator]	::=	[space]{comma ,}[space]
[data terminator]	::=	[space]{semicolon;}[space]
[line terminator]	::=	{CR or CR/LF}

For example:

```
thickness      =    100.0 ;
Thickness=470;
geometric_units=micron;
geometricunits      =    micron;
GeometricUnits= "millimetres";
terminal_type = T1, Circle, 220;
Terminal_Type = T2, Rectangle, 200 , 250;
TerminalType = T2, O, (200, 250);
TERMINALTYPE      =    T2, O, 200 , 250;
```

Thus, **terminal_type**, **Terminal_Type**, **TerminalType** and **TERMINALTYPE** will all reference the same parameter name.

8 Definitions of DEVICE block parameters

8.0 General usage notes

8.0.1 Device form notes

Where a parameter is unique to the **device_form**, as defined in the **DEVICE** block, the parameter will be preceded with the following ...

- 8.0.1.1 **DIE_** data parameter is unique to bare die or bumped die form
- 8.0.1.2 **BUMP_** data parameter is unique to only bumped die
- 8.0.1.3 **MPD_** data parameter is unique to a minimally packaged device, such as a CSP
- 8.0.1.4 **WAFER_** data parameter is unique to a die device delivered at wafer level
- 8.0.1.5 **LEAD_** data parameter is unique to a die device with attached lead frame.

8.0.2 Data Parameter Items

Within the following list of data parameters (see 8.1 onwards), the following items are shown:

- 8.0.2.1 the parameter name, as used syntactically within the **DDX** file,
- 8.0.2.2 the parameter type, indicating either a variable or structure data type,
- 8.0.2.3 the parameter function, determining its usage and meaning,
- 8.0.2.4 the parameter value, indicating the type of data expected,
- 8.0.2.5 any parameter limitation, indicating any limitation within the **DEVICE** block,
- 8.0.2.6 parameter dependencies, highlighting parameters that need to be declared prior to invocation,
- 8.0.2.7 one or more practical examples, and

8.0.2.8 any relevant notes.

A brief table of parameters is given in Annex F, and a working example of a full **DDX DEVICE** block is given in Annex A, with its expected graphical output in Annex C.

All parameters shall conform to the relevant IEC 61360 Data Element Type (DET) codes, as defined in IEC 61360-4:2005. Refer to Annex F for a cross-reference table.

8.0.3 Terms and conventions

A point of electrical connection is called a terminal. This may be a bond-pad for a bare die, and may equally refer to the landing or connection footprint area required by an interconnection medium. It is a common convention for die to have the initial terminal, numbered 1, in the upper left hand corner of the die, and for terminal or pin numbering to continue counter-clockwise in sequence.

The X co-ordinate dimensions are for the length in the horizontal plane with increasing positive values to the right. The Y co-ordinate dimensions are for the width in the horizontal plane with increasing positive values away from the user's view. The Z co-ordinate dimensions are for height in the vertical direction with increasing positive values upwards (towards the viewer).

As a point of reference, all die components, including bumped die, are generally viewed from above with the active side upwards.

8.0.4 Summary of general rules

- 8.0.4.1 All valid data shall be contained within a **DEVICE** block (refer to 7.1.1).
- 8.0.4.2 Any local or unique parameter, such as a name, shall be defined prior to its usage.
- 8.0.4.3 All parameters shall conform to the relevant IEC 61360 DET codes, as defined in Part 4 of IEC 61360 (refer to 5.8 and Annex F).
- 8.0.4.4 The units of measurement, **GEOMETRIC_UNITS**, shall be defined before any geometric variable is defined.
- 8.0.4.5 The geometric origin, **GEOMETRIC_ORIGIN**, and the geometric view, **GEOMETRIC_VIEW**, shall be defined before any geometric co-ordinates are defined.
- 8.0.4.6 The **TERMINAL_COUNT** parameter shall be defined before any **TERMINAL** parameters are referred to and the number of **TERMINAL** parameters shall not exceed the **TERMINAL_COUNT** value.
- 8.0.4.7 The **TERMINAL_TYPE_COUNT** parameter shall be defined before any **TERMINAL_TYPE** parameters are referred to and the number of **TERMINAL_TYPE** parameters shall not exceed the **TERMINAL_TYPE_COUNT** value.

8.1 BLOCK DATA

8.1.1 **DEVICE_NAME** Parameter

This is defined within the **DEVICE** block heading as the **device_name** parameter

Parameter Name	device_name
Parameter Type	Variable, refer to 7.2 on DEVICE blocks
Parameter Function	Defines the device manufacturer's type number or the reference name.
Parameter Values	Textual name data, as 7.1.3.2
Example	SN74LS04
Reference	See 7.1.7, 7.2 and Annex G.

8.1.2 DEVICE_FORM Parameter

This is defined within the **DEVICE** block heading by the **device_form** parameter.

Parameter Name	device_form
Parameter Type	Variable, refer to 7.2 on DEVICE blocks
Parameter Function	Defines the physical form of the device.
Parameter Values	Textual string data, as 7.1.3.1
Example	bare_die, bumped_die, MPD
Reference	Subclause 7.2 and Annex G.

8.1.3 BLOCK_VERSION Parameter

Parameter Name	BLOCK_VERSION
Parameter Type	Variable
Parameter Function	Specifies the version number and/or issue number of the DEVICE block.
Parameter Values	Textual string data, as 7.1.3.1
Limitations	Shall be declared only once within a single DEVICE block.
Example	BLOCK_VERSION = "1.0A";
Reference	Annex G.

8.1.4 BLOCK_CREATION_DATE Parameter

Parameter Name	BLOCK_CREATION_DATE
Parameter Type	Variable
Parameter Function	Specifies the date that the DEVICE block was created and last edited.
Parameter Values	Date, as 7.1.3.5
Limitations	Shall be declared only once within a single DEVICE block.
Example	BLOCK_CREATION_DATE = "1997-12-25";
Reference	Annex G.

8.1.5 VERSION Parameter

Parameter Name	VERSION
Parameter Type	Variable
Parameter Function	Specifies the revision/version number of the DDX standard, (currently at version 1.3.0), to which this DEVICE block conforms.
Parameter Values	Textual string data, as 7.1.3.1
Limitations	Shall be declared only once within a single DEVICE block.
Example	VERSION = "1.3.0";
Notes	Refer to Clause 1 for the version of this standard document. Note that this document may not be the latest version, so refer to your Standards Authority if in doubt.
Reference	Annex G.

8.2 DEVICE DATA

8.2.1 DIE_NAME Parameter

Parameter Name	DIE_NAME
Parameter Type	Variable
Parameter Function	Specifies the name of the die or mask set from which the die was produced. This may be different to the DEVICE_NAME parameter.
Parameter Values	Textual string data, as 7.1.3.1
Limitations	Shall be declared only once within a single DEVICE block.
Example	DIE_NAME = "XXC345";
Reference	Annex G.

8.2.2 DIE_PACKAGED_PART_NAME Parameter

Parameter Name	DIE_PACKAGED_PART_NAME
----------------	-------------------------------

Parameter Type	Variable
Parameter Function	Specifies the manufacturers part name for the equivalent packaged part, where available or applicable. This may be different to the DEVICE_NAME parameter.
Parameter Values	Textual string data, as 7.1.3.1
Example	DIE_PACKAGED_PART_NAME = "SN5405JN";
Notes	Used to reference the identical packaged die part, not merely similar function, when supplied by the same manufacturer in packaged form.

8.2.3 DIE_MASK_REVISION Parameter

Parameter Name	DIE_MASK_REVISION
Parameter Type	Variable
Parameter Function	Specifies the mask revision details associated with that particular version on the die.
Parameter Values	Textual string data, as 7.1.3.1
Limitations	Shall be declared only once within a single DEVICE block.
Example	DIE_MASK_REVISION = "RTDAC1"; DIE_MASK_REVISION = "9033-2-101-M5/2";
Notes	Intended to ensure that the die data matches the geometric version of the actual die.
Reference	Annex G.

8.2.4 MANUFACTURER Parameter

Parameter Name	MANUFACTURER
Parameter Type	Variable
Parameter Function	Specifies the manufacturer or fabrication house of the device.
Parameter Values	Textual string data, as 7.1.3.1
Limitations	Shall be declared only once within a single DEVICE block.
Example	MANUFACTURER = "Fuzziwuz Logic Inc.";

8.2.5 DATA_SOURCE Parameter

Parameter Name	DATA_SOURCE
Parameter Type	Variable
Parameter Function	Specifies the source of the device data, essentially where this is different from the manufacturer or fabrication house.
Parameter Values	Textual string data, as 7.1.3.1
Limitations	Shall be declared only once within a single DEVICE block.
Example	DATA_SOURCE = "AnyChip Technology Ltd."; DATA_SOURCE = "Good-Die database";

8.2.6 DATA_VERSION Parameter

Parameter Name	DATA_VERSION
Parameter Type	Variable
Parameter Function	Specifies the revision of the data source use to determine the parameters within the DEVICE block. This parameter is linked to 8.2.5, the DATA_SOURCE parameter.
Parameter Values	Textual string data, as 7.1.3.1
Limitations	Shall be declared only once within a single DEVICE block.
Example	DATA_VERSION = "Initial Issue 1.0";
Reference	Refer to Annex G.

8.2.7 FUNCTION Parameter

Parameter Name	FUNCTION
Parameter Type	Variable
Parameter Function	A brief description of the devices' function.
Parameter Values	Textual string data, as 7.1.3.1

Limitations	Shall be declared only once within a single DEVICE block.
Example	FUNCTION = "16 Bit Microprocessor";
Notes	IEC 61360-4:2005 specifies certain functional and application classes that may be used.

8.2.8 IC_TECHNOLOGY Parameter

Parameter Name	IC_TECHNOLOGY
Parameter Type	Variable
Parameter Function	Specifies the fabrication technology of the device.
Parameter Values	Textual string data, as 7.1.3.1
Limitations	Shall be declared only once within a single DEVICE block.
Example	<pre> IC_TECHNOLOGY = "CMOS"; IC_TECHNOLOGY = "bipolar"; IC_TECHNOLOGY = "bicmos"; IC_TECHNOLOGY = "GaAs"; </pre>

8.2.9 DEVICE_PICTURE_FILE Parameter

Parameter Name	DEVICE_PICTURE_FILE
Parameter Type	Variable
Parameter Function	Specifies the name(s) of the graphics or picture file(s) representing the device.
Parameter Values	Textual name data, as 7.1.3.2
Example	<pre> DEVICE_PICTURE_FILE = "DIE001.JPG"; DEVICE_PICTURE_FILE = "AA0B0C.SF", "FRED.GIF"; </pre>
Notes	The picture file may be an actual photograph, or a pictorial representation of the device. The file extent should indicate the file format used. Only file names, without relative or absolute path names, shall be used. Multiple parameters (picture file names) may be introduced within a single declaration, or multiple declarations maybe be employed to the same effect. There is no scaling or positional data requirement.
Reference	Annex I, Notes 3 and 4.

8.2.10 DEVICE_DATA_FILE Parameter

Parameter Name	DEVICE_DATA_FILE
Parameter Type	Variable
Parameter Function	Specifies the name(s) of a file(s) containing pertinent data, such as technical specifications, procurement documents or general data-sheets.
Parameter Values	Textual name data, as 7.1.3.2
Example	<pre> DEVICE_DATA_FILE = "SpecSheet.PDF"; DEVICE_DATA_FILE = "AA0B0C.DOC", "AA0B0C.TXT"; </pre>
Notes	The data file may be of any recognised format. The file extent should indicate the file format used. Only file names, without relative or absolute path names, shall be used. Multiple parameters (data file names) may be introduced within a single declaration, or multiple declarations maybe be employed to the same effect.
Reference	Annex I, Notes 3 and 4.

8.3 GEOMETRIC DATA

8.3.1 GEOMETRIC_UNITS Parameter


Parameter Name	GEOMETRIC_UNITS
Parameter Type	Variable
Parameter Function	Specifies the geometric units that shall apply to all geometric values within the DEVICE block.
Parameter Values	Textual string data, as 7.1.3.1. One of the following values: ▪ micrometre, or micron, ▪ metre, ▪ millimetre, ▪ inch ▪ mil (1.0E-3 inch)
Limitations	Shall be declared only once within a single DEVICE block.
Example	<code>GEOMETRIC_UNITS = microns;</code> <code>GEOMETRIC_UNITS = mil;</code>
Notes	This GEOMETRIC_UNITS parameter shall be declared before any geometric units are used. The micron is generally the default dimensional unit for die dimensions, and the inch and mil are non-preferred units.
Reference	Subclause 7.1.5 and Annex E.

8.3.2 GEOMETRIC_VIEW Parameter

Parameter Name	GEOMETRIC_VIEW
Parameter Type	Variable
Parameter Function	Specifies the geometric view that shall apply to all geometric shapes within the DEVICE block.
Parameter Values	Textual string data, as 7.1.3.1. One of the following values: • TOP meaning active side upwards, and • BOTTOM meaning active side downwards.
Limitations	Shall be declared only once within a single DEVICE block.
Example	<code>GEOMETRIC_VIEW = top;</code> <code>GEOMETRIC_VIEW = "bottom";</code>
Notes	The GEOMETRIC_VIEW parameter shall be declared before any geometric shapes are created. It would be common for a bare die and packaged part to be viewed in the "TOP" view, whereas bumped die may well be viewed from the "BOTTOM" (i.e. through the substrate).
Reference	Annex E.

8.3.3 GEOMETRIC_ORIGIN Parameter

Parameter Name	GEOMETRIC_ORIGIN
Parameter Type	Variable
Parameter Function	Determines the X- and Y-geometric origin from which all other co-ordinate pairs are referenced. The origin is given with respect to the geometric centre of the die in the units specified by the GEOMETRIC_UNITS parameter.
Parameter Values	Real X co-ordinate origin, Real Y co-ordinate origin, as 7.1.3.3
Dependencies	GEOMETRIC_UNITS, SIZE
Limitations	Shall be declared only once within a single DEVICE block.
Example	<code>GEOMETRIC_ORIGIN = -6000,-7500;</code>
Notes	Dimension values are in GEOMETRIC_UNITS. The origin co-ordinate pair values relate to the geometric die centre, refer to Figure 1. for further explanation.
Reference	Annex E.



IEC 895/11

Figure 1 – Relationship between geometric centre and geometric origin

The GEOMETRIC_ORIGIN is treated as an offset for all co-ordinate data, so that the GEOMETRIC_ORIGIN values are **added to all** individual co-ordinate data pairs to give the X- and Y- position relative to the geometric centre of the device.

The primary use of the GEOMETRIC_ORIGIN parameter is to permit the centring of the origin on a terminal or other geometric feature, rather than an arbitrary geometric position, as, in practice, SIZE may be subject to an asymmetric tolerance so that all related references to this geometric centre could therefore also be subject to a tolerance error.

8.3.4 SIZE Parameter

Parameter Name	SIZE
Parameter Type	Variable
Parameter Function	Determines the X- and Y- dimensions of the device, and optionally specifies its shape as an ellipse.
Parameter Values	Real X-dimension, Real Y-dimension, (as 7.1.3.3), {Ellipse}
Dependencies	GEOMETRIC_UNITS, GEOMETRIC_VIEW
Limitations	Shall be declared only once within a single DEVICE block.
Example	<pre>SIZE = 250, 500.5; SIZE = 350, 350, E;</pre>
Notes	Dimension values are in GEOMETRIC_UNITS. In the latter example, the character "E" as the 3rd parameter defines an ellipse, in this instance a circular die of 350 GEOMETRIC_UNITS in diameter.
Reference	Annex E.

8.3.5 SIZE_TOLERANCE Parameter

Parameter Name	SIZE_TOLERANCE
Parameter Type	Variable
Parameter Function	Specify the geometric tolerance(s) of the SIZE parameter values.
Parameter Values	Real in GEOMETRIC_UNITS, as 7.1.3.3

Dependencies	GEOMETRIC_UNITS, SIZE, GEOMETRIC_VIEW
Limitations	Shall be declared only once within a single DEVICE block.
Example	<pre> SIZE_TOLERANCE = 0.5; SIZE_TOLERANCE = -0.2, 0.5; SIZE_TOLERANCE = -0.2, 0.5, -0.1, 0.4; </pre>
Notes	One, two or four values may be given:- Where a single tolerance value is given, the tolerance shall be taken as an unsigned $\pm$ value for both the X- and Y-axis. Where two tolerance values are given:- the first value shall be taken as the minimum for both the X-axis and the Y-axis, the second value shall be taken as the maximum for both X-axis and the Y-axis. Where four tolerance values are given:- the first value shall be taken as the minimum for the X-axis, the second value shall be taken as the maximum for the X-axis, the third value shall be taken as the minimum for the Y-axis, and the fourth value shall be taken as the maximum for the Y-axis.

8.3.6 THICKNESS Parameter

Parameter Name	THICKNESS
Parameter Type	Variable
Parameter Function	Determines the thickness (Z-dimension) of the device.
Parameter Values	Real Z-dimension value, as 7.1.3.3
Dependencies	GEOMETRIC_UNITS
Limitations	Shall be declared only once within a single DEVICE block.
Example	THICKNESS = 10.5;
Notes	Dimension values are in GEOMETRIC_UNITS.

8.3.7 THICKNESS_TOLERANCE Parameter

Parameter Name	THICKNESS_TOLERANCE
Parameter Type	Variable
Parameter Function	Specifies the tolerance(s) of the THICKNESS parameter that may be expected due to normal process variations.
Parameter Values	Real in GEOMETRIC_UNITS, as 7.1.3.3
Dependencies	GEOMETRIC_UNITS, THICKNESS
Limitations	Shall be declared only once within a single DEVICE block.
Example	<pre> THICKNESS_TOLERANCE = 2.5; THICKNESS_TOLERANCE = -1.2, 1.5; </pre>
Notes	One or two values may be given:- Where a single tolerance value is given, the tolerance shall be taken as an unsigned $\pm$ value. Where two tolerance values are given:- the first value shall be taken as the minimum, and the second value shall be taken as the maximum.

8.3.8 FIDUCIAL_TYPE Parameter

Parameter Name	FIDUCIAL_TYPE
Parameter Type	Structure
Parameter Function	The FIDUCIAL_TYPE structure assigns a fiducial type name and defines the associated graphic file and size of an individual fiducial type. The structure may be used to define a single fiducial type, or a multiple of fiducial types.
Dependencies	GEOMETRIC_UNITS, GEOMETRIC_VIEW
Notes	A fiducial only exists as a graphic shape within a rectangle, the graphic data for the fiducial is held within an external graphic file. The co-

ordinate pairs for this rectangle are relative only to the fiducial shape type, and are used as references when placing the shape.

Reference

Annexes E and I.

Single FIDUCIAL_TYPE definition syntax:

```
FIDUCIAL_TYPE Fiducial_type_name = Fiducial_file_name, X-size, Y-size;
FIDUCIAL_TYPE Fiducial_type_name = Fiducial_file_name, X-size, Y-size;
```

Multiple FIDUCIAL_TYPE definition syntax:

```
FIDUCIAL_TYPE {
    Fiducial_type_name = Fiducial_file_name, X-size, Y-size;
    Fiducial_type_name = Fiducial_file_name, X-size, Y-size;
    Fiducial_type_name = Fiducial_file_name, X-size, Y-size;
}
```

where:

8.3.8.1 Fiducial_type_name

Textual reference name (as 7.1.3.2) for a fiducial type, which shall be unique within the DEVICE block.

8.3.8.2 Fiducial_file_name

This is the name of the file (as 7.1.3.2) that holds the fiducial as graphic data. The graphic data type shall be indicated by the file extension code, such as "BMP", "GIF", "DXF" etc. The data type is not specified with this standard, and it is up to the CAD/CAM software as to what can and cannot be displayed. The graphic shall be treated as being contained within a rectangle of X-size, Y-size dimensions.

8.3.8.3 X-size, Y-size

These real numeric parameters (as 7.1.3.3) comprise a co-ordinate pair, and determine the rectangle size of the fiducial graphic. The geometric centre of the fiducial graphic shall be determined as being (X-size/2, Y-size/2).

Example 1

```
FIDUCIAL_TYPE Fid1 = "tile.bmp", 200, 250;
```

This example describes a fiducial, found as an external file "tile.bmp", uniquely referred to as Fid1, with an X-size of 200 units, and a Y-size of 250 units. The units are defined by the GEOMETRIC_UNITS parameter.

Example 2

```
FIDUCIAL_TYPE {
    fidu1 = "graphic1.bmp", 200, 300;
    fidu2 = "graphic2.dxf", 500, 500;
    fidu3 = "graphic3.gif", 100, 100;
}
```

This multiple definition example describes three separate fiducial types and shapes:

- fidu1 is contained in file "graphic1.bmp", of size 200 by 300 units.
- fidu2 is contained in file "graphic2.dxf", of size 500 by 500 units.
- fidu3 is contained in file "graphic3.gif", of size 100 by 100 units.

8.3.9 FIDUCIAL Parameter

Parameter Name	FIDUCIAL
Parameter Type	Structure
Parameter Function	The FIDUCIAL structure defines the location and orientation of each individual graphic fiducial. As a structure, FIDUCIAL may be used to define a single fiducial, or a multiple of fiducials.
Dependencies	GEOMETRIC_VIEW, FIDUCIAL_TYPE, GEOMETRIC_UNITS, and GEOMETRIC_ORIGIN.
Notes	Each fiducial type name used shall have been previously declared in a FIDUCIAL_TYPE invocation, and co-ordinate pair information shall relate to the GEOMETRIC_ORIGIN of the device.
Reference	Annex E.

Single **FIDUCIAL** definition syntax:

```
FIDUCIAL F_n = Fiducial_type_name, X-co., Y-co., orientation;  
FIDUCIAL F_n = Fiducial_type_name, X-co., Y-co., orientation;
```

Multiple FIDUCIAL definition syntax:

```
FIDUCIAL {  
    F_n = Fiducial_type_name, X-co., Y-co., orientation;  
    F_n = Fiducial_type_name, X-co., Y-co., orientation;  
    F_n = Fiducial_type_name, X-co., Y-co., orientation;  
}
```

where:

8.3.9.1 **F_n**

Unique fiducial identifier, where “*n*” is the actual fiducial number (Integer, as in 7.1.3.4), numbering from top left anti-clockwise. Note that the underscore character is optional, it is used for clarity only.

8.3.9.2 **Fiducial_type_name**

Textual name (as in 7.1.3.2) of a referenced FIDUCIAL_TYPE shape (as 8.3.8.1), which shall have been previously declared, (refer to 7.1.4).

8.3.9.3 **X-co**

Numeric real X co-ordinate value (as 7.1.3.3) for location of the centre of the fiducial shape, in units defined by the GEOMETRIC_UNITS parameter. This value is relative to the X co-ordinate value of the GEOMETRIC_ORIGIN, and this parameter is identical in operation to that described in 8.4.5.4.

8.3.9.4 **Y-co**

Numeric real Y co-ordinate value (as 7.1.3.3) for location of the centre of the fiducial shape, in units defined by the GEOMETRIC_UNITS parameter. This value is relative to the Y co-ordinate value of the GEOMETRIC_ORIGIN, and this parameter is identical in operation to that described in 8.4.5.5.

8.3.9.5 **Orientation**

Orientation value, of integer values from 0 to 360 (see 7.1.3.4). This is the angle of clockwise rotation in degrees about the geometric reference centre of the fiducial shape. If the letters “**MX**” are included, then the orientation of the fiducial shape shall be mirrored in the X-axis, similarly if the letters “**MY**” are included, then the orientation of the fiducial shape shall be

mirrored in the Y-axis. Both “MX” and “MY” may be present simultaneously (refer to Annex D for a graphical representation), and all mirroring shall be done about the geometric reference centre of the fiducial shape. Note that the mirroring operation shall be carried out first, then the fiducial shall be rotated by the orientation angle. This parameter is identical in operation to that described in 8.4.5.6

Example 1

```
FIDUCIAL Fid007 = fidu1, 5000, 7000, MX0;
```

This example declares that fiducial **Fid007**.....

- is located at X = 5000 units, Y = 7000 units,
- is a FIDUCIAL_TYPE named “fidu1”, mirrored on the X-axis and orientated at 0°.

Example 2

```
FIDUCIAL F_18 = fiduX1, 1000, 2200, 90;
```

This example declares that fiducial **F_18**

- is located at X = 1000 units, Y = 2200 units
- is a FIDUCIAL_TYPE named “fiduX1”, orientated (rotated) by 90° clockwise.

Example 3

```
FIDUCIAL {
  Fid007=fidu1, 5000, 7000, MX0;
  F_18 = fiduX1, 1000, 2200, 90;
}
```

This multiple fiducial definition example declares identical fiducial data to that shown in Examples 1 and 2.

8.4 TERMINAL DATA

8.4.1 TERMINAL_COUNT Parameter

Parameter Name	TERMINAL_COUNT
Parameter Type	Variable
Parameter Function	Specifies the number of electrical terminal or points of connection.
Parameter Values	Integer, as in 7.1.3.4
Limitations	Shall be declared only once within a single DEVICE block.
Example	TERMINAL_COUNT = 44;
Notes	The TERMINAL_COUNT value shall be declared before any TERMINAL declaration or usage.

8.4.2 TERMINAL_TYPE_COUNT Parameter

Parameter Name	TERMINAL_TYPE_COUNT
Parameter Type	Variable
Parameter Function	Specifies the number of different connection or bond terminal types or shapes.
Parameter Values	Integer, as in 7.1.3.4
Limitations	Shall be declared only once within a single DEVICE block.
Example	TERMINAL_TYPE_COUNT = 4;
Notes	The TERMINAL_TYPE_COUNT value shall be declared before any TERMINAL_TYPE declaration or usage.

8.4.3 CONNECTION_COUNT Parameter

Parameter Name	CONNECTION_COUNT
Parameter Type	Variable, optional

Parameter Function	Specifies the maximum number of connections used by the TERMINAL parameter. This parameter actually specifies the highest value for the connection conn_N numbers used in the TERMINAL parameter declaration (refer to 8.4.5.2).
Parameter Values	Integer, as in 7.1.3.4
Limitations	Shall be declared only once within a single DEVICE block.
Example	CONNECTION_COUNT = 4;
Notes	The CONNECTION_COUNT value should be declared before any TERMINAL declaration or usage. It shall be used as a limit check for the connection conn_N numbers. If the CONNECTION_COUNT parameter is not declared, then no check will take place.

8.4.4 TERMINAL_TYPE Parameter

Parameter Name	TERMINAL_TYPE
Parameter Type	Structure
Parameter Function	The TERMINAL_TYPE structure assigns a type name and defines the shape and size of an individual terminal type. As a structure, TERMINAL_TYPE may be used to define a single terminal type, or a multiple of terminal types.
Dependencies	GEOMETRIC_UNITS, GEOMETRIC_VIEW, TERMINAL_TYPE_COUNT
Notes	The co-ordinate pairs are relative only to the terminal shape type, and are used as references when placing the shape.
Reference	Annex E.

Single TERMINAL_TYPE definition syntax:

```
TERMINAL_TYPE Terminal_type_name = Terminal_shape_type, Co-ordinates.,.,.;
TERMINAL_TYPE Terminal_type_name = Terminal_shape_type, Co-ordinates.,.,;
```

Multiple TERMINAL_TYPE definition syntax:

```
TERMINAL_TYPE {
    Terminal_type_name = Terminal_shape_type, Co-ordinates .,.,.;
    Terminal_type_name = Terminal_shape_type, Co-ordinates .,.,.;
    Terminal_type_name = Terminal_shape_type, Co-ordinates .,.,.;
}
```

where:

8.4.4.1 Terminal_type_name

Textual reference name for a terminal type, as in 7.1.3.2, which shall be unique within the DEVICE block.

8.4.4.2 Terminal_shape_type

Determines the terminal shape type (only the first letter need be used):

Table 1 – Terminal shape types

Char	DET data	Shape
R	RECT	<u>R</u> ectangle,
C	CIRC	<u>C</u> ircle,
E	ELL	<u>E</u> llipse,
P	POLY	<u>P</u> olygon.

8.4.4.3 Co-ordinates

Real co-ordinate values (refer to Table 2), as in 7.1.3.3.

This specifies the relative co-ordinates for the terminal shape, and in doing so, determines the geometric reference centre for the shape. The geometric reference centre of the shape will be used by the TERMINAL co-ordinates (see 8.4.5.4 and 8.4.5.5) to place the shape, and all rotation and mirroring will be about this geometric reference centre. Only the polygon shape can have a geometric reference centre other than the natural “centre-of gravity”.

Table 2 – Terminal shape co-ordinates

Shape	Co-ordinates	Geometric reference centre
<u>R</u> ectangle	X-size, Y-size	The geometric centre (0,0) will occur at X-size/2:Y-size/2
<u>C</u> ircle	Diameter	The geometric centre (0,0) will occur at diameter/2:diameter/2
<u>E</u> llipse	X-axis, Y-axis	The geometric centre (0,0) will occur at X-axis/2, Y-axis/2
<u>P</u> olygon	X-co ₁ , Y-co ₁ , X-co _N , Y-co _N	An “N” sided polygon will have N pairs of co-ordinates, geometrically centred upon (0,0), with the assumption that the polygon shape will be completed with the vector (Xco _N ,Yco _N - Xco ₁ ,Yco ₁)

Example 1

```
TERMINAL_TYPE ShapeR1 = Rectangle, 200, 250;
```

This example describes a rectangle, uniquely referred to as ShapeR1, with an X-axis dimension of 200 units, and a Y-axis dimension of 250 units. The units are defined by the GEOMETRIC_UNITS parameter.

Example 2

```
TERMINAL_TYPE {
    ShapeR1 = R, 200, 300;
    ShapeC2 = C, 250;
    ShapeE3 = E, 400, 200;
    ShapeP4 = P, (150, 200), (-150, 200), (-150, -150), (150, -150);
}
```

This example describes four separate terminal types and shapes:

- ShapeR1 is a rectangular terminal having an X-axis dimension of 200 units and a Y-axis dimension of 300 units,
- ShapeC2 is a circular terminal of 250 units in diameter,
- ShapeE3 is an elliptical terminal with the X-axis diameter of 400 units and Y-axis diameter of 200 units, and
- ShapeP4 is a 4-sided polygonal terminal shape, with a geometric reference centre of (0,0).

Note that only the first letter of the *Terminal_shape_type* descriptor is used, and that the *Terminal_type_names* are unique.

8.4.5 TERMINAL Parameter

Parameter Name **TERMINAL**
Parameter Type Structure

Parameter Function	The TERMINAL structure defines the name, location, orientation and electrical function of each individual connection terminal. As a structure, TERMINAL may be used to define a single terminal, or a multiple of terminals.
Dependencies	TERMINAL_COUNT, CONNECTION_COUNT, GEOMETRIC_VIEW, TERMINAL_TYPE, GEOMETRIC_UNITS, GEOMETRIC_ORIGIN.
Notes	Each terminal type name used shall have been previously declared in a TERMINAL_TYPE invocation, and co-ordinate pair information shall relate to the GEOMETRIC_ORIGIN of the device. Refer to Annex E.

Single TERMINAL definition syntax:

```

TERMINAL T_n = conn_N, Terminal_type_name, X-co., Y-co., orient.,
                  Terminal_name, IO_type;
TERMINAL T_n = conn_N, Terminal_type_name, X-co., Y-co., orient.,
                  Terminal_name, IO_type;

```

Multiple TERMINAL definition syntax:

```

TERMINAL {
    T_n = conn_N, Terminal_type_name, X-co., Y-co., orient.,
          Terminal_name, IO_type;
    T_n = conn_N, Terminal_type_name, X-co., Y-co., orient.,
          Terminal_name, IO_type;
    T_n = conn_N, Terminal_type_name, X-co., Y-co., orient.,
          Terminal_name, IO_type;
}

```

where:

8.4.5.1 **T_n**

Unique terminal identifier, where “*n*” is the actual terminal number (Integer, as 7.1.3.4), numbering from top left anti-clockwise. Note that the underscore character is optional, it is used for clarity only.

8.4.5.2 **conn_N**

Connection number, non-unique integer, as 7.1.3.4. This connection number is merely a place reference, and may optionally refer to a package pin; need not be present, or may be zero, 0, or left blank if unknown. The singular advantage of this connection number is in specifying and identifying multiple terminals that need to be connected together. The value of this connection number should be checked to ensure that it does not exceed the value determined by CONNECTION_COUNT, when specified.

8.4.5.3 **Terminal_type_name**

Textual name, as 7.1.3.2, of a referenced TERMINAL_TYPE terminal shape (as 8.4.3.1), which shall have been previously declared, (refer to 7.1.4).

8.4.5.4 **X-co**

Numeric real X co-ordinate value, as 7.1.3.3, for location of centre of the terminal shape, in units defined by the GEOMETRIC_UNITS parameter. This value is relative to the X co-ordinate value of the GEOMETRIC_ORIGIN.

8.4.5.5 Y-co

Numeric real Y co-ordinate value, as 7.1.3.3, for location of centre of the terminal shape, in units defined by the GEOMETRIC_UNITS parameter. This value is relative to the Y co-ordinate value of the GEOMETRIC_ORIGIN.

8.4.5.6 Orient

Orientation value, of integer values from 0 to 360, as 7.1.3.4. This is the angle of clockwise rotation in degrees about the geometric reference centre of the terminal shape. If the letters “MX” are included, then the orientation of the terminal shape shall be mirrored in the X-axis, similarly if the letters “MY” are included, then the orientation of the terminal shape shall be mirrored in the Y-axis. Both “MX” and “MY” may be present simultaneously (refer to Annex D for a graphical representation), and all mirroring shall be done about the geometric reference centre of the terminal shape. Note that the mirroring operation shall be carried out first, then the terminal shall be rotated by the orientation angle.

8.4.5.7 Terminal_name

Textual name, non-unique, as 7.1.3.2. This terminal name is for user reference and graphic display only, and may be omitted.

8.4.5.8 IO_type

A single letter indicating the terminal pin function type as given in Table 3, not mandatory. Further characters may be added as required.

Table 3 – Terminal IO types

Letter	Terminal Function
I	Input, digital
O	Output, digital
B	Bi-directional, digital
G	Ground connection
V	Supply, may be any supply type
A	Analog pin, input or output
N	No-connect pin, leave disconnected
U	Undetermined, user programmable I/O
T	Test pin, connect only under manufacturers advice
X	Internally connected, do not connect.
H	Digital functional input pin, to be held at a logic High
L	Digital functional input pin, to be held at a logic Low

T_n (see 8.4.5.1) shall always be unique, whereas the pin connection number (see 8.4.5.2), **conn_N**, and terminal name (see 8.4.5.7), **Terminal_name**, need not be unique.

Example 1

```
TERMINAL Pin007 = 9, ShapeR1, (5000, 7000), MX0, VCC1, V;
```

This example declares that terminal “Pin007”.....

- is connected to arbitrary connection # 9,
- is located at x = 5000 units, Y = 7000 units,

- is a `TERMINAL_TYPE` named “ShapeR1”, mirrored on the X-axis, orientated at 0°, and
- is called “VCC1”, and
- is a power supply pin.

Example 2

```
TERMINAL Conn08 = 17, ShapeP2, 5000, 7300, 90, qd2i, I;
TERMINAL Conn09 = 17, ShapeP2, 5000, 7800, 90, qd2o, O;
```

These example declare that terminals “**Conn08**” and “**Conn09**”.....

- are both connected to arbitrary connection # 17,
- are located at X = 5000 units, Y = 7300 units & X = 5000 units, Y = 7800 units respectively,
- are both a `TERMINAL_TYPE` named “ShapeP2”, orientated (rotated) by 90° clockwise,
- are named “qd2i” & “qd2o”
- and constitute a digital I/O bi-directional connection, with “qd2i” being an input (I) and “qd2o” being an output (O).

Example 3

```
TERMINAL Term10 = , ShapeP2, 5000, 7600, 0, , X;
```

This example declares that terminal “**Term10**”.....

- is unconnected (or with no specific connection reference),
- is located at X = 5000 units, Y = 7600 units,
- is a `TERMINAL_TYPE` named “ShapeP2”, orientated at 0°, and
- has no given name and
- is specified as not to be bonded to.

Example 4

```
TERMINAL T_44 = , ShapeR2, 25000, 97000, MXMY90, , ;
```

This example declares that terminal **T_44**.....

- is unconnected (or with no specific connection reference),
- is located at (25000:97000),
- is a `TERMINAL_TYPE` named “ShapeR2”, mirrored in both the X- and Y-axis, then orientated at (rotated clockwise by) 90°,
- has no given name, and
- has no specified electrical connection properties.

Example 5

```
TERMINAL {
    Pin007 = 9, ShapeR1, (5000, 7000), MX0, VCC1, V;
    Conn08 = 17, ShapeP2, (5000, 7300), 90, qd2i, I;
    Conn09 = 17, ShapeP2, (5000, 7800), 90, qd2o, O;
    Term10 = , ShapeP2, (5000, 7600), 0, , X;
    T_44 = , ShapeR2, (25000, 97000), MXMY90, , ;
}
```

This multiple terminal definition example declares identical terminal data to that shown in Examples 1 to 4.

8.4.6 TERMINAL_GROUP Parameter

Parameter Name	TERMINAL_GROUP
Parameter Type	Structure
Parameter Function	The <code>TERMINAL_GROUP</code> structure assigns a group of terminals to a single terminal-group identifier that may be used in place of a list of

	terminals. The structure may be used to define a single group or a multiple of groups. Refer to <code>TERMINAL_GROUP</code> Rules (voir 8.4.6.1) for detail.
Parameter Values	Two or more terminal or group identifiers, as defined in 8.4.5.1 and 8.4.6.3
Dependencies	<code>TERMINAL</code> (see 8.4.5)
Limitations	A <code>TERMINAL_GROUP</code> identifier must be unique, and may only referenced after it has been declared.
Reference	Annex B.

8.4.6.1 **TERMINAL_GROUP Rules**

8.4.6.1.1 **Content**

The elements forming a group may be terminal identifiers or group identifiers or any mixture of the two. A group must contain at least two elements.

8.4.6.1.2 **Uniqueness**

All elements within a group must be unique. A group may not contain groups that refer directly or indirectly to the same element.

8.4.6.1.3 **Ordering**

The order of elements within groups may be important. Where two or more groups are to be related in a permutation, then the elements within those groups must correspond across the groups.

8.4.6.1.4 **Recursion**

A group may not contain itself nor may it contain any group that refers directly or indirectly to itself

Single `TERMINAL_GROUP` definition syntax:

```
TERMINAL_GROUP Gn = _ Terminal or Group identifier, ... Terminal or Group identifier;  
TERMINAL_GROUP Gn = _ Terminal or Group identifier, ... Terminal or Group identifier;
```

Multiple `TERMINAL_GROUP` definition syntax:

```
TERMINAL_GROUP {  
    Gn = _ Terminal or Group identifier, ... Terminal or Group identifier;  
    Gn = _ Terminal or Group identifier, ... Terminal or Group identifier;  
}
```

where:

8.4.6.2 **G_{*n*}**

Unique `TERMINAL_GROUP` identifier, where “*n*” is the actual `TERMINAL_GROUP` number (Integer, as 7.1.3.4). Note that the underscore character is optional, it is used for clarity only.

8.4.6.3 **Terminal or Group identifier**

Two or more terminal or terminal-group identifier names, as

- Any terminal identifier name must be pre-declared in a `TERMINAL` statement, refer to 8.4.4.1. A terminal identifier name may occur only once within a single group assignment.
- Any terminal-group identifier name must be pre-declared in a `TERMINAL_GROUP` statement, refer to 8.4.6.2. A terminal-group identifier name may occur only once within a single group assignment and assignment circularity or recursion is not permitted.

Example

```

TERMINAL_GROUP G_1 = T_10, T_11, T_12;
TERMINAL_GROUP G_2 = T_15, T_16, T_12;

TERMINAL_GROUP {
    G_3 = T_1, T_2;
    G_4 = T_4, T_5;
    G_5 = G_1, T_3;
    G_6 = G_3, G_4, T_11;
}

```

Notes

In all cases, a single terminal identifier shall only occur with a group once. This is also relevant when considering the expansion of a terminal-group.
Refer to Annex B.

8.4.7 PERMUTABLE Parameter

Parameter Name PERMUTABLE

Parameter Type Structure

Parameter Function The PERMUTABLE structure assigns a list of terminals or terminal groups that are permutable. The list can comprise terminal identifiers (as 8.4.5.1) or terminal-group identifiers (as 8.4.6.2) but not a mixture of the two types of identifier. Each PERMUTABLE assignment declares that the terminals or terminal groups listed are exchangeable and/or swappable in terms of functionality. This is to facilitate alternative connection and routing by CAD software.
Refer PERMUTABLE Rules (see 8.4.7.1) for detail.
Refer to Annex B for further explanation.

Parameter Values The PERMUTABLE parameter statement shall consist of either a list of two or more terminal identifiers (see 8.4.6.1) or two or more terminal-group identifiers (see 8.4.6.1), but shall not contain a mixture of terminal and terminal-group identifiers.

Dependencies TERMINAL (see 8.4.5)
TERMINAL_GROUP (see 8.4.6)

Notes In all cases, a single terminal identifier shall only occur with a group once. This is relevant when considering the expansion of a terminal-group.
For correct permutation of terminal-groups within a single PERMUTABLE assignment, it is mandatory that the sequence of terminals within each group corresponds directly to the sequence of terminals of the other terminal-groups within the assignment.

Reference Annex B.

8.4.7.1 PERMUTABLE Rules**8.4.7.1.1 Content**

The elements forming a permutation may be terminal identifiers or group identifiers but not a mixture of the two. A permutation must contain at least two elements.

8.4.7.1.2 Uniqueness

All elements within a permutation must be unique. A permutation may not contain groups that refer directly or indirectly to the same element.
Each element within a permutation must contain the same number of Terminal identifiers (whether within Terminal Groups or not) as each other.

8.4.7.1.3 Ordering

The order of elements within a permutation is not important.

Single PERMUTABLE definition syntax:

PERMUTABLE **P_n** = *Terminal identifier, ... Terminal identifier;*
 PERMUTABLE **P_n** = *Terminal identifier, ... Terminal identifier;*
 PERMUTABLE **P_n** = *Group identifier, ... Group identifier;*
 PERMUTABLE **P_n** = *Group identifier, ... Group identifier;*

Multiple PERMUTABLE definition syntax:

```
PERMUTABLE {
    Pn = Terminal identifier, ... Terminal identifier;
    Pn = Terminal identifier, ... Terminal identifier;
    Pn = Group identifier, ... Group identifier;
    Pn = Group identifier, ... Group identifier;
}
```

Example

```
PERMUTABLE P_1 = T_1, T_2, T_3;
PERMUTABLE P_2 = GP1, GP2, GP3, GP5, GP4;

PERMUTABLE {
    P_1 = T_1, T_2;
    P_2 = T_4, T_5;
    P_3 = T_9, T_10;
    P_4 = T_12, T_13;
    P_5 = G_5, G_6, G_7, G_8;
}
```

8.5 MATERIAL DATA

8.5.1 TERMINAL_MATERIAL Parameter

Parameter Name	TERMINAL_MATERIAL
Parameter Type	Variable
Parameter Function	Specifies the material used for the final terminations on the device.
Parameter Values	Textual string data, as 7.1.3.1
Limitations	Shall be declared only once within a single DEVICE block.
Example	<pre>TERMINAL_MATERIAL = "Al"; TERMINAL_MATERIAL = "Copper"; TERMINAL_MATERIAL = "SAC405";</pre>

8.5.2 TERMINAL_MATERIAL_STRUCTURE Parameter

Parameter Name	TERMINAL_MATERIAL_STRUCTURE
Parameter Type	Variable
Parameter Function	Specifies the sequential structure of the materials used to build-up the terminations on the device.
Parameter Values	Textual string data, as 7.1.3.1
Limitations	Shall be declared only once within a single DEVICE block.
Example	<pre>TERMINAL_MATERIAL_STRUCTURE = "Al-Ti-Ni-Au";</pre>

8.5.3 DIE_SEMICONDUCTOR_MATERIAL Parameter

Parameter Name	DIE_SEMICONDUCTOR_MATERIAL
Parameter Type	Variable
Parameter Function	Specifies the semiconductor material, which is used for fabrication of the die.
Parameter Values	Textual string data, as 7.1.3.1
Limitations	Shall be declared only once within a single DEVICE block.
Example	<pre>DIE_SEMICONDUCTOR_MATERIAL = "Insulator"; DIE_SEMICONDUCTOR_MATERIAL = "Silicon"; DIE_SEMICONDUCTOR_MATERIAL = "Sapphire";</pre>
Notes	This parameter is only relevant if the die bulk material is different from the die substrate material.

8.5.4 DIE_SUBSTRATE_MATERIAL Parameter

Parameter Name	DIE_SUBSTRATE_MATERIAL
Parameter Type	Variable
Parameter Function	Specifies the bulk or substrate material on which the die is made where it differs from the DIE_SEMICONDUCTOR_MATERIAL.
Parameter Values	Textual string data, as 7.1.3.1
Limitations	Shall be declared only once within a single DEVICE block.
Example	<pre> DIE_SUBSTRATE_MATERIAL = "Silicon"; DIE_SUBSTRATE_MATERIAL = "Insulator"; DIE_SUBSTRATE_MATERIAL = "Sapphire"; </pre>

8.5.5 DIE_SUBSTRATE_CONNECTION Parameter

Parameter Name	DIE_SUBSTRATE_CONNECTION
Parameter Type	Variable
Parameter Function	Specifies the electrical connection for the substrate, if any. By fabrication, the substrate may be already electrically connected, which should also be stated. Where a substrate connection should be made, the potential point for connection shall also be stated.
Parameter Values	One or more textual string data, as 7.1.3.1 The first parameter shall conform to values given in Table 4
Limitations	Shall be declared only once within a single DEVICE block.
Example	<pre> DIE_SUBSTRATE_CONNECTION = "CONN", "Ground"; DIE_SUBSTRATE_CONNECTION = "N/A"; DIE_SUBSTRATE_CONNECTION = "ISOL"; DIE_SUBSTRATE_CONNECTION = "OPT", "Most Negative"; DIE_SUBSTRATE_CONNECTION = "OPT", "Most Positive"; DIE_SUBSTRATE_CONNECTION = "CONN", "Digital Vdd"; DIE_SUBSTRATE_CONNECTION = "OPT", "Analog ground"; </pre>

Table 4 – Substrate Connection Parameters

Parameter Value	Function
CONN	Must be electrically connected
ISOL	Must be electrically isolated
OPT	May be optionally connected
N/A	Not Applicable
N/K	Not Known (unknown)

Notes	When either "CONN" or "OPT" is given as the first parameter value, the second parameter value shall be comprehensively stated, sufficiently adequate to be understood for electrical connectivity. Recommended parameter values are: "Most Positive", "Most Negative", "GND", "AGND", "DGND", "VSS", "VDD", "VEE", "VCC", "AVSS", "AVDD", "AVEE", "AVCC", "DVSS", "DVDD", "DVEE", "DVCC", "VBIAS", or "SPECIAL". Alternatively, a specific TERMINAL name "T_n", as described in 8.4.5 may be used as the second parameter value for direct connection to the substrate.
-------	--

8.5.6 DIE_PASSIVATION_MATERIAL Parameter

Parameter Name	DIE_PASSIVATION_MATERIAL
Parameter Type	Variable
Parameter Function	Specifies the die surface passivation material.
Parameter Values	Textual string data, as 7.1.3.1
Limitations	Shall be declared only once within a single DEVICE block.
Example	<pre> DIE_PASSIVATION_MATERIAL = "Silicon Nitride"; DIE_PASSIVATION_MATERIAL = "Oxy-Nitride"; DIE_PASSIVATION_MATERIAL = "Polyimide"; </pre>

8.5.7 DIE_BACK_DETAIL Parameter

Parameter Name	DIE_BACK_DETAIL
Parameter Type	Variable
Parameter Function	Specifies the detail finish to the die backside, relevant for different attachment methods / package styles, to include both finish and material.
Parameter Values	Textual string data, as 7.1.3.1
Limitations	Shall be declared only once within a single DEVICE block.
Example	<pre> DIE_BACK_DETAIL = "Sawn"; DIE_BACK_DETAIL = "Au-Metallized"; DIE_BACK_DETAIL = "Backlapped"; DIE_BACK_DETAIL = "Polished"; DIE_BACK_DETAIL = "Gold Metal"; DIE_BACK_DETAIL = "None"; </pre>

8.6 ELECTRICAL AND THERMAL RATING DATA

8.6.1 MAX_TEMP Parameter

Parameter Name	MAX_TEMP
Parameter Type	Variable
Parameter Function	Specifies the maximum temperature to which the device may be exposed during any part of die attach, device soldering or other manufacturing process.
Parameter Values	Real, as 7.1.3.3
Parameter Units	°C, Celsius
Limitations	Shall be declared only once within a single DEVICE block.
Example	<code>MAX_TEMP = 280;</code>

8.6.2 MAX_TEMP_TIME Parameter

Parameter Name	MAX_TEMP_TIME
Parameter Type	Variable
Parameter Function	Specifies the maximum time for which the device may be exposed to the maximum temperature during any part of die attach, device soldering or other manufacturing process.
Parameter Values	Real, as 7.1.3.3
Parameter Units	Seconds
Dependencies	MAX_TEMP
Limitations	Shall be declared only once within a single DEVICE block.
Example	<code>MAX_TEMP_TIME = 10;</code>

8.6.3 POWER_RANGE Parameter

Parameter Name	POWER_RANGE
Parameter Type	Variable
Parameter Function	Specifies the power likely to be dissipated by the device.
Parameter Values	Real, as 7.1.3.3
Parameter Units	Watts
Limitations	Shall be declared only once within a single DEVICE block.
Example	<code>POWER_RANGE = 0.92;</code>
Notes	This parameter should be used with caution, as without fully specifying all measurement conditions, use of this value can be misunderstood. The value given should indicate the likely maximum power dissipated under "typical" worst-case conditions.

8.6.4 TEMPERATURE_RANGE Parameter

Parameter Name	TEMPERATURE_RANGE
Parameter Type	Variable
Parameter Function	Specifies the operation and specification range of the die.
Parameter Values	Minimum (Real, in °C), Maximum (Real, in °C), as clause 7.1.3.3

Parameter Units	⁰ C, Celsius
Limitations	Shall be declared only once within a single DEVICE block.
Example	TEMPERATURE_RANGE = -40, 90;
Notes	For use with bare die, this parameter should be used with caution, and is only intended to indicate the operational or specified temperature “grade” of the equivalent packaged part.

8.7 SIMULATION DATA

8.7.1 Simulator MODEL FILE Parameter

Parameter Name	SIMULATOR_simulator_MODEL_FILE
Parameter Type	Variable
Parameter Function	Specifies the name of the model file for use with <i>simulator</i> .
Parameter Values	Textual name data, as 7.1.3.2
Limitations	Shall be declared only once within a DEVICE block per <i>simulator</i> type.
Example	SIMULATOR_SPICE_MODEL_FILE = "BC109.MOD"; SIMULATOR_SPECTRE_MODEL_FILE = "RTBAA1.S";
Notes	Only file names, without relative or absolute path names, shall be used.
Reference	Annex D.

8.7.2 Simulator MODEL FILE DATE Parameter

Parameter Name	SIMULATOR_simulator_MODEL_FILE_DATE
Parameter Type	Variable
Parameter Function	Specifies the creation or validation date of the model file.
Parameter Values	Date, as 7.1.3.5
Limitations	Shall be declared only once within a DEVICE block per <i>simulator</i> type.
Example	SIMULATOR_SPICE_MODEL_FILE_DATE="19951021"; SIMULATOR_VHDL_MODEL_FILE_DATE="1993-05-17";
Notes	This date should match the date of the actual model file, to indicate that the correct model file is being used, and for use within a library make / build function.
Reference	Annex D.

8.7.3 Simulator NAME Parameter

Parameter Name	SIMULATOR_simulator_NAME
Parameter Type	Variable
Parameter Function	Specifies the name of either the generic or specific <i>simulator</i> to which the model file is appropriate.
Parameter Values	Textual string data, as 7.1.3.1
Limitations	Shall be declared only once within a DEVICE block per <i>simulator</i> type.
Example	SIMULATOR_SPICE_NAME = "pSpice"; SIMULATOR_VERILOG_NAME = "Verilog-XL";
Reference	Annex D.

8.7.4 Simulator VERSION Parameter

Parameter Name	SIMULATOR_simulator_VERSION
Parameter Type	Variable
Parameter Function	Specifies the version number of the <i>simulator</i> as specified by the SIMULATOR_simulator_NAME parameter, which was used to verify the model data.
Parameter Values	Textual string data, as 7.1.3.1
Limitations	Shall be declared only once within a DEVICE block per <i>simulator</i> type.
Example	SIMULATOR_SPICE_VERSION = "4.0.1"; SIMULATOR_VERILOG_VERSION = "1.7B";
Reference	Annex D.

8.7.5 Simulator COMPLIANCE Parameter

Parameter Name	SIMULATOR_simulator_COMPLIANCE
Parameter Type	Variable
Parameter Function	Specifies the minimum compliance level of the <i>simulator</i> required to both accurately reproduce and correlate with simulation results.
Parameter Values	Textual string data, as 7.1.3.1
Limitations	Shall be declared only once within a DEVICE block per <i>simulator</i> type.
Example	<pre>SIMULATOR_VHDL_COMPLIANCE = "VHDL '93"; SIMULATOR_SPICE_COMPLIANCE = "2G6";</pre>
Reference	Annex D.

8.7.6 Simulator TERM_GROUP Parameter

Parameter Name	SIMULATOR_simulator_TERM_GROUP
Parameter Type	Variable
Parameter Function	Specifies the group or terminals to which the simulator model applies. If missing, the assumption is that the simulator model applies to the whole device.
Parameter Values	A list of terminals (as 8.4.5.1) and/or terminal groups (as 8.4.6.2)
Limitations	The terminals or terminal groups referenced shall have already been declared in either a TERMINAL or TERMINAL_GROUP parameter. Shall be declared only once within a DEVICE block per <i>simulator</i> type.
Example	<pre>SIMULATOR_SPICE_TERM_GROUP = T_1, T_2, G_1; SIMULATOR_IBIS_TERM_GROUP = G_5, G_8, T_11, T_33;</pre>
Reference	Annexes B and D.

8.8 HANDLING, PACKING, STORAGE and ASSEMBLY DATA

8.8.1 DELIVERY_FORM Parameter

Parameter Name	DELIVERY_FORM
Parameter Type	Variable
Parameter Function	Specifies the form in which the die is delivered.
Parameter Values	Textual string data, as 7.1.3.1
Limitations	Shall be declared only once within a single DEVICE block.
Example	<pre>DELIVERY_FORM = "Wafer"; DELIVERY_FORM = "Die"; DELIVERY_FORM = "Bare Die in Waffle Tray"; DELIVERY_FORM = "Sawn Wafer"; DELIVERY_FORM = "Tray"; DELIVERY_FORM = "Bandoleer", "Waffle";</pre>

8.8.2 PACKING_CODE Parameter

Parameter Name	PACKING_CODE
Parameter Type	Variable
Parameter Function	Specifies the form of primary packing used for the supply of devices.
Parameter Values	Textual string data, as 7.1.3.1
Example	<pre>PACKING_CODE = "WAFFLE"; PACKING_CODE = "GEL_PACK"; PACKING_CODE = "Bandoleer";</pre>

8.8.3 ASSEMBLY Parameters

Parameter Name	ASSY_text-identifier
Parameter Type	Variable
Parameter Function	General textual parameter, to enable the user to include relevant and identified assembly techniques, parameters and operations.
Parameter Values	Textual string data, as 7.1.3.1
Examples	<pre>ASSY_PROCESS_LIMITATIONS = "NONE";</pre>
Notes	Recognised ASSY_identifiers are:

8.8.3.1	ASSY_PROCESS_LIMITATIONS
8.8.3.2	ASSY_STORAGE_LIMITATIONS
8.8.3.3	ASSY_ASSEMBLY_LIMITATIONS
8.8.3.4	ASSY_TEMPERATURE_LIMITATIONS
8.8.3.5	ASSY_BONDING_METHODS
8.8.3.6	ASSY_BONDING_MATERIALS
8.8.3.7	ASSY_ATTACH_METHODS
8.8.3.8	ASSY_ATTACH_MATERIALS
8.8.3.9	ASSY_GENERAL_REQUIREMENTS
8.8.3.10	ASSY_HANDLING_REQUIREMENTS
8.8.3.11	ASSY_PACKING_REQUIREMENTS
8.8.3.12	ASSY_STORAGE_REQUIREMENTS
8.8.3.13	ASSY_SHIPPING_REQUIREMENTS

8.9 WAFER SPECIFIC DATA

8.9.1 WAFER_SIZE Parameter

Parameter Name	WAFER_SIZE
Parameter Type	Variable
Parameter Function	Specifies the wafer diameter.
Parameter Values	Textual string data, as 7.1.3.1
Limitations	Shall be declared only once within a single DEVICE block.
Example	WAFER_SIZE = "6 inch"; WAFER_SIZE = "150mm";
Notes	As this is a dimensional value, but related to the fabrication and not the die size, the WAFER_SIZE parameter may be in units different to those defined by the GEOMETRIC_UNITS parameter, hence the data is presented as free-form text.

8.9.2 WAFER_THICKNESS Parameter

Parameter Name	THICKNESS
Parameter Type	Variable
Parameter Function	Determines the thickness (Z-dimension) of the wafer.
Parameter Values	Real Z-dimension value, as in 7.1.3.3
Dependencies	GEOMETRIC_UNITS
Limitations	Shall be declared only once within a single DEVICE block.
Example	WAFER_THICKNESS = 10.5; WAFER_THICKNESS = 80;
Notes	Dimension values are in GEOMETRIC_UNITS.

8.9.3 WAFER_THICKNESS_TOLERANCE Parameter

Parameter Name	WAFER_THICKNESS_TOLERANCE
Parameter Type	Variable
Parameter Function	Specifies the tolerance(s) of the WAFER_THICKNESS parameter that may be expected due to normal process variations.
Parameter Values	Real in GEOMETRIC_UNITS, as 7.1.3.3
Dependencies	GEOMETRIC_UNITS, WAFER_THICKNESS
Limitations	Shall be declared only once within a single DEVICE block.
Example	WAFER_THICKNESS_TOLERANCE = 2.5; WAFER_THICKNESS_TOLERANCE = -1.2, 1.5;
Notes	One or two values may be given:- Where a single tolerance value is given, the tolerance shall be taken as an unsigned $\pm$ value. Where two tolerance values are given:- the first value shall be taken as the minimum, and the second value shall be taken as the maximum.

8.9.4 WAFER_DIE_STEP_SIZE Parameter

Parameter Name	WAFER_DIE_STEP_SIZE
Parameter Type	Variable
Parameter Function	Determines the X- and Y- step size dimensions, in GEOMETRIC_UNITS, for the die on wafer, as required by mechanical handling equipment.
Parameter Values	Real X-dimension, Real Y-dimension, (as 7.1.3.3)
Dependencies	GEOMETRIC_UNITS, GEOMETRIC_VIEW
Limitations	Shall be declared only once within a single DEVICE block.
Example	WAFER_DIE_STEP_SIZE = 280, 530; WAFER_DIE_STEP_SIZE = 1500, 1500;
Reference	Annex H.

8.9.5 WAFER_GROSS_DIE_COUNT Parameter

Parameter Name	WAFER_GROSS_DIE_COUNT
Parameter Type	Variable
Parameter Function	Specifies the number of whole and viable gross die (of the die type in question) available on the wafer.
Parameter Values	Integer, as 7.1.3.4
Limitations	Shall be declared only once within a single DEVICE block.
Example	WAFER_GROSS_DIE_COUNT = 2027;
Notes	This parameter value is only intended to give an indication of the number of relevant and viable die per wafer, and shall have no other implication.
Reference	Annex H.

8.9.6 WAFER_INDEX Parameter

Parameter Name	WAFER_INDEX
Parameter Type	Variable
Parameter Function	Specifies the type of index feature on a wafer which acts as a reference feature and its orientation with respect to the X-axis for the die. The first parameter determines the index feature type, and the second parameter specifies the approximate angular relationship between the assumed X-axis for the die and the index feature on the wafer. The angle shall be given, in degrees counted clockwise, of the index feature, taking the X-axis of the die as the reference.
Parameter Values	Textual string data, as 7.1.3.1, with value "Flat" or "Notch", followed by a single integer value, in units of degrees, from 0 to 359, as 7.1.3.4.
Limitations	Shall be declared only once within a single DEVICE block.
Example	WAFER_INDEX = "Flat", 90; WAFER_INDEX = "Notch", 0;
Notes	This parameter is only intended as a guide, and so integer approximations shall be acceptable. Negative angle values are not permitted. Where more than one flat exists on the wafer, the orientation is with respect to the major, or prime, flat. This may also indicate the crystal [110] direction.
Reference	Annex H.

8.9.7 WAFER_RETICULE_STEP_SIZE Parameter

Parameter Name	WAFER_RETICULE_STEP_SIZE
Parameter Type	Variable
Parameter Function	Specifies X- and Y- step and repeat dimensions for a single reticule.
Parameter Values	Real X-dimension, Real Y-dimension, (as 7.1.3.3)
Dependencies	GEOMETRIC_UNITS, GEOMETRIC_VIEW
Limitations	Shall be declared only once within a single DEVICE block.
Example	WAFER_RETICULE_STEP_SIZE = 2500, 8000; WAFER_RETICULE_STEP_SIZE = 15000, 27500;

Notes	This parameter is relevant mainly for MPW (Multi Project Wafers), or instances where the WAFER_DIE_STEP_SIZE becomes invalid due to a non-integer relationship between reticule size and die size.
Reference	Annex H.

8.9.8 WAFER_RETICULE_GROSS_DIE_COUNT Parameter

Parameter Name	WAFER_RETICULE_GROSS_DIE_COUNT
Parameter Type	Variable
Parameter Function	Specifies the number of whole and viable gross die (of the die type in question) emplaced within a single reticule.
Parameter Values	Integer, as 7.1.3.4
Limitations	Shall be declared only once within a single DEVICE block.
Example	WAFER_RETICULE_GROSS_DIE_COUNT = 40;
Notes	This parameter is relevant mainly for MPW (Multi Project Wafers), or instances where there is more than one die type in the reticule. This parameter value is only intended to give an indication of the number of relevant and viable die per reticule, and shall have no other implication.
Reference	Annex H.

8.9.9 WAFER_INK Parameters

Parameter Name	WAFER_INK_text-identifier																
Parameter Type	Variable																
Parameter Function	General textual parameter, to enable the user to include relevant parameters relating to the wafer dot/ink size and colour. This is of particular relevance for visual systems for die selection, sorting and inspection.																
Parameter Values	Textual string data, as 7.1.3.1																
Examples	<pre> WAFER_INK_COLOUR = "BLACK"; WAFER_INK_LOCATION = "CENTRAL"; WAFER_INK_SIZE_MAX = "0.8mm"; WAFER_INK_SORT_COLOUR = "BIN1, RED, UPPER RIGHT"; WAFER_INK_SORT_COLOUR = "BIN2, GREEN, LOWER LEFT"; </pre>																
Notes	Recognised <i>WAFER_INK_identifiers</i> are: <table> <tr><td>8.9.9.1</td><td>WAFER_INK_COLOUR</td></tr> <tr><td>8.9.9.2</td><td>WAFER_INK_SIZE</td></tr> <tr><td>8.9.9.3</td><td>WAFER_INK_SIZE_TOL</td></tr> <tr><td>8.9.9.4</td><td>WAFER_INK_SIZE_MAX</td></tr> <tr><td>8.9.9.5</td><td>WAFER_INK_LOCATION</td></tr> <tr><td>8.9.9.6</td><td>WAFER_INK_LOCATION_TOL</td></tr> <tr><td>8.9.9.7</td><td>WAFER_INK_HEIGHT_MAX</td></tr> <tr><td>8.9.9.8</td><td>WAFER_INK_SORT_COLOUR</td></tr> </table>	8.9.9.1	WAFER_INK_COLOUR	8.9.9.2	WAFER_INK_SIZE	8.9.9.3	WAFER_INK_SIZE_TOL	8.9.9.4	WAFER_INK_SIZE_MAX	8.9.9.5	WAFER_INK_LOCATION	8.9.9.6	WAFER_INK_LOCATION_TOL	8.9.9.7	WAFER_INK_HEIGHT_MAX	8.9.9.8	WAFER_INK_SORT_COLOUR
8.9.9.1	WAFER_INK_COLOUR																
8.9.9.2	WAFER_INK_SIZE																
8.9.9.3	WAFER_INK_SIZE_TOL																
8.9.9.4	WAFER_INK_SIZE_MAX																
8.9.9.5	WAFER_INK_LOCATION																
8.9.9.6	WAFER_INK_LOCATION_TOL																
8.9.9.7	WAFER_INK_HEIGHT_MAX																
8.9.9.8	WAFER_INK_SORT_COLOUR																

8.10 BUMP TERMINATION SPECIFIC DATA

Any data given that is pertinent to a "bumped" device (a device using added bump connection structures) can only reflect the bump parameters at the time of bump formation, and not necessarily the final parameters. Due to the nature of final bump connection, the bump parameters will be altered and deformed during the attachment process. Therefore all geometric and metallurgical parameters given should be considered for "virgin" bumps.

8.10.1 BUMP_MATERIAL Parameter

Parameter Name	BUMP_MATERIAL
Parameter Type	Variable
Parameter Function	Specifies the metallurgical material of the bump contact.
Parameter Values	Textual string data, as clause 7.1.3.1
Limitations	Shall be declared only once within a single DEVICE block.

Example	<pre> BUMP_MATERIAL = "Copper"; BUMP_MATERIAL = "Molybdenum Telluride"; BUMP_MATERIAL = "Au"; BUMP_MATERIAL = "SAC415"; BUMP_MATERIAL = "Pb-Sn"; </pre>
Notes	Required only for device types with bump connection structures. Where a device has both bumped and non-bumped terminals, TERMINAL_MATERIAL should be used to describe the non-bumped terminals, and BUMP_MATERIAL should be used to describe the bumped terminal.

8.10.2 BUMP_HEIGHT Parameter

Parameter Name	BUMP_HEIGHT
Parameter Type	Variable
Parameter Function	Specifies the bump contact height above the passivation surface.
Parameter Values	Numeric real, in GEOMETRIC_UNITS , as 7.1.3.3
Dependencies	GEOMETRIC_UNITS
Limitations	Shall be declared only once within a single DEVICE block.
Example	<pre>BUMP_HEIGHT = 150.0;</pre>
Notes	Required only for device types with bump connection structures. The height of the bump can only be stated before the bump is modified by attachment and/or permanent connection.

8.10.3 BUMP_HEIGHT_TOLERANCE Parameter

Parameter Name	BUMP_HEIGHT_TOLERANCE
Parameter Type	Variable
Parameter Function	Specifies the tolerance of bump contact height above the passivation surface.
Parameter Values	Numeric real, in GEOMETRIC_UNITS , as 7.1.3.3
Dependencies	GEOMETRIC_UNITS , BUMP_HEIGHT
Limitations	Shall be declared only once within a single DEVICE block.
Example	<pre> BUMP_HEIGHT_TOLERANCE = 35.0; BUMP_HEIGHT_TOLERANCE = -10.0, 25.0; </pre>
Notes	One or two values may be given:- Where a single tolerance value is given, the tolerance shall be taken as an unsigned $\pm$ value. Where two tolerance values are given:- the first value shall be taken as the minimum, and the second value shall be taken as the maximum. Required only for device types with bump connection structures.

8.10.4 BUMP_SHAPE Parameter

Parameter Name	BUMP_SHAPE
Parameter Type	Variable
Parameter Function	Specifies the shape of bump the contact height.
Parameter Values	Textual string data, as 7.1.3.1
Limitations	Shall be declared only once within a single DEVICE block.
Example	<pre> BUMP_SHAPE="Pyramidical"; BUMP_SHAPE="Ball"; </pre>
Notes	Required only for device types with bump connection structures. The shape of the bump can only be stated before the bump is modified by attachment and/or permanent connection.

8.10.5 BUMP_SIZE Parameter

Parameter Name	BUMP_SIZE
Parameter Type	Variable
Parameter Function	Specifies the size of bump X-Y co-ordinates.
Parameter Values	Numeric real, in GEOMETRIC_UNITS , as 7.1.3.3

Dependencies	GEOMETRIC_UNITS
Limitations	Shall be declared only once within a single DEVICE block.
Example	BUMP_SIZE= "150,150";
Notes	Required only for device types with bump connection structures. The size of the bump can only be stated before the bump is modified by attachment and/or permanent connection.

8.10.6 BUMP_SPECIFICATION_DRAWING Parameter

Parameter Name	BUMP_SPECIFICATION_DRAWING
Parameter Type	Variable
Parameter Function	Specifies the name(s) of the bump specification drawing file(s).
Parameter Values	Textual name data, as 7.1.3.2
Example	BUMP_SPECIFICATION_DRAWING = "BumpShapel.JPG"; BUMP_SPECIFICATION_DRAWING = "BS1.JPG", "BS2.TIF";
Notes	Only file names, without relative or absolute path names, shall be used. Required only for device types with bump connection structures. Any drawing of the bump can only reflect the state of the bump before being modified by attachment and/or permanent connection. Multiple parameters (specification drawing files) may be introduced within a single declaration, or multiple declarations maybe be employed to the same effect. There is no scaling or positional data requirement.
Reference	Annex I, Note 3 and 4.

8.10.7 BUMP_ATTACHMENT_METHOD Parameter

Parameter Name	BUMP_ATTACHMENT_METHOD
Parameter Type	Variable
Parameter Function	Specifies the type of attachment method required or suggested for this type of bump.
Parameter Values	Textual string data, as 7.1.3.1
Limitations	Shall be declared only once within a single DEVICE block.
Example	BUMP_ATTACHMENT_METHOD = "Thermocompression"; BUMP_ATTACHMENT_METHOD = "Solder Reflow";
Notes	Required only for device types with bump connection structures.

8.11 MINIMALLY PACKAGED DEVICE (MPD) SPECIFIC DATA

8.11.1 MPD_PACKAGE_MATERIAL Parameter

Parameter Name	MPD_PACKAGE_MATERIAL
Parameter Type	Variable
Parameter Function	Specifies the package body material used as final encapsulation of the MPD.
Parameter Values	Textual string data as 7.1.3.1
Limitations	Shall be declared only once within a single DEVICE block.
Example	MPD_PACKAGE_MATERIAL = "Plastic"; MPD_PACKAGE_MATERIAL = "Epoxy"; MPD_PACKAGE_MATERIAL = "Ceramic"; MPD_PACKAGE_MATERIAL = "Metal Can";
Notes	Generally required for assembly purposes.

8.11.2 MPD_PACKAGE_STYLE Parameter

Parameter Name	MPD_PACKAGE_STYLE
Parameter Type	Variable
Parameter Function	Specifies the code for the package style as defined in a standard or as given by the manufacturer.
Parameter Values	Textual string data as 7.1.3.1
Limitations	Shall be declared only once within a single DEVICE block.

Example MPD_PACKAGE_STYLE = "SOT-23";
 MPD_PACKAGE_STYLE = "MO";
 MPD_PACKAGE_STYLE = "TSOP-48";

8.11.3 MPD_CONNECTION_TYPE Parameter

Parameter Name **MPD_CONNECTION_TYPE**
 Parameter Type Variable
 Parameter Function Specifies the connection method to the MPD, such as lead, bump etc.
 Parameter Values Textual string data, as 7.1.3.1
 Limitations Shall be declared only once within a single DEVICE block.
 Example MPD_CONNECTION_TYPE = "Bump";
 MPD_CONNECTION_TYPE = "TAB Lead";

8.11.4 MPD_MSL_LEVEL Parameter

Parameter Name **MPD_MSL_LEVEL**
 Parameter Type Variable
 Parameter Function Specifies the Moisture Sensitivity Level of the MPD package, in accordance with IPC/JEDEC J-STD-033B:2007 – Handling, Packing, Shipping and Use of Moisture/Reflow Sensitive Surface Mount Devices, 2005.
 Parameter Values Textual string data, as 7.1.3.1
 Limitations Shall be declared only once within a single DEVICE block.
 Example MPD_MSL_LEVEL = "3";

8.11.5 MPD_PACKAGE_DRAWING Parameter

Parameter Name **MPD_PACKAGE_DRAWING**
 Parameter Type Variable
 Parameter Function Specifies the name(s) of the MPD package specification drawing file(s).
 Parameter Values Textual name data, as 7.1.3.2
 Example MPD_PACKAGE_DRAWING = "PackageOutline.PDF";
 MPD_PACKAGE_DRAWING = "P01.JPG", "P01A.GIF";
 Notes Only file names, without relative or absolute path names, shall be used.
 Multiple parameters (package drawing files) may be introduced within a single declaration, or multiple declarations maybe be employed to the same effect.
 There is no scaling or positional data requirement.
 Reference Annex I, Notes 3 and 4.

8.12 QUALITY, RELIABILITY and TEST DATA

8.12.1 QUALITY Parameters

Parameter Name **QUAL_ *identifier***
 Parameter Type Variable
 Parameter Function General text parameter, to enable the user to include relevant and identified quality and reliability parameters.
 Parameter Values Textual string data, as 7.1.3.1
 Limitations Each identifier shall be declared only once within a single DEVICE block.
 Examples QUAL_OUTGOING_QUALITY_LEVEL = "...";

Notes Recognised **QUAL_ *identifiers*** are:

- 8.12.1.1 QUAL_OUTGOING_QUALITY_LEVEL
- 8.12.1.2 QUAL_OUTGOING_QUALITY_UNITS
- 8.12.1.3 QUAL_OUTGOING_QUALITY_DESCRIPTION
- 8.12.1.4 QUAL_RELIABILITY_VALUE
- 8.12.1.5 QUAL_RELIABILITY_UNITS
- 8.12.1.6 QUAL_RELIABILITY_REFERENCE

8.12.1.7	QUAL_RELIABILITY_CONDITIONS
8.12.1.8	QUAL_RELIABILITY_CALC_METHOD
8.12.1.9	QUAL_STANDARDS_COMPLIANCE

8.12.2 TEST Parameters

Parameter Name	TEST_ <i>identifier</i>
Parameter Type	Variable
Parameter Function	General text parameter, to enable the user to include relevant and identified test related parameters.
Parameter Values	Textual string data, as 7.1.3.1
Limitations	Each identifier shall be declared only once within a single DEVICE block.
Examples	TEST_ADDITIONAL_REQUIREMENTS = "NONE"; TEST_SCREEN_COMPLIANCE = "MIL-883B";
Notes	Recognised <i>TEST_</i> identifiers are:

8.12.2.1	TEST_ELECTRICAL_CONDITIONS
8.12.2.2	TEST_ADDITIONAL_SCREENING
8.12.2.3	TEST_TESTABILITY_FEATURES
8.12.2.4	TEST_ADDITIONAL_REQUIREMENTS
8.12.2.5	TEST_YIELD_CODE
8.12.2.6	TEST_FLOW
8.12.2.7	TEST_TEMP
8.12.2.8	TEST_SCREEN
8.12.2.9	TEST_SCREEN_COMPLIANCE

8.13 OTHER DATA

8.13.1 TEXT Parameters

Parameter Name	TEXT_ <i>identifier</i>
Parameter Type	Variable
Parameter Function	General text parameter, to enable the user to include relevant and identified text not otherwise covered.
Parameter Values	Textual string data, as 7.1.3.1
Limitations	Each identifier shall be declared only once within a single DEVICE block.
Examples	TEXT_SPECIAL_REQUIREMENTS = "N/A";
Notes	Recognised <i>TEXT_</i> identifiers are:

8.13.1.1	TEXT_PRODUCT_STATUS
8.13.1.2	TEXT_FORM_OF_SUPPLY
8.13.1.3	TEXT_SPECIAL_REQUIREMENTS
8.13.1.4	TEXT_SPECIFIC_REQUIREMENTS
8.13.1.5	TEXT_STORAGE_CONDITIONS
8.13.1.6	TEXT_STORAGE_DURATION
8.13.1.7	TEXT_LONGTERM_STORAGE
8.13.1.8	TEXT_ORIGINAL_MANUFACTURER
8.13.1.9	TEXT_ORIGINAL_DESIGN_DATE

8.14 CONTROL DATA

8.14.1 PARSE Parameters

Parameter Name	PARSE_ <i>identifier</i>
Parameter Type	Variable
Parameter Function	Specific parameters for use as control flags or parameters by the parsing software only, these parameters have no DEVICE related meaning nor function.

**Parameter Values
Notes**

Textual string data, as 7.1.3.1

The PARSE_xxx parameters are only applicable to data occurring subsequent to their invocation; this allows the PARSE_xxx parameters to be changed during parsing throughout a single DEVICE block. It is therefore strongly advised that if the PARSE_xxx parameters are to be used, the initial invocation occurs before any other data within the device BLOCK. Multi-pass parsers must accommodate this feature. These parse parameters may be modified or overridden by other options within the parsing software, such as command-line options. Refer to Annex K for further details.

Examples

```
PARSE_MODE = STRICT;
PARSE_ERROR_REPORT = TERSE;
PARSE_ERROR_TRAP = ALL;
PARSE_IGNORE = NONE;
PARSE_DEFINE_PARAMETER = "A_New_Parameter";
PARSE_DEFINE_STRUCTURE = "A_New_Structure";
```

8.14.1.1 PARSE_MODE

The PARSE_MODE parameter selects the severity of rule and syntax checking within a device BLOCK. Refer to Annex K for more detail.

The recognised PARSE_MODE parameters are:

```
STRICT
RELAXED
ENHANCED
USER
```

8.14.1.2 PARSE_ERROR_REPORT

The PARSE_ERROR_REPORT parameter determines how the warnings and errors uncovered during parsing of the device BLOCK are reported. A cumulative report of warnings and errors is expected once all parsing has been completed, this feature is not affected by this parameter. Refer to Annex K for further details.

The recognised PARSE_ERROR_REPORT parameters are:

OFF	No errors are reported during parsing
TERSE	Only errors are reported during parsing
VERBOSE	All warnings and errors are reported during parsing

8.14.1.3 PARSE_ERROR_TRAP

The PARSE_ERROR_TRAP parameter determines how the parsing software should proceed once an error has been uncovered. Refer to Annex K for further details.

The recognised PARSE_ERROR_TRAP parameters are:

ALL	Parser should not halt on error.
FIRST	Parser should halt on first error.

8.14.1.4 PARSE_IGNORE

The PARSE_IGNORE parameter determines whether the data is checked or not. Extreme caution must be exercised when using this parameter. Refer to Annex K for further details.

The recognised PARSE_ IGNORE parameters are:

NONE	All parsing checks are performed.
OFF	All parsing checks are performed (as NONE)
ALL	All parsing checks are ignored.
SYNTAX_ONLY	Only syntactical errors and line-termination checks.

8.14.1.5 PARSE_DEFINE_PARAMETER

The PARSE_DEFINE_PARAMETER parameter allows for the introduction and definition of new data parameters by name prior to them being incorporated within a new release of the DDX syntax. Refer to Annex K for further details.

Example:

```
PARSE_DEFINE_PARAMETER = "My_New_Parameter";
PARSE_DEFINE_PARAMETER = "My_Second_Parameter";
```

```
My_New_Parameter = "some data";
My_Second_Parameter = "some other data";
```

If the "new" parameter name conflicts with parameter names or reserved words already in existence, a warning should be flagged up, and the "new" parameter treated as defined in the current DDX standard, i.e. the PARSE_DEFINE_PARAMETER should be flagged as a warning, then ignored. This will allow the parsing software to accept these "new" parameters once they have been ratified without re-writing the DDX file.

The "new" name shall follow the general guidelines as set out in Clauses 5 to 7, and will only be valid within that device BLOCK. The "new" parameter will then be checked for syntax and parsed as if it were a standard parameter.

The PARSE_DEFINE_PARAMETER may occur as many times as needed, each statement may only introduce a single parameter, and must precede the use of that parameter.

Until ratified and incorporated with a new release of the DDX standard, all values pertaining to the "new" parameter will be treated as textual string data, as 7.1.3.1.

8.14.1.6 PARSE_DEFINE_STRUCTURE

The PARSE_DEFINE_STRUCTURE parameter allows for the introduction of new data structures by name prior to them being incorporated within a new release of the DDX syntax. Refer to Annex K for further details.

Example:

```
PARSE_DEFINE_STRUCTURE = "A_New_Structure";
PARSE_DEFINE_STRUCTURE = "Another_Structure";
```

```
A_New_Structure {
    NEW_STRUCTURE = "some data", "some more data";
    NEW_STRUCTURE = "some data", "some more data";
}
```

```
Another_Structure {
    ANOTHER_NEW_STRUCT = "some data", "some more data";
    ANOTHER_NEW_STRUCT = "some data", "some more data";
}
```

If the “new” structure name conflicts with structure names or reserved words already in existence, a warning should be flagged up, and the “new” structure treated as defined in the current DDX standard, i.e. the PARSE_DEFINE_STRUCTURE should be flagged as a warning, then ignored. This will allow the parsing software to accept these “new” structures once they have been ratified without re-writing the DDX file.

The “new” name shall follow the general guidelines as set out in Clauses 5 to 7, and will only be valid within that device BLOCK. The “new” structure will then be checked for syntax and parsed as if it were a structure.

The PARSE_DEFINE_STRUCTURE may occur as many times as needed, each statement may only introduce a single structure, and must precede the use of that structure.

The “*Structure_indent_name*” may be referenced as any other structure name, but again not within existing defined structure parameters until ratified.

Until ratified and incorporated with a new release of the DDX standard, all individual values contained within the “new” structure will be treated as textual string data, as 7.1.3.1.

Annex A (informative)

An example of a DDX DEVICE block

```

DEVICE 7995 bare_die {
#
# Initial header data, with block and device history.
#
BLOCK_CREATION_DATE = "2000-12-25";
BLOCK_VERSION = 1.0;
MANUFACTURER = "Fuzziwuzz Logic Ltd.";
FUNCTION = "Special gate";
DATA_SOURCE = "GOOD-DIE database";
DATA_VERSION = "Initial Issue A";
VERSION = "1.2.2";

#
# Declaration of geometric view, units, size etc.
#
GEOMETRIC_UNITS = millimetre;
GEOMETRIC_VIEW = "top";
SIZE = 1.312, 1.050;
SIZE_TOLERANCE = 0.00, 0.0005, 0.00 0.0005;
THICKNESS = 0.360;
THICKNESS_TOLERANCE = 0.00, 0.0007;
GEOMETRIC_ORIGIN = 0,0;

#
# Additional details of Die type and usage.
#
DIE_NAME = "XXZ322";
DIE_MASK_REVISION = "Mask 1.0";
MAX_TEMP = 280;
POWER_RANGE = 0.500;
DIE_SUBSTRATE_MATERIAL = "Silicon";
DIE_TERMINAL_MATERIAL = "Al";
IC_TECHNOLOGY = "bipolar";
DIE_SUBSTRATE_CONNECTION = "Ground";

#
# Delivery details.
#
DIE_BACK_DETAIL = "Back-Lapped";
DIE_DELIVERY_FORM = "Die, Wafer";
WAFER_SIZE = "4 inch";

#
# Definition of the number of bond pad types, bond pads
# and connections.
#
TERMINAL_TYPE_COUNT = 5;
TERMINAL_COUNT = 8;
CONNECTION_COUNT = 14;

```

```

#
# Definition of the bond pad shapes and dimensions.
#
TERMINAL_TYPE {
    PADR1 = Rectangle, 0.144, 0.104;
    PADR2 = Rectangle, 0.264, 0.104;
    PADR3 = Rectangle, 0.084, 0.084;
    PADC1 = Circle, 0.100;
    PADP1 = Polygon, (-0.0175,-0.042), (-0.042,-0.0175),
    (-0.042, 0.0175), (-0.0175, 0.042),
    ( 0.0175, 0.042), ( 0.042, 0.0175),
    ( 0.042,-0.0175), ( 0.0175,-0.042);
}

#
# Bond pad placement, naming, orientation and connectivity
# details.
#
TERMINAL {
    T1 = 1 ,PADC1,-0.550, 0.416, 0,VCCA ,P;
    T2 = 3 ,PADP1,-0.502, 0.190, 0,INPUTA ,I;
    T3 = 4 ,PADP1,-0.502,-0.192, 0,INPUTB ,I;
    T4 = 7 ,PADC1,-0.399,-0.442, 0,GNDA ,G;
    T5 = 8 ,PADR2, 0.498,-0.442, 0,GNDB ,G;
    T6 = 11,PADR3, 0.511,-0.171, 0,OUTPUTA,O;
    T7 = 12,PADR3, 0.511, 0.171, 0,OUTPUTB,O;
    T8 = 14,PADR1, 0.558, 0.416, 0,VCCB ,P;
}

#
# Details of a supplied pSpice simulation model.
#
SIMULATOR_SPICE_MODEL_FILE = "SP7995.MOD";
SIMULATOR_SPICE_MODEL_FILE_DATE = "1997-09-17";
SIMULATOR_SPICE_NAME = "pSpice";
SIMULATOR_SPICE_VERSION = "4.0.1";
SIMULATOR_SPICE_COMPLIANCE = "2G6";

#
# Details of a supplied Spectre simulation model.
#
SIMULATOR_SPECTRE_MODEL_FILE = "SP7995.S";
SIMULATOR_SPECTRE_MODEL_FILE_DATE = "1998-11-05";
SIMULATOR_SPECTRE_NAME = "Spectre";
SIMULATOR_SPECTRE_VERSION = "4.2.1, 1992";
SIMULATOR_SPECTRE_COMPLIANCE = "2G6, Level-3";

#
# Details of reference fiducial, supplied as a JIF graphic file
#
FIDUCIAL_TYPE fiduc1 = "7995FID1.JIF", 0.072, 0.055;
FIDUCIAL F1 = fiduc1, -0.612, 0.470, 0;

# End of block
}

```

Annex B (informative)

Groups and Permutation

A. Specific Rules for the **TERMINAL_GROUP** parameter

- Rule A1. **Content** (refer to 8.4.6.1.1) – The elements forming a group may be terminal identifiers or group identifiers or any mixture of the two. A group must contain at least two elements.
- Rule A2. **Uniqueness** (refer to 8.4.6.1.2) – All elements within a group must be unique. A group may not contain groups that refer directly or indirectly to the same element.
- Rule A3. **Ordering** (refer to 8.4.6.1.3) – the order of elements within groups may be important. Where two or more groups are to be related in a permutation, then the elements within those groups must correspond across the groups.
- Rule A4. **Recursion** (refer to 8.4.6.1.4) – A group may not contain itself nor may it contain any group that refers directly or indirectly to itself.

B. Specific Rules for the **PERMUTABLE** parameter

- Rule B1. **Content** (refer to 8.4.7.1.1) – The elements forming a permutation may be terminal identifiers or group identifiers but not a mixture of the two. A permutation must contain at least two elements.
- Rule B2. **Uniqueness** (refer to 8.4.7.1.2) – All elements within a permutation must be unique. A permutation may not contain groups that refer directly or indirectly to the same element. Each element within a permutation must contain the same number of Terminal identifiers (whether within Terminal Groups or not) as each other.
- Rule B3. **Ordering** (refer to 8.4.7.1.3) – the order of elements within a permutation is not important.

The simplest method of describing the use and function of the **TERMINAL_GROUP** and **PERMUTABLE** parameters is by analysing a simple example. Here, a fragment of a DDX file for a 7400 device is given. The 7400 device is a quad 2-input NAND gate, and so for functionality, all four NAND gates are exchangeable. Throughout the analysis we refer to terminals, but for a packaged part the user may consider the term “pins” to be more appropriate.

```

DEVICE 74ACT00 bare_die {

    BLOCK_CREATION_DATE = "13/02/2006";
    BLOCK_VERSION = 1.0;
    DEVICE_NAME = "74ACT00";
    MANUFACTURER = "Fuzziwuzz Logic Ltd";
    FUNCTION = "Quad two-input advanced CMOS NAND gate";
    DEVICE_FORM = "bare die";
    DATA_SOURCE = "GOOD-DIE Project database";
    VERSION = "1.3.0";
    GEOMETRIC_UNITS = micrometre;
    GEOMETRIC_VIEW = "top";
    SIZE = 1067, 1143;
    THICKNESS = 356;
    GEOMETRIC_ORIGIN = 0,0;
    DIE_NAME = "74ACT00";
    DIE_MASK_REVISION = "Mask T";
    MAX_TEMP = 150;

```

```

POWER_RANGE = 0.2;
IC_TECHNOLOGY = "CMOS";
DIE_SEMICONDUCTOR_MATERIAL = "silicon";
DIE_SUBSTRATE_CONNECTION = "CONN, Vcc";
DIE_DELIVERY_FORM = "Die, wafer";
TERMINAL_TYPE_COUNT = 1;

TERMINAL_TYPE {
    PADR1 = Rectangle, 97, 97;
}

TERMINAL_COUNT = 14;

TERMINAL {
    T_1 = 1, PADR1, -385, 422, 0, A1, I;
    T_2 = 2, PADR1, -385, 176, 0, B1, I;
    T_3 = 3, PADR1, -385, 11, 0, Y1, O;
    T_4 = 4, PADR1, -385, -236, 0, A2, I;
    T_5 = 5, PADR1, -208, -423, 0, B2, I;
    T_6 = 6, PADR1, -43, -423, 0, Y2, O;
    T_7 = 7, PADR1, 123, -423, 0, GND, G;
    T_8 = 8, PADR1, 385, -423, 0, Y3, O;
    T_9 = 9, PADR1, 385, -166, 0, B3, I;
    T_10 = 10, PADR1, 385, -1, 0, A3, I;
    T_11 = 11, PADR1, 385, 164, 0, Y4, O;
    T_12 = 12, PADR1, 385, 423, 0, B4, I;
    T_13 = 13, PADR1, 38, 423, 0, A4, I;
    T_14 = 14, PADR1, -129, 423, 0, VCC, P;
}

TERMINAL_GROUP {
    NAND_INA = T_1, T_2;
    NAND_INB = T_4, T_5;
    NAND_INC = T_9, T_10;
    NAND_IND = T_12, T_13;
    NAND_A = NAND_INA, T_3;
    NAND_B = NAND_INB, T_6;
    NAND_C = NAND_INC, T_8;
    NAND_D = NAND_IND, T_11;
}

PERMUTABLE {
    P_1 = T_1, T_2;
    P_2 = T_4, T_5;
    P_3 = T_9, T_10;
    P_4 = T_12, T_13;
    P_5 = NAND_A, NAND_B, NAND_C, NAND_D;
}

```

The 7400 device has 4 identical gates, Gates A to D, with the following characteristics:

7400 Device	INPUT1	INPUT2	OUTPUT
Gate A	T_1	T_2	T_3
Gate B	T_4	T_5	T_6
Gate C	T_9	T_10	T_8
Gate D	T_12	T_13	T_11

Regarding the DDX fragment above, we see that `TERMINAL_GROUP NAND_INA` groups the inputs for Gate A together, `NAND_INB` for Gate B and so on ...

`TERMINAL_GROUP NAND_A` similarly groups the inputs for Gate A along with the relevant output terminal, and again `NAND_B` to `NAND_D` follow the Gates B to D in similar fashion. Note

that the mixing of terminal-groups and terminals within the same statement (in accordance with **Rule A1**), and that the terminal ordering (**Rule A3**) of input terminals and then output terminal, is adhered to.

Finally, the PERMUTABLE statement can be analysed thus:

- P_1 states that the terminals T_1 and T_2 (Gate A) are interchangeable.
- P_2 states that the terminals T_4 and T_5 (Gate B) are interchangeable.
- P_3 states that the terminals T_9 and T_10 (Gate C) are interchangeable.
- P_4 states that the terminals T_12 and T_13 (Gate D) are interchangeable.
- P_5 states that groups NAND_A to NAND_D (Gates A to D) are interchangeable, so long as the sequence order of the terminals is adhered to.

Note that in the above example, we use “P_1 = T_1, T_2;” and not “P_1 = NAND_INA;”, as the latter statement would violate **Rule B1** in not having at least two elements.

As **Rule B3** states, the ordering of the elements is not important, such that the statement

P_5 = NAND_A, NAND_B, NAND_C, NAND_D;

shall have the same interpretation as

P_5 = NAND_D, NAND_C, NAND_B, NAND_A;


As **Rule B2** states, the following would **NOT** be acceptable

- P_7 = NAND_D, T_1, T_2; (unequal elements, also breaks **Rule B1**)
- P_8 = NAND_INA, NAND_B; (unequal elements)
- P_9 = NAND_INA, NAND_A; (unequal elements and possible recursion)
- P_10 = NAND_A, NAND_A; (possible recursion)

IECNORM.COM : Click to view the full PDF of IEC 62258-2:2011

Annex C (informative)

A Typical CAD view from the DDX file block example given in Annex A



IEC 896/11

Figure C.1 – CAD representation of DDX example from Annex A

Note that Figure C.1. is not intended to be a geometrically accurate drawing, the purpose is solely to assist visualise the output from the DDX example given in Annex A. (The Die Fiducial graphic is not shown). The CAD system has chosen to display the **DEVICE_NAME** (refer to 8.1.1) and the **DIE_MASK_REVISION** (refer clause 8.2.3) parameters for the die. The individual terminal identifiers and terminal names have similarly been selected for display (refer to 8.4.5 for details).

Annex D (informative)

Properties for Simulation

A DDX file can reference other external files, such as electrical simulation model files, mechanical model files and thermal modelling files.

To do this adequately, the following data shall be present:

- the file name and its creation date,
- the exact name of the simulator,
- its version
- the relevant compliance level to which this model applies,
- The terminals to which the model applies (electrical).

Within the model file there should be a textual note relating to the model's capability, applicability and accuracy, specifically noting any shortcomings of the model and its usage. The text "**simulator**" shall be replaced with either the actual or generic name of the simulator used and/or model data. Typical "**simulator**" names might be Verilog, VHDL, SPICE, ELDO, BSDL, IBIS etc.

- 8.7.1 SIMULATOR_simulator_MODEL_FILE**
Data presented as a file name. All file names given shall not include any absolute computer drive, computer path reference, or any details that cause the information to become computer or operating system specific or dependent.
- 8.7.2 SIMULATOR_simulator_MODEL_FILE_DATE**
Data presented as a date, as per ISO 8601.
- 8.7.3 SIMULATOR_simulator_NAME**
Data presented as text of the actual simulator used to prove the model.
- 8.7.4 SIMULATOR_simulator_VERSION**
Data presented as text determining the actual version or revision of the simulator against which the model file was proven.
- 8.7.5 SIMULATOR_simulator_COMPLIANCE**
Data presented as text which reflects the overall compliance of the simulator model, where applicable. "2G6", "VHDL '93", "IEEE 1364-2001" or "IEEE 1076.3-97" are examples of industry recognised compliance levels.
- 8.7.6 SIMULATOR_simulator_TERM_GROUP**
Determines the terminals or terminal groups to which the simulator applies when the model file only covers a limited range of terminals, otherwise it is assumed that the model file covers the entire device. This parameter therefore permits the restriction of the simulation model to specific terminals or groups of terminals, and by its absence, implies that the simulation model is applicable to all device terminals.

Example:

```
SIMULATOR_SPICE_MODEL_FILE = "RTBAE2.MOD";
SIMULATOR_SPICE_MODEL_FILE_DATE = "1997-09-17";
SIMULATOR_SPICE_NAME = "pSpice";
```

```
SIMULATOR_SPICE_VERSION = "4.0.1";  
SIMULATOR_SPICE_COMPLIANCE = "2G6";  
TERMINAL_GROUP G_1 = P8, P9, P10;  
TERMINAL_GROUP G_2 = P28, P29, P30;  
SIMULATOR_SPICE_TERM_GROUP = T_1, T_2, G_1, G_2;
```

IECNORM.COM : Click to view the full PDF of IEC 62258-2:2011

Annex E (informative)

TERMINAL and TERMINAL_TYPE graphical usage for CAD/CAM systems

The creation of a CAD/CAE “view” of the device from the data within the **DEVICE** block may be considered as having four separate steps. There is no geometric layer information contained within the DDX format, and it is assumed that all geometric data shall be displayed on a single layer. Textual information may be provided on a separate layer.

The **GEOMETRIC_UNITS** parameter (see 8.3.1) defines the appropriate scaling factors to be employed, and sets the scene for all further numerical input from that **DEVICE** block. The **GEOMETRIC_VIEW** parameter (see 8.3.2) determines whether the device is being viewed from the top or bottom.

The device outline is created from the **SIZE** parameter (see 8.3.4), and any geometric offset for further geometric placement is calculated from the **GEOMETRIC_ORIGIN** parameter (see 8.3.3). Data such as device name and type is collected and prepared for display purposes. Note that the **GEOMETRIC_ORIGIN** parameter is referenced to the XSIZE and YSIZE parameters, before tolerancing, as XSIZE/2, YSIZE/2. The **GEOMETRIC_ORIGIN** parameter values are added to this reference for all relative geometric parameters. The **SIZE_TOLERANCE** parameter (see 8.3.5) values may also be used to indicate the minimum and maximum device outline.

The **TERMINAL_COUNT**, **TERMINAL_TYPE_COUNT** and **CONNECTION_COUNT** parameters (see 8.4.1, 8.4.2 and 8.4.3) are essentially duplicated, as their values may be calculated from the **TERMINAL** (see 8.4.5) and **TERMINAL_TYPE** (see 8.4.4) structures. They are intended, however, to be used as a “sanity” check, to ensure correct parsing, and highlight any file or BLOCK corruption. The **TERMINAL_TYPE_COUNT** value can only be less than or equal to the **TERMINAL_TYPE** value. The **CONNECTION_COUNT** value has no such restriction.

The shapes of the terminals or connecting areas are separately defined, each shape having its own geometric reference centre. These shapes are defined with the **TERMINAL_TYPE** structure. Each of these terminal shapes can be placed anywhere within the device outline and, as there is no placement limitation, may be placed outside the device outline should the user so desire (e.g. pad placement for PCB-type connections). The **TERMINAL_TYPE** structure introduces **Terminal_Type_Names** (see 8.4.4.1 and 8.4.5.3) that shall be unique within the **DEVICE** block; these names are placeholders for subsequent usage by the **TERMINAL** structure, and so should be introduced prior to the **TERMINAL** structure statement using the placeholder name to permit single pass parsing of the **DEVICE** block. To prevent any possible ambiguity, it is strongly advised that the **Terminal_Type_Names** be limited to alphanumeric characters.

These terminals types (shapes), having been defined, may now be referenced by their **Terminal_Type_Name**, and geometrically placed by the **TERMINAL** structure in sequence (**T_n**), at given locations (the X & Y co-ordinates), orientated by mirroring (Figure E.1) and clockwise rotation (Figure E.2), and finally assigned a terminal name and I/O function for further use by the CAD system. The **Terminal_name** (see 8.4.5.7) would usually be visible as text, for visual convenience and need not be unique. The **Terminal_name** can also indicate terminals that will usually be electrically connected together, such as “VDD”, “VSS”, “Ground” etc.. A connection number (**conn_N**) may also be assigned and whilst this number bears no relation to the actual terminal number, it can be used for identifying common groups of pins, (such as pins that must be connected together), or actually referring to the original device’s packaged pin-out (which again can be different to the die pad numbering). The functional I/O details (**IO_type**) (see 8.4.5.8) of each terminal are available for further connectivity checks by the CAD system. The unique **TERMINAL** identifier, (**T_n**) (see 8.4.5.1), can have any mix of


alphanumeric characters, and need not be in, nor follow, any particular sequence. The only requisite is that, as an identifier, it is unique within that **DEVICE** block, and to prevent any possible ambiguity, it is strongly advised that the unique identifier, (T_n) be limited to alphanumeric characters.

Where applicable, the **DIE_SUBSTRATE_CONNECTION** (see 8.5.5) details should be displayed, alerting the user to the need to facilitate appropriate connection.

The creation and placement of fiducials is identical to that for terminals by using the **FIDUCIAL_TYPE** (see 8.3.8) and **FIDUCIAL** (see 8.3.9) parameter structures (q.v.). The main differences being that


- graphical fiducial data are only held within a separate graphic file, and
- that fiducials do not have any connectivity or electrical properties.

It is up to the CAD/CAM system to determine as to how to display the graphic content of the fiducial graphic file, as there are currently a plethora of graphical file standards. The fiducial graphic shall be scaled to fit within the size dimensions given by the **FIDUCIAL_TYPE** parameter structure, whose reference and placement centre will be taken as the midpoint of the X- and Y-size dimensions. The actual content and type of graphical data within this file is commonly determined by the file extent. i.e. TIFF, GIF, JPEG, BMP.



IEC 897/11

Figure E.1 – Highlighting the MX and MY orientation properties



IEC 898/11

Figure E.2 – Highlighting the angular rotational orientation properties

Annex F (informative)

Cross-reference with IEC 61360-4

The table below provides a read-across between the parameters in this standard and the DET definitions given in IEC 61360-4:2005.

Table F.1 – Parameter List

Clause/ Sub- clause	Parameter Name	Parameter Type	Data Type	DET Code
8.1	BLOCK DATA			
8.1.1	DEVICE_NAME	Header	Text	AAH547-001
8.1.2	DEVICE_FORM	Header	Text	AAD004-001
8.1.3	BLOCK_VERSION	Variable	Text	
8.1.4	BLOCK_CREATION_DATE	Variable	Date	
8.1.5	VERSION	Variable	Text	
8.2	DEVICE DATA			
8.2.1	DIE_NAME	Variable	Text	AAD002-001
8.2.2	DIE_PACKAGED_PART_NAME	Variable	Text	AAD143-001
8.2.3	DIE_MASK_REVISION	Variable	Text	AAD003-001
8.2.4	MANUFACTURER	Variable	Text	AAD140-001
8.2.5	DATA_SOURCE	Variable	Text	AAD142-001
8.2.6	DATA_VERSION	Variable	Text	
8.2.7	FUNCTION	Variable	Text	
8.2.8	IC_TECHNOLOGY	Variable	Text	AAE686-005
8.2.8	DEVICE_PICTURE_FILE	Variable	File Name	
8.2.9	DEVICE_DATA_FILE	Variable	File Name	
8.3	GEOMETRIC DATA			
8.3.1	GEOMETRIC_UNITS	Variable	Real	AAD115-001
8.3.2	GEOMETRIC_VIEW	Variable	Text	AAD144-001
8.3.3	GEOMETRIC_ORIGIN	Variable	Real	AAD129 & 130-001
8.3.4	SIZE	Variable	Real	AAD070 & 071-001
8.3.5	SIZE_TOLERANCE	Variable	Real	AAD117-001
8.3.6	THICKNESS	Variable	Real	AAD072-001
8.3.7	THICKNESS_TOLERANCE	Variable	Real	AAD118-001
8.3.8	FIDUCIAL_TYPE	Structure		AAD156 to 159-001
8.3.9	FIDUCIAL	Structure		AAD160 to 162-001
8.4	TERMINAL DATA			
8.4.1	TERMINAL_COUNT	Variable	Integer	AAD145-001
8.4.2	TERMINAL_TYPE_COUNT	Variable	Integer	AAD116-001
8.4.3	CONNECTION_COUNT	Variable	Integer	
8.4.4	TERMINAL_TYPE	Structure		AAD024 to 030, AAD121-001

Clause/ Sub- clause	Parameter Name	Parameter Type	Data Type	DET Code
8.4.5	TERMINAL	Structure		AAD014 to 016, AAD019, AAD020-001
8.4.6	TERMINAL_GROUP	Structure		
8.4.7	PERMUTABLE	Structure		
8.5	MATERIAL DATA			
8.5.1	TERMINAL_MATERIAL (was DIE_TERMINAL_MATERIAL)	Variable	Text	AAD120-001, AAE634-005
8.5.2	TERMINAL_MATERIAL_STRUCTURE	Variable	Text	
8.5.3	DIE_SEMICONDUCTOR_MATERIAL	Variable	Text	AAD148-001
8.5.4	DIE_SUBSTRATE_MATERIAL	Variable	Text	AAD005-001
8.5.5	DIE_SUBSTRATE_CONNECTION	Variable	Text	AAD006 & 007-001
8.5.6	DIE_PASSIVATION_MATERIAL	Variable	Text	AAD078-001
8.5.7	DIE_BACK_DETAIL	Variable	Text	AAD119-001
8.6	ELECTRICAL and THERMAL DATA	Variable		
8.6.1	MAX_TEMP	Variable	Real	AAD149-001
8.6.2	MAX_TEMP_TIME	Variable	Real	
8.6.3	POWER_RANGE	Variable	Real	AAD151-001
8.6.4	TEMPERATURE_RANGE	Variable	Real	AAE891-005
8.7	SIMULATOR DATA			
8.7.1	SIMULATOR_simulator_MODEL_FILE	Variable	File Name	
8.7.2	SIMULATOR_simulator_MODEL_FILE_DATE	Variable	Text	
8.7.3	SIMULATOR_simulator_NAME	Variable	Text	
8.7.4	SIMULATOR_simulator_VERSION	Variable	Text	
8.7.5	SIMULATOR_simulator_COMPLIANCE	Variable	Text	
8.7.6	SIMULATOR_simulator_TERM_GROUP	Variable		
8.8	HANDLING, PACKING, STORAGE and ASSEMBLY			
8.8.1	DELIVERY_FORM (was DIE_DELIVERY_FORM)	Variable	Text	AAD155-001
8.8.2	PACKING_CODE	Variable	Text	AAD055-001
8.8.8	ASSEMBLY parameters	Variable	Text	
8.9	WAFER SPECIFIC DATA			
8.9.1	WAFER_SIZE	Variable	Text	AAD011-001
8.9.2	WAFER_THICKNESS	Variable	Real	
8.9.3	WAFER_THICKNESS_TOLERANCE	Variable	Real	
8.9.4	WAFER_DIE_STEP_SIZE	Variable	Real	AAD163-001, AAD164-001
8.9.5	WAFER_GROSS_DIE_COUNT	Variable	Integer	AAD165-001
8.9.6	WAFER_INDEX	Variable	Real	AAD166-001, AAD167-001
8.9.7	WAFER_RETICULE_STEP_SIZE	Variable	Real	AAD168-001, AAD169-001
8.9.8	WAFER_RETICULE_GROSS_DIE_COUNT	Variable	Integer	AAD170-001

Clause/ Sub- clause	Parameter Name	Parameter Type	Data Type	DET Code
8.9.9	WAFER_INK_PARAMETERS	Variable	Text	
8.10	BUMP TERMINATION SPECIFIC DATA			
8.10.1	BUMP_MATERIAL	Variable	Text	AAD124-001
8.10.2	BUMP_HEIGHT	Variable	Real	AAD146-001
8.10.3	BUMP_HEIGHT_TOLERANCE	Variable	Real	AAD147-001
8.10.4	BUMP_SHAPE	Variable	Text	
8.10.5	BUMP_SIZE	Variable	Real	
8.10.6	BUMP_SPECIFICATION_DRAWING	Variable	File Name	
8.10.7	BUMP_ATTACHMENT_METHOD	Variable	Text	
8.11	MINIMALLY PACKAGE DEVICE SPECIFIC DATA			
8.11.1	MPD_PACKAGE_MATERIAL	Variable	Text	AAD150-001
8.11.2	MPD_PACKAGE_STYLE	Variable	Text	
8.11.3	MPD_CONNECTION_TYPE	Variable	Text	
8.11.4	MPD_MSL_LEVEL	Variable	Text	
8.11.5	MPD_PACKAGE_DRAWING	Variable	File Name	
Deleted	MPD_DELIVERY_FORM (refer to 8.8.1)	Variable		
Deleted	MPD_CONNECTION_MATERIAL (refer to 8.5.1)	Variable		
8.12	QUALITY, RELIABILITY and TEST DATA			
8.12.1	QUALITY Parameters	Variable	Text	
8.12.1	TEST Parameters	Variable	Text	
8.13	OTHER DATA			
8.13.1	TEXT	Variable	Text	

IECNORM.COM : Click to view the full PDF of IEC 62258-2:2011

Annex G (informative)

Notes on VERSION and NAME parameters

There are three “VERSION” related parameters, each of which contains specific revision data concerned with the different aspects of the data presented within a DDX BLOCK.

VERSION

Subclause 8.1.5

This relates to the IEC 62258, Part 2, and its issue. Being a data transfer standard for use with CAD/CAE systems, it is anticipated that there will be updates and revisions, particularly the inclusion of additional data, on a regular basis. Refer to Clause 1 to determine the DDX version covered in this standard.

BLOCK_VERSION

Subclause 8.1.3

This parameter relates solely to the revision status of the data within the BLOCK, and would expect to be “up-revved” as data within the BLOCK is modified. The **BLOCK_VERSION** parameter is specifically NOT concerned with the source of any data changes.

DATA_VERSION

Subclause 8.2.6

This parameter covers the source of the data used; to indicate the technical “state-of-the-art” for the data contents. This parameter is therefore closely coupled with the **DATA_SOURCE** parameter.

BLOCK_CREATION_DATE

Subclause 8.1.4

This parameter relates solely to the last date that data within the block was revised, and always accompanies, and should be linked to, the **BLOCK_VERSION** parameter. Likewise, there are four “NAME” related parameters, each of which represents a different aspect of the name by which the device is known.

DEVICE_NAME

Subclause 8.1.1

This is often referred to as the type number and is the identity normally used in data sheets and in parts lists.

DIE_NAME

Subclause 8.2.1

This is the name given to the die itself and the set of masks used in its fabrication. This name is often part of the fiducials on the die surface.

DIE_MASK_REVISION

Subclause 8.2.3

The revision or version code of the mask set used in fabricating the die.

DIE_PACKAGED_PART_NAME

Subclause 8.2.2

This is generally similar to the **DEVICE_NAME** and is quoted as the name of a packaged part which usually contains the same die and has similar electrical characteristics.

Annex H (informative)

Notes on WAFER parameters

When die are delivered as unsawn wafers, additional parameters can assist in the practicality of mechanical handling and quantity purchasing. Such parameters include the die step size, wafer size, wafer flat angle and gross die per wafer. Where the die step size is irregular, often caused by the reticule step, further parameters relating to the reticule size can become important.

Parameters relating to wafer delivery include:

WAFER_SIZE Subclause 8.9.1

This parameter gives the approximate wafer diameter. This is commonly quoted in millimetres or inches, and so need not be related to the **GEOMETRIC_UNITS** parameter.

WAFER_DIE_STEP_SIZE Subclause 8.9.4

The X and Y co-ordinates specified by this parameter are commonly used for die sawing and wafer probing, etc. The units again are determined by the **GEOMETRIC_UNITS** parameter.

WAFER_GROSS_DIE_COUNT Subclause 8.9.5

The gross die count can be an important parameter in the calculation of nett die per wafer, but does not reflect the good die per wafer, only the total of viable relevant die (whole die). Whilst theoretically there is a direct mathematical relationship between wafer and die size, test “drop-ins” etc., will affect the final count. The user should also be aware of cost-saving techniques which involve the reduction in the number of masks required that often result in fewer viable die.

WAFER_INDEX Subclause 8.9.6

This parameter pair defines the both type of physical feature present on a wafer and its orientation, which may then be used in an auto-location system in order to determine the placement and orientation of the wafer.


The first parameter specifies the type of feature, either a “flat” or “notch”, whilst the second parameter determines the approximate angle, to the nearest degree, of this index feature on the wafer with respect to the X-axis on the surface of the die. This can assist in wafer location recognition system for initial or crude orientation prior to final alignment by optical means. Where more than one flat exists on the wafer, the orientation is with respect to the major, or prime, flat, which may also be used to indicate the wafer lattice crystal [110] direction.

WAFER_RETICULE_STEP_SIZE Subclause 8.9.7

Where the reticule dimensions interfere with the regular stepping of the die size, the reticule step size should be given, in the same dimensions as the die step size (**GEOMETRIC_UNITS**).

WAFER_RETICULE_GROSS_DIE_COUNT Subclause 8.9.8

Where the **WAFER_RETICULE_STEP_SIZE** parameter is relevant, it may also be relevant to state the number of die, of the specified die type, within the reticule window. In the case of MPW runs, this may only be one die.



IEC 899/11

Figure H.1 – Illustrating the WAFER parameters

Figure H.1 shows a representation of where the reticule step size interferes with the die step dimensions, (the reticule here containing a total of 8 die in a 4 by 2 matrix). The gap between reticule and reticule results in an additional distance between adjacent die at the boundaries of the reticule. Figure H.1 also shows then wafer flat angle with respect to the assumed X-dimension of the die. Notional parameter values for Figure H.1 might be:

```

WAFER_SIZE = "150mm";
WAFER_DIE_STEP_SIZE = 1000,1000;
WAFER_GROSS_DIE_COUNT = 2077;
WAFER_INDEX = "Flat",45;
WAFER_RETICULE_STEP_SIZE = 4050, 2100;
WAFER_RETICULE_GROSS_DIE_COUNT = 8;

```

The reticule parameters given in this example here demonstrates a 50 unit discrepancy (**GEOMETRIC_UNITS**) in the X-dimension, and a 100 unit discrepancy (**GEOMETRIC_UNITS**) in the Y-dimension.

Annex I (informative)

Additional notes

- 1) As it stands, the DDX format requires data to reside within a block structure, strictly delimited by braces. The only data required outside of these braces are the **DEVICE** keyword and the associated parameters of **DEVICE_NAME** and **DEVICE_FORM**. This then leaves scope for future expansion, such as the inclusion of non-DDX format data outside of the DDX block structure, provided that the DDX structure and format rules are conformed to. Such additional data may include file and block checksums to validate the data file contents, although full ASCII character checksum calculations need to take into account the differing line delimiters used by different software operating systems. This additional data should be catered for, and ignored, by any parsing routine specifically for reading DDX formatted data.
- 2) As there are many different character conventions for displaying or annotating a negated signal, such as “\”, “/”, “N”, “B” or “not/bar”, no particular method has been adopted in the DDX format for the display of such signal names. It is therefore reliant upon the information provider to adopt a single convention, and the CAE vendor to accommodate this convention in the graphical display, where required.
- 3) Referencing an external file. File name references are required by:

8.3.8.2	FIDUCIAL_TYPE
8.2.9	DEVICE_PICTURE_FILE
8.2.10	DEVICE_DATA_FILE
8.11.5	MPD_PACKAGE_DRAWING
8.10.6	BUMP_SPECIFICATION_DRAWING

When referencing an external file, such as a graphic, textual or document file, it is preferable that the external file type conforms to a standard format in common use. Convention holds that the document format and/or type is indicated by the named file extent.

- 4) Multiple file names. Multiple file names are permitted in:

8.2.9	DEVICE_PICTURE_FILE
8.2.10	DEVICE_DATA_FILE
8.11.5	MPD_PACKAGE_DRAWING
8.10.6	BUMP_SPECIFICATION_DRAWING

Where multiple file names are permitted, the file names can be introduced in a single function invocation, as:

```
DEVICE_DATA_FILE = "file1.txt", "file2.txt", ... , "fileX.txt";
```

or as multiple invocations of that function, as:

```
DEVICE_DATA_FILE = "file1.txt";
DEVICE_DATA_FILE = "file2.txt";
.
DEVICE_DATA_FILE = "fileN.txt";
```

When using a single function invocation to introduce more than one file name, each file name should be surrounded by double quotes (as 6.3.7) and each file name shall be separated by a comma (as 6.3.2). Each line shall be terminated by a semicolon as 6.3.1.

Annex J (informative)

DDX Version history

The following table, Table J.1, indicates the parameter version history. The issue column reflects the current DDX revision and version number at which that parameter was either introduced or last altered.

The current version for this DDX format is 1.3.0, as stated in Clause 1 of this standard.

The previous version of this DDX format was 1.0, as defined in ES59008, Part 6-1.

Table J.1 – Parameter Change History List

Clause/ Subclause	Parameter Name	ES59008-6-1 Reference	Previous Clause	Current Issue
8.1	BLOCK DATA			
8.1.1	DEVICE_NAME	8.2	8.5	1.0
8.1.2	DEVICE_FORM	8.1	8.4	1.0
8.1.3	BLOCK_VERSION	8.17	8.2	1.0
8.1.4	BLOCK_CREATION_DATE	8.16	8.1	1.0
8.1.5	VERSION	8.3	8.3	1.0
8.2	DEVICE_DATA			
8.2.1	DIE_NAME		8.8	1.2.1
8.2.2	DIE_PACKAGED_PART_NAME	8.36	8.9	1.0
8.2.3	DIE_MASK_REVISION	8.30	8.6	1.0
8.2.4	MANUFACTURER	8.4	8.7	1.0
8.2.5	DATA_SOURCE	8.19	8.11	1.0
8.2.6	DATA_VERSION	8.55	8.12	1.0
8.2.7	FUNCTION	8.5	8.10	1.0
8.2.8	IC_TECHNOLOGY	8.20	8.25	1.0
8.2.8	DEVICE_PICTURE_FILE			1.3.0
8.2.9	DEVICE_DATA_FILE			1.3.0
8.3	GEOMETRIC DATA			
8.3.1	GEOMETRIC_UNITS	8.6	8.13	1.0
8.3.2	GEOMETRIC_VIEW	8.7	8.14	1.0
8.3.3	GEOMETRIC_ORIGIN	8.10	8.17	1.0
8.3.4	SIZE	8.8	8.15	1.0
8.3.5	SIZE_TOLERANCE	8.21	8.18	1.0
8.3.6	THICKNESS	8.9	8.16	1.0
8.3.7	THICKNESS_TOLERANCE	8.22	8.19	1.0
8.3.8	FIDUCIAL_TYPE	8.47	8.51	1.0
8.3.9	FIDUCIAL	8.48	8.52	1.0
8.4	TERMINAL DATA			

Clause/ Subclause	Parameter Name	ES59008-6-1 Reference	Previous Clause	Current Issue
8.4.1	TERMINAL_COUNT	8.11	8.20	1.0
8.4.2	TERMINAL_TYPE_COUNT	8.12	8.21	1.0
8.4.3	CONNECTION_COUNT	8.13	8.22	1.0
8.4.4	TERMINAL_TYPE	8.14	8.23	1.0
8.4.5	TERMINAL	8.15	8.24	1.0
8.4.6	TERMINAL_GROUP		8.58	1.3.0
8.4.7	PERMUTABLE		8.61	1.3.0
8.5	MATERIAL DATA			
8.5.1	TERMINAL_MATERIAL (was DIE_TERMINAL_MATERIAL)		8.30	1.3.0
8.5.2	TERMINAL_MATERIAL_STRUCTURE			1.3.0
8.5.3	DIE_SEMICONDUCTOR_MATERIAL	8.34	8.26	1.0
8.5.4	DIE_SUBSTRATE_MATERIAL	8.32	8.27	1.0
8.5.5	DIE_SUBSTRATE_CONNECTION	8.31	8.28	1.0
8.5.6	DIE_PASSIVATION_MATERIAL	8.37	8.29	1.0
8.5.7	DIE_BACK_DETAIL	8.33	8.31	1.0
8.6	ELECTRICAL and THERMAL DATA			
8.6.1	MAX_TEMP	8.18	8.33	1.0
8.6.2	MAX_TEMP_TIME			1.3.0
8.6.3	POWER_RANGE	8.23	8.34	1.0
8.6.4	TEMPERATURE_RANGE	8.24	8.35	1.0
8.7	SIMULATOR DATA			
8.7.1	SIMULATOR_simulator_MODEL_FILE	8.25	8.36	1.0
8.7.2	SIMULATOR_simulator_MODEL_FILE_DATE	8.26	8.37	1.0
8.7.3	SIMULATOR_simulator_NAME	8.27	8.38	1.0
8.7.4	SIMULATOR_simulator_VERSION	8.28	8.39	1.0
8.7.5	SIMULATOR_simulator_COMPLIANCE	8.29	8.40	1.0
8.7.6	SIMULATOR_simulator_TERM_GROUP		8.59	1.3.0
8.8	HANDLING, PACKING, STORAGE and ASSEMBLY			
8.8.1	DELIVERY_FORM (was DIE_DELIVERY_FORM)	8.35	8.41	1.0
8.8.2	PACKING_CODE	8.46	8.42	1.0
8.8.8	ASSEMBLY parameters			1.3.0
8.9	WAFER SPECIFIC DATA			
8.9.1	WAFER_SIZE	8.45	8.32	1.0
8.9.2	WAFER_THICKNESS			1.3.0
8.9.3	WAFER_THICKNESS_TOLERANCE			1.3.0
8.9.4	WAFER_DIE_STEP_SIZE		8.53	1.2.1
8.9.5	WAFER_GROSS_DIE_COUNT		8.54	1.2.1
8.9.6	WAFER_INDEX		8.55	1.2.1
8.9.7	WAFER_RETICULE_STEP_SIZE		8.56	1.2.1
8.9.8	WAFER_RETICULE_GROSS_DIE_COUNT		8.57	1.2.1

Clause/ Subclause	Parameter Name	ES59008-6-1 Reference	Previous Clause	Current Issue
8.9.9	WAFER_INK			1.3.0
8.10	BUMP TERMINATION SPECIFIC DATA			
8.10.1	BUMP_MATERIAL	8.38	8.43	1.0
8.10.2	BUMP_HEIGHT	8.39	8.44	1.0
8.10.3	BUMP_HEIGHT_TOLERANCE	8.40	8.45	1.0
8.10.4	BUMP_SHAPE			1.3.0
8.10.5	BUMP_SIZE			1.3.0
8.10.6	BUMP_SPECIFICATION_DRAWING			1.3.0
8.10.7	BUMP_ATTACHMENT_METHOD			1.3.0
8.11	MINIMALLY PACKAGE DEVICE SPECIFIC DATA			
8.11.1	MPD_PACKAGE_MATERIAL	8.41	8.46	1.0
8.11.2	MPD_PACKAGE_STYLE		8.47	1.2.1
8.11.3	MPD_CONNECTION_TYPE	8.43	8.49	1.0
8.11.4	MPD_MSL_LEVEL			1.30
8.11.5	MPD_PACKAGE_DRAWING			1.30
Deleted	MPD_DELIVERY_FORM (refer to 8.8.1)	8.42	8.48	1.0
Deleted	MPD_CONNECTION_MATERIAL (refer to 8.5.1)	8.44	8.50	1.0
8.12	QUALITY, RELIABILITY and TEST DATA			
8.12.1	QUALITY Parameters			1.3.0
8.12.1	TEST Parameters			1.3.0
8.13	OTHER DATA			
8.13.1	TEXT		8.60	1.3.0
8.14	CONTROL DATA			
8.14.1	PARSE			1.3.0

Annex K (informative)

Parse Control

The **PARSE_** series of parameters are intended to add in-line control of the parsing software, primarily to allow for additions and extensions to the DDX software that have not, to date, been ratified and included in the current standard. Note that none of the **PARSE_** parameters have any relevance or meaning to the device data.

To this end a number of **PARSE_** parameters have been added:

8.14.1	PARSE_MODE
8.14.2	PARSE_ERROR_REPORT
8.14.3	PARSE_ERROR_TRAP
8.14.4	PARSE_IGNORE
8.14.5	PARSE_DEFINE_PARAMETER
8.14.6	PARSE_DEFINE_STRUCTURE

The **PARSE_MODE**, **PARSE_ERROR_REPORT**, **PARSE_ERROR_TRAP** and **PARSE_IGNORE** parameters may have multiple occurrences, and are intended to “switch” the desired parse mode as the DDX file or DDX block is linearly read.

The **PARSE_DEFINE_PARAMETER** and **PARSE_DEFINE_STRUCTURE** parameters serve to introduce new parameters and/or structures to the parsing software for inclusion in syntax checks, data validation and value assignment, solely for that specific DDX block. Once defined, it is expected that the new parameters and structures will fully conform to the syntax etc., as defined in Clauses 5 to 7. Until the new parameters and structures have been ratified and included in an update to this DDX standard, all data shall be treated as textual and will have no associated S.I unit.

The **PARSE_MODE** parameter is intended to control the way in which the syntax and data rules are interpreted and applied. In all cases, data that complies with this version of the DDX format (refer Clause 1) shall be free from errors or warnings. New data parameters or structures that have been introduced using the **PARSE_DEFINE_xxx** parameters may require some rule relaxation before an error-free parse result is achieved.

PARSE_MODE = **STRICT**;

Under “normal” circumstances, the **_MODE** parameter will default to “STRICT”, and all currently compliant data must be error free, and errors will be issued if the **PARSE_DEFINE** options are used. These errors are to or structures than those given in the current standard,

PARSE_MODE = **RELAXED**;

The “RELAXED” value is given to permit inclusion of additional defined data that may not strictly comply with the rules as written. Instead of errors, warnings are to be issued when new parameters are included to serve notice to the user that the DDX block under scrutiny contains parameters not currently in the standard.

PARSE_MODE = **USER**;

PARSE_MODE = **ENHANCED**;

The “ENHANCED” and “USER” values are alternative options available to the discretion of the parse software provider and user.

The **PARSE_ERROR_REPORT** parameter determines the level of warnings and errors reported DURING parsing, it should have no effect on the end report. This is primarily to prevent warnings regarding parameters being used prior to their assignment, caused by the introduction of new parameters. These parameter options are self-explanatory.

```

PARSE_ERROR_REPORT = OFF;
PARSE_ERROR_REPORT = TERSE;
PARSE_ERROR_REPORT = VERBOSE;

```

The **PARSE_ERROR_TRAP** parameter determines how the parsing software should react once an error (as opposed to a warning) is discovered.

```

PARSE_ERROR_TRAP = ALL;

```

This is the expected “default” mode. The DDX block is parsed and all errors are reported.

```

PARSE_ERROR_TRAP = FIRST;

```

The “FIRST” value should cause the parsing software to halt upon the detection of the first error.

The **PARSE_IGNORE** parameter is meant to control whether checking is actually performed of part of the DDX block or not, and should accordingly be used with care.

```

PARSE_IGNORE = NONE;
PARSE_IGNORE = OFF;

```

All parsing checks are performed. This should be the default state for the parsing software.

```

PARSE_IGNORE = ALL;

```

All parsing checks are ignored, this is useful only to bypass rubbish data

```

PARSE_IGNORE = SYNTAX_ONLY;

```

Only syntactical errors and line-termination checks are performed. There are no checks on forward/backward referencing of variables, nor of parameter counts etc. This option should only be used when new parameters or structures are introduced that include variable referencing or non-textual data.

WARNINGS and ERRORS

It is advised that the following items be classed as **WARNINGS**, and all other errors classified as **ERRORS**:

- WARNING 1. The occurrence of ASCII characters in the range 0x80 to 0xFF
- WARNING 2. Where a data line is assumed to be terminated due to its length exceeding the parser’s line input buffer. Refer to 6.3.9.
- WARNING 3. Where textual data, not enclosed within double quotes, includes line break characters, refer to 6.3.8.
- WARNING 4. Where the textual file name does not conform to the character set as defined in 7.1.3.2.
- WARNING 5. Where the **PARSE_DEFINE_xxx** introduces a parameter or structure that has been ratified and defined within the later versions of the DDX standard.

SOMMAIRE

AVANT-PROPOS	74
INTRODUCTION	76
1 Domaine d'application et objet	77
2 Références normatives	77
3 Termes et définitions	78
4 Exigences	78
5 Buts et usage du fichier de format d'échange de données de dispositif (DDX)	78
6 Format de fichier DDX et règles relatives au format de fichier	79
6.1 Validité des données	79
6.2 Jeu de caractères	79
6.3 RÈGLES SYNTAXIQUES	79
7 Contenu d'un fichier DDX	80
7.1 Règles relatives au contenu d'un fichier DDX	80
7.1.1 Structure en blocs	80
7.1.2 Types des paramètres	80
7.1.3 Types de donnée	80
7.1.4 Déclarations aval	81
7.1.5 Unités	82
7.1.6 Données de coordonnées	82
7.1.7 Mots réservés	82
7.2 Syntaxe du bloc DEVICE DDX	82
7.3 Syntaxe des données DDX	83
8 Définitions des paramètres d'un bloc DEVICE	84
8.1 BLOCK DATA (DONNÉES DE BLOC)	85
8.1.1 Paramètre DEVICE_NAME	85
8.1.2 Paramètre DEVICE_FORM	85
8.1.3 Paramètre BLOCK_VERSION	85
8.1.4 Paramètre BLOCK_CREATION_DATE	86
8.1.5 Paramètre VERSION	86
8.2 DONNÉES DE DISPOSITIF	86
8.2.1 Paramètre DIE_NAME	86
8.2.2 Paramètre DIE_PACKAGED_PART_NAME	86
8.2.3 Paramètre DIE_MASK_REVISION	86
8.2.4 Paramètre MANUFACTURER	87
8.2.5 Paramètre DATA_SOURCE	87
8.2.6 Paramètre DATA_VERSION	87
8.2.7 Paramètre FUNCTION	87
8.2.8 Paramètre IC_TECHNOLOGY	87
8.2.9 Paramètre DEVICE_PICTURE_FILE	88
8.2.10 Paramètre DEVICE_DATA_FILE	88
8.3 DONNÉES GÉOMÉTRIQUES	88
8.3.1 Paramètres GEOMETRIC_UNITS	88
8.3.2 Paramètre GEOMETRIC_VIEW	89
8.3.3 Paramètre GEOMETRIC_ORIGIN	89
8.3.4 Paramètre SIZE	90
8.3.5 Paramètre SIZE_TOLERANCE	90

8.3.6	Paramètre THICKNESS	91
8.3.7	Paramètre THICKNESS_TOLERANCE	91
8.3.8	Paramètre FIDUCIAL_TYPE	91
8.3.9	Paramètre FIDUCIAL	93
8.4	DONNÉES RELATIVES AUX BORNES	94
8.4.1	Paramètre TERMINAL_COUNT	94
8.4.2	Paramètre TERMINAL_TYPE_COUNT	95
8.4.3	Paramètre CONNECTION_COUNT	95
8.4.4	Paramètre TERMINAL_TYPE	95
8.4.5	Paramètre TERMINAL	97
8.4.6	Paramètre TERMINAL_GROUP	100
8.4.7	Paramètre PERMUTABLE	102
8.5	DONNÉES RELATIVES AUX MATÉRIAUX	103
8.5.1	Paramètre TERMINAL_MATERIAL	103
8.5.2	Paramètre TERMINAL_MATERIAL_STRUCTURE	103
8.5.3	Paramètre DIE_SEMICONDUCTOR_MATERIAL	103
8.5.4	Paramètre DIE_SUBSTRATE_MATERIAL	103
8.5.5	Paramètre DIE_SUBSTRATE_CONNECTION	104
8.5.6	Paramètre DIE_PASSIVATION_MATERIAL	104
8.5.7	Paramètre DIE_BACK_DETAIL	104
8.6	DONNÉES RELATIVES AUX CARACTÉRISTIQUES ASSIGNÉES ÉLECTRIQUES ET THERMIQUES	105
8.6.1	Paramètre MAX_TEMP	105
8.6.2	Paramètre MAX_TEMP_TIME	105
8.6.3	Paramètre POWER_RANGE	105
8.6.4	Paramètre TEMPERATURE_RANGE	105
8.7	DONNÉES DE SIMULATION	106
8.7.1	Paramètre MODEL FILE de simulateur	106
8.7.2	Paramètre MODEL FILE DATE de simulateur	106
8.7.3	Paramètre NAME de simulateur	106
8.7.4	Paramètre VERSION de simulateur	106
8.7.5	Paramètre COMPLIANCE de simulateur	107
8.7.6	Paramètre TERM_GROUP de simulateur	107
8.8	DONNÉES RELATIVES À LA MANUTENTION, AU CONDITIONNEMENT, AU STOCKAGE ET À L'ASSEMBLAGE	107
8.8.1	Paramètre DELIVERY_FORM	107
8.8.2	Paramètre PACKING_CODE	107
8.8.3	Paramètres ASSEMBLY	108
8.9	DONNÉES SPÉCIFIQUES AUX TRANCHES	108
8.9.1	Paramètre WAFER_SIZE	108
8.9.2	Paramètre WAFER_THICKNESS	108
8.9.3	Paramètre WAFER_THICKNESS_TOLERANCE	108
8.9.4	Paramètre WAFER_DIE_STEP_SIZE	109
8.9.5	Paramètre WAFER_GROSS_DIE_COUNT	109
8.9.6	Paramètre WAFER_INDEX	109
8.9.7	Paramètre WAFER_RETICULE_STEP_SIZE	110
8.9.8	Paramètre WAFER_RETICULE_GROSS_DIE_COUNT	110
8.9.9	Paramètres WAFER_INK	110
8.10	DONNÉES SPÉCIFIQUES AUX TERMINAISONS À BOSSES	111

8.10.1	Paramètre BUMP_MATERIAL	111
8.10.2	Paramètre BUMP_HEIGHT	111
8.10.3	Paramètre BUMP_HEIGHT_TOLERANCE	111
8.10.4	Paramètre BUMP_SHAPE	112
8.10.5	Paramètre BUMP_SIZE	112
8.10.6	Paramètre BUMP_SPECIFICATION_DRAWING	112
8.10.7	Paramètre BUMP_ATTACHMENT_METHOD	112
8.11	DONNÉES SPÉCIFIQUES AUX DISPOSITIFS À ENCAPSULATION RÉDUITE (MPD, MINIMALLY PACKAGED DEVICE)	113
8.11.1	Paramètre MPD_PACKAGE_MATERIAL	113
8.11.2	Paramètre MPD_PACKAGE_STYLE	113
8.11.3	Paramètre MPD_CONNECTION_TYPE	113
8.11.4	Paramètre MPD_MSL_LEVEL	113
8.11.5	Paramètre MPD_PACKAGE_DRAWING	113
8.12	DONNÉES DE QUALITÉ, FIABILITÉ ET ESSAIS	114
8.12.1	Paramètres QUALITY	114
8.12.2	Paramètres TEST	114
8.13	AUTRES DONNÉES	115
8.13.1	Paramètres TEXT	115
8.14	DONNÉES DE CONTRÔLE	115
8.14.1	Paramètres PARSE	115
Annexe A (informative)	Exemple d'un bloc DEVICE DDX	119
Annexe B (informative)	Groupes et permutation	121
Annexe C (informative)	Vue CAO type à partir de l'exemple de bloc de fichier DDX donné dans l'Annexe A	124
Annexe D (informative)	Propriétés pour la Simulation	125
Annexe E (informative)	Utilisation graphique de TERMINAL et TERMINAL_TYPE pour les systèmes CAO/FAO	127
Annexe F (informative)	Correspondance avec la CEI 61360-4	130
Annexe G (informative)	Notes sur les paramètres VERSION et NAME	133
Annexe H (informative)	Notes sur les paramètres WAFER	134
Annexe I (informative)	Notes complémentaires	136
Annexe J (informative)	Historique des versions DDX	137
Annexe K (informative)	Contrôle d'analyse	140
Figure 1	– Relation entre le centre géométrique et l'origine géométrique	90
Figure C.1	– Représentation CAO de l'exemple de DDX issu de l'Annexe A	124
Figure E.1	– Mise en évidence des propriétés d'orientation MX et MY	128
Figure E.2	– Mise en évidence des propriétés d'orientation de rotation angulaire	129
Figure H.1	– Illustration des paramètres WAFER	135
Tableau 1	– Types de forme de borne	96
Tableau 2	– Coordonnées de la forme de borne	96
Tableau 3	– Types d'I/O (c'est-à-dire E/S) de borne	99
Tableau 4	– Paramètres de connexion au substrat	104
Tableau F.1	– Liste de paramètres	130

Tableau J.1 – Liste de l'historique des modifications des paramètres.....	137
---	-----

IECNORM.COM : Click to view the full PDF of IEC 62258-2:2011

COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

PRODUITS DE PUCES DE SEMICONDUCTEURS –

Partie 2: Formats d'échange de données

AVANT-PROPOS

- 1) La Commission Electrotechnique Internationale (CEI) est une organisation mondiale de normalisation composée de l'ensemble des comités électrotechniques nationaux (Comités nationaux de la CEI). La CEI a pour objet de favoriser la coopération internationale pour toutes les questions de normalisation dans les domaines de l'électricité et de l'électronique. A cet effet, la CEI – entre autres activités – publie des Normes internationales, des Spécifications techniques, des Rapports techniques, des Spécifications accessibles au public (PAS) et des Guides (ci-après dénommés "Publication(s) de la CEI"). Leur élaboration est confiée à des comités d'études, aux travaux desquels tout Comité national intéressé par le sujet traité peut participer. Les organisations internationales, gouvernementales et non gouvernementales, en liaison avec la CEI, participent également aux travaux. La CEI collabore étroitement avec l'Organisation Internationale de Normalisation (ISO), selon des conditions fixées par accord entre les deux organisations.
- 2) Les décisions ou accords officiels de la CEI concernant les questions techniques représentent, dans la mesure du possible, un accord international sur les sujets étudiés, étant donné que les Comités nationaux de la CEI intéressés sont représentés dans chaque comité d'études.
- 3) Les Publications de la CEI se présentent sous la forme de recommandations internationales et sont agréées comme telles par les Comités nationaux de la CEI. Tous les efforts raisonnables sont entrepris afin que la CEI s'assure de l'exactitude du contenu technique de ses publications; la CEI ne peut pas être tenue responsable de l'éventuelle mauvaise utilisation ou interprétation qui en est faite par un quelconque utilisateur final.
- 4) Dans le but d'encourager l'uniformité internationale, les Comités nationaux de la CEI s'engagent, dans toute la mesure possible, à appliquer de façon transparente les Publications de la CEI dans leurs publications nationales et régionales. Toutes divergences entre toutes Publications de la CEI et toutes publications nationales ou régionales correspondantes doivent être indiquées en termes clairs dans ces dernières.
- 5) La CEI elle-même ne fournit aucune attestation de conformité. Des organismes de certification indépendants fournissent des services d'évaluation de conformité et, dans certains secteurs, accèdent aux marques de conformité de la CEI. La CEI n'est responsable d'aucun des services effectués par les organismes de certification indépendants.
- 6) Tous les utilisateurs doivent s'assurer qu'ils sont en possession de la dernière édition de cette publication.
- 7) Aucune responsabilité ne doit être imputée à la CEI, à ses administrateurs, employés, auxiliaires ou mandataires, y compris ses experts particuliers et les membres de ses comités d'études et des Comités nationaux de la CEI, pour tout préjudice causé en cas de dommages corporels et matériels, ou de tout autre dommage de quelque nature que ce soit, directe ou indirecte, ou pour supporter les coûts (y compris les frais de justice) et les dépenses découlant de la publication ou de l'utilisation de cette Publication de la CEI ou de toute autre Publication de la CEI, ou au crédit qui lui est accordé.
- 8) L'attention est attirée sur les références normatives citées dans cette publication. L'utilisation de publications référencées est obligatoire pour une application correcte de la présente publication.
- 9) L'attention est attirée sur le fait que certains des éléments de la présente Publication de la CEI peuvent faire l'objet de droits de brevet. La CEI ne saurait être tenue pour responsable de ne pas avoir identifié de tels droits de brevets et de ne pas avoir signalé leur existence.

La Norme internationale CEI 62258-2 a été établie par le comité d'études 47 de la CEI: Dispositifs à semiconducteurs.

La présente norme doit être lue en conjonction avec la CEI 62258-1.

Cette deuxième édition annule et remplace la première édition parue en 2005, dont elle constitue une révision technique.

Par rapport à la première édition, les paramètres suivants ont été mis à jour pour la présente édition:

Paragraphe	Nom du paramètre
8.2.9	DEVICE_PICTURE_FILE
8.2.10	DEVICE_DATA_FILE
8.4.6	TERMINAL_GROUP
8.4.7	PERMUTABLE
8.5.1	TERMINAL_MATERIAL (anciennement DIE_TERMINAL_MATERIAL)
8.5.2	TERMINAL_MATERIAL_STRUCTURE
8.6.2	MAX_TEMP_TIME
8.7.6	SIMULATOR_simulator_TERM_GROUP
8.8.3	ASSEMBLY
8.9.2	WAFER_THICKNESS
8.9.3	WAFER_THICKNESS_TOLERANCE
8.9.9	WAFER_INK
8.10.4	BUMP_SHAPE
8.10.5	BUMP_SIZE
8.10.6	BUMP_SPECIFICATION_DRAWING
8.10.7	BUMP_ATTACHMENT_METHOD
8.11.4	MPD_MSL_LEVEL
8.11.5	MPD_PACKAGE_DRAWING
8.12.1	QUALITY
8.12.2	TEST
8.13.1	TEXT
8.14.1	PARSE

Le texte de cette norme est issu des documents suivants:

FDIS	Rapport de vote
47/2085/FDIS	47/2095/RVD

Le rapport de vote indiqué dans le tableau ci-dessus donne toute information sur le vote ayant abouti à l'approbation de cette norme.

Cette publication a été rédigée selon les Directives ISO/CEI, Partie 2.

Le comité a décidé que le contenu de cette publication ne sera pas modifié avant la date de stabilité indiquée sur le site web de la CEI sous "<http://webstore.iec.ch>" dans les données relatives à la publication recherchée. A cette date, la publication sera

- reconduite,
- supprimée,
- remplacée par une édition révisée, ou
- amendée.

INTRODUCTION

La présente Norme internationale est fondée sur les travaux réalisés dans le cadre du projet ESPRIT 4, GOODDIE, qui a donné lieu à la publication de la série de Spécifications européennes ES 59008. Les organisations qui ont aidé à la préparation du présent document incluent les membres des projets ESPRIT ENCAST et ENCASIT, le Die Products Consortium, JEITA, JEDEC et ZVEI.

La structure de la présente Norme internationale telle qu'actuellement conçue est la suivante :

Sous le titre général : CEI 62258: Produits de puces de semiconducteurs

- Partie 1: Approvisionnement et utilisation
- Partie 2: Formats d'échange de données
- Partie 3: Bonnes pratiques recommandées pour la manipulation, le conditionnement et le stockage (Rapport technique)
- Partie 4: Questionnaire destiné aux utilisateurs et fournisseurs de puces (Rapport technique)
- Partie 5: Exigences pour l'information concernant la simulation électrique
- Partie 6: Exigences pour l'information concernant la simulation thermique
- Partie 7: Schéma du langage XML pour l'échange de données (Rapport technique)
- Partie 8: Schéma du modèle EXPRESS pour l'échange de données (Rapport technique)

D'autres parties peuvent être ajoutées si nécessaire.

PRODUITS DE PUCES DE SEMICONDUCTEURS –

Partie 2: Formats d'échange de données

1 Domaine d'application et objet

La présente partie de la CEI 62258 spécifie les formats de données qui peuvent être utilisés pour l'échange de données qui est couvert par d'autres parties de la présente série CEI 62258 ainsi que les définitions de tous les paramètres utilisés selon les principes et méthodes de la CEI 61360. Elle présente un format d'échange de données de dispositif, DDX (Device Data Exchange), dans le but premier de faciliter le transfert des données géométriques adéquates entre le fabricant de la puce et l'utilisateur de CAO/IAO et des modèles d'informations formels qui permettent l'échange de données dans d'autres formats tels que le format de fichier physique STEP, conformément à ISO 10303-21 et XML. Le format de données a été tenu intentionnellement flexible pour permettre un usage au-delà de ce domaine initial d'application.

Elle a été développée pour faciliter la production, la fourniture et l'utilisation des produits de puces de semiconducteurs, y compris, sans que cela soit limitatif.

- les tranches,
- les puces nues isolées,
- les puces et tranches avec structures de connexion fixées,
- les puces et tranches à encapsulation minimale ou partielle.

La présente norme reflète le format de données DDX en sa version **1.3.0**

2 Références normatives

Les documents de référence suivants sont indispensables pour l'application du présent document. Pour les références datées, seule l'édition citée s'applique. Pour les références non datées, la dernière édition du document de référence s'applique (y compris les éventuels amendements).

CEI 62258-1, *Produits de puces de semiconducteurs – Partie 1: Approvisionnement et utilisation*

CEI 61360-4:2005, *Standard data element types with associated classification scheme for electric components – Part 4: IEC reference collection of standard data element types, component classes* (disponible en anglais seulement)

ISO 8601:2004, *Éléments de données et formats d'échange – Échange d'information – Représentation de la date et de l'heure*

ISO 6093:1985, *Traitement de l'information – Représentation des valeurs numériques dans les chaînes de caractères pour l'échange d'information*

IPC/JEDEC J-STD-033B:2007, *Handling, Packing, Shipping and Use of Moisture/Reflow Sensitive Surface Mount Devices*

ISO 10303-21:2002, *Systèmes d'automatisation industrielle et intégration – Représentation et échange de données de produits – Partie 21: Méthodes de mise en application: Encodage en texte clair des fichiers d'échange*

3 Termes et définitions

Pour les besoins du présent document, les termes et définitions donnés dans la CEI 62258-1 s'appliquent.

4 Exigences

Une référence spécifique pour les variables paramétriques est faite aux codes de types d'éléments de données (DET) de la CEI 61360, lesquels codes sont définis dans la Partie 4 de la CEI 61360.

5 Buts et usage du fichier de format d'échange de données de dispositif (DDX)

5.1 Pour faciliter le transfert de données par des supports électroniques du fournisseur de dispositif jusqu'à l'utilisateur final en vue de leur utilisation dans un système de CAO ou d'IAO, un format de fichier de données, à savoir le **Device Data eXchange**, (**DDX**, format d'échange de données), doit être utilisé. Ce format de fichier de données a été intentionnellement maintenu flexible, afin de permettre des améliorations et additions ultérieures pour une utilisation future

5.2 Il est fortement recommandé que les fichiers d'échange de données de dispositif (**Device Data eXchange**) aient les trois lettres **DDX** comme extension de fichier. De plus, un fichier d'échange de données de dispositif doit être appelé ici fichier **DDX**.

5.3 Les données devant être transférées d'un fournisseur de dispositif à un utilisateur doivent être contenues dans un seul fichier DDX lisible par un ordinateur. En outre, le contenu minimal de ce fichier doit suffire à un système de conception de logiciel CAO/IAO géométrique. Le fichier doit être lisible textuellement, afin de permettre une simple vérification manuelle.

5.4 Le fichier DDX et le contenu de données doivent être indépendants tant de la machine informatique que du système d'exploitation.

5.5 Le contenu du fichier DDX doit comprendre des informations mécaniques et d'interconnectivité, mais il peut en plus comprendre des données électriques et fonctionnelles.

5.6 Le fichier DDX peut contenir des données pour un ou plusieurs dispositifs et doit pouvoir être utilisé comme fichier bibliothèque par un système de conception de logiciel CAO/IAO. Le fichier peut contenir un ou plusieurs jeux de données pour le même type de dispositif, chacun de ces jeux ayant des formes de livraison différentes, telles que puces à bosses, puces nues, et emballage grandeur puce

5.7 Le fichier DDX doit pouvoir être créé de manière simple ou automatique, comme par exemple par un éditeur de texte ASCII ou une feuille de calcul.

5.8 Le fichier DDX doit pouvoir référencer des fichiers externes complémentaires, tels que fichiers de simulation et modèles thermiques.

5.9 Toutes les données doivent être définies de façon à permettre la conversion en d'autres formats d'échange et vice versa, tels que GDSII et CIF pour les données géométriques relatives aux puces. Une compatibilité aussi étroite que possible avec les données DIE

(échange d'informations de puces) existantes est souhaitable afin de faciliter une traduction simple de fichiers partiels de données DIE.

5.10 Les définitions des paramètres doivent être conformes à la CEI 61360 (voir Article 5 de la CEI 62258-1).

6 Format de fichier DDX et règles relatives au format de fichier

NOTE 1 La version 1.2.1 du DDX annule et remplace la version 1.0.0 contenue dans l'ES 59008-6-1.

NOTE 2 La version 1.3.0 du DDX annule et remplace la version 1.2.1 contenue dans la CEI 62258-2:2005.

Voir l'Article 1 pour la version DDX de la présente norme.

6.1 Validité des données

6.1.1 Toutes les données qui ne sont pas conformes à la syntaxe des données (voir 7.3) doivent être traitées comme une remarque et, donc, ignorées.

6.1.2 Toutes les données obligatoires doivent être présentes. Les données manquantes doivent être étiquetées comme étant une erreur, rendant ainsi ces données inutilisables.

6.1.3 Les opérations, calculs ou formules mathématiques ne doivent pas être permis au sein des données numériques.

6.2 Jeu de caractères

6.2.1 Le fichier DDX doit être un fichier texte compatible avec l'ASCII ayant la fin de ligne appropriée. La fin de ligne dépendra du système d'exploitation. DOS/Windows® utilise en général un caractère d'arrêt (ASCII 0Dh/0Ah) de retour chariot/changement de ligne <CR/LF> alors qu'UNIX® se repose invariablement et uniquement sur le caractère d'arrêt (ASCII 0x0A) de changement de ligne <LF>, le retour chariot <CR> (ASCII 0x0D) étant présent par implication.

6.2.2 Les caractères ASCII 0x00 à 0x7F sont permis; les caractères 0x80 à 0xFF de l'ASCII doivent être ignorés.

6.2.3 Toutes les données textuelles doivent être indépendantes de la casse.

6.2.4 Les caractères espace (ASCII 20h) et tabulation (ASCII 09h) doivent tous deux être traités comme des séparateurs espace; les multiples caractères espace et tabulation seront traités par la syntaxe comme un séparateur espace unique.

6.3 RÈGLES SYNTAXIQUES

6.3.1 Toutes les lignes de données doivent se terminer par un point-virgule: «;».

6.3.2 La virgule «,» doit être utilisée comme séparateur de données.

6.3.3 Les lignes commençant par un dièse «#» doivent être traitées comme un commentaire intentionnel. Toutes les données présentes sur ces lignes doivent être ignorées.

6.3.4 Les traits de soulignement «_» doivent être ignorés dans le nom d'une variable ou d'une propriété et ils peuvent servir de séparateurs intermédiaires de noms. Les traits de soulignement sont valides dans une chaîne textuelle et dans les données de nom.

6.3.5 Des accolades sont utilisées pour ouvrir ou fermer les structures ou les BLOCS. Une accolade d'ouverture «{» doit être utilisée pour débiter une structure ou un bloc et une accolade de fermeture «}» doit être utilisée pour terminer une structure ou un bloc.

6.3.6 Les parenthèses «(» doivent être permises, mais ignorées, dans les données numériques par souci de clarté (par exemple dans les paires de coordonnées).

6.3.7 Pour prendre en charge les sorties au format CSV (variable séparée par une virgule) caractéristique des feuilles de calcul, les données textuelles peuvent être mises entre des guillemets, «», et les paires conjuguées de guillemets doivent être ignorées.

6.3.8 Il n'y a pas de caractère spécifique pour la continuation de ligne. Une chaîne textuelle ouverte par des guillemets «'» doit être fermée par les guillemets conjugués «'», quel que soit le nombre de retours à la ligne dans le texte en question. Comme toutes les commandes DDX se terminent par un point-virgule, les données non textuelles sont réputées s'être terminées à ce point-virgule. Les données textuelles sont réputées se terminer au point-virgule suivant les guillemets de fermeture. Les données textuelles qui ne sont pas entourées de guillemets ne peuvent pas contenir de retour à la ligne ou de caractères de commande et elles doivent se terminer à la première occurrence d'un point-virgule. Les données textuelles placées après ce point-virgule seront traitées comme des données erronées et rejetées.

6.3.9 Pour la commodité pratique, la lisibilité et la facilité de l'analyse des lignes, il est recommandé que la longueur d'une ligne (entre caractères de fin de ligne) ne dépasse pas 255 caractères. En outre, il est fortement recommandé d'imposer une limite maximale de 1 023 caractères par ligne afin d'éviter que d'autres logiciels d'analyse ne rencontrent une erreur de dépassement de tampon d'entrée.

7 Contenu d'un fichier DDX

7.1 Règles relatives au contenu d'un fichier DDX

7.1.1 Structure en blocs

Les données ne doivent exister qu'au sein d'une structure de bloc, appelée «bloc DEVICE» et un ou plusieurs blocs DEVICE, contenant chacun des données, peuvent exister dans un même fichier. Chaque bloc DEVICE est unique et ne doit contenir que les données pertinentes pour un seul dispositif, ayant une forme de dispositif spécifique. Toutes les données dans chaque bloc DEVICE doivent être traitées comme étant locales et uniques au bloc en question seulement. (Voir 6.3.4)

7.1.2 Types des paramètres

Il y a deux types d'utilisation de paramètres pour les données, les structures et les variables, et ces paramètres doivent exister uniquement avec un bloc DEVICE:

- une structure détermine un ou plusieurs jeux de données ayant différents types de donnée.
- une variable équivaut à une ou plusieurs données d'un seul type de donnée

7.1.3 Types de donnée

Les types de donnée sont les suivants.

7.1.3.1 Données chaînes textuelles

Tous les caractères de l'ASCII entre ASCII 20h et ASCII 7Fh sont permis dans les données textuelles, les caractères de l'ASCII 80h inclus et au-dessus doivent être ignorés. Des caractères spéciaux de commande d'impression et d'affichage peuvent être pris en compte

pour permettre l'impression des caractères de soulignement ou de surlignement. Il est conseillé de placer les données chaînes textuelles entre des paires de guillemets (voir 6.3.7).

7.1.3.2 Données de nom textuel

Tous les noms doivent être uniques et doivent être constitués uniquement des caractères suivants issus du jeu de caractères ASCII:-

A à Z a à z 0 à 9 \$ - % & ! @ _ .

Lorsque les données de nom textuel sont utilisées pour former le nom d'un fichier, il est conseillé de limiter le nom à huit caractères pour le nom de fichier et à trois caractères pour l'extension de fichier, avec le point «.» comme délimiteur nom/extension, au diapason d'un grand nombre de systèmes d'exploitation courants. Il est conseillé de placer les données de nom textuel entre des paires de guillemets (voir 6.3.7).

Remarquer que toutes les données de nom textuel sont indépendantes de la casse et que les espaces sont interdits dans un nom textuel.

7.1.3.3 Données numériques Real (réelles)

Les données numériques réelles doivent être conformes à l'ISO 6093:1985 et doivent être constituées des caractères:

0 à 9 + - . E e

Les valeurs des données peuvent être signées et utiliser la notation technique ou scientifique, mais elles ne doivent pas comporter d'unité dimensionnelle, par exemple:

90008, 9000.80, 9.0008E5, -5207, -5.207E3, 0.102, 102E-3

Remarquer que la virgule « , » est utilisée comme séparateur de données et, donc, elle ne doit pas être utilisée comme remplacement du point décimal « . ».

7.1.3.4 Données numériques Integer (entières)

Les données numériques entières doivent être conformes à l'ISO 6093:1985 et seuls les caractères **0 à 9** sont permis. Les nombres entiers doivent être non signés et ne doivent pas non plus comporter d'unités dimensionnelles.

Pour des besoins pratiques, un nombre entier doit être limité à une résolution de 16 bits, c'est-à-dire que seules les valeurs entières comprises entre 0 inclus et 65536 inclus sont acceptables.

7.1.3.5 Données de date

Les données de date doivent être conformes au format de l'ISO 8601:2004, et peuvent comporter des informations d'heure également, par exemple:

“AAAA-MM-JJ”, “AAAAMMJJ”, “AAAA-MM-JJTHH:MM:SS”.

7.1.4 Déclarations aval

Afin de permettre une analyse en une seule passe, aucun identificateur de variable ou nom de variable ne doit être référencé avant d'avoir été défini.

7.1.5 Unités

Toutes les unités doivent appartenir au système SI, à part l'unité géométrique du micron (10^{-6} m), le pouce et le mil (10^{-3} pouce). Une seule unité de dimension doit être permise au sein d'un même bloc **DEVICE**. Remarquer que le pouce et le millième de pouce sont des unités non préférentielles et ne sont présents qu'en raison de la poursuite de leur usage courant.

7.1.6 Données de coordonnées

Dans toutes les données de coordonnées, la coordonnée **X** doit précéder la coordonnée **Y** et la coordonnée **Y** doit précéder la coordonnée **Z** (à savoir **X,Y** ou **X,Y,Z**).

La coordonnée **X** doit être l'axe horizontal (numériquement de gauche à droite), la coordonnée **Y** doit être l'axe vertical (numériquement de bas en haut) et la coordonnée **Z** doit être l'axe de profondeur (numériquement de proche en éloigné).

7.1.7 Mots réservés

Tous les noms de paramètres doivent être considérés comme réservés et aucun identificateur de variable ou nom de variable ne doit être autorisé à avoir le même nom. L'interdiction ne s'applique pas aux données textuelles de forme libre entre apostrophes ou entre guillemets (voir 7.1.3.1 et 7.1.3.2).

7.2 Syntaxe du bloc **DEVICE DDX**

```
DEVICE device_name device_form {  
    données pertinentes de la puce .....  
}
```

Le fichier **DDX** peut contenir un ou plusieurs blocs **DEVICE**, toutes les données appartenant à un dispositif particulier doivent être intégrées dans le bloc correspondant. (Voir 6.1.1 et 7.1.1).

Un bloc **DEVICE** s'ouvre avec le mot-clé **DEVICE** et l'accolade d'ouverture «{», (comme monté), et le bloc **DEVICE** se ferme par l'accolade de fermeture «}».

Les données qui ne sont pas à l'intérieur de la structure de bloc **DEVICE** doivent être traitées comme une remarque, permettant l'addition ultérieure d'informations de somme de contrôle, la date de création de fichier et des données historiques etc., dans le fichier **DDX**, sans altérer les données du dispositif réel.

device_name est le nom donné par lequel le dispositif doit être appelé tandis que le **device_form** est la forme mécanique du dispositif auquel les données du bloc se rapportent.

Les données valides pour la variable **device_form** sont:

- **bare_die**,
- **bumped_die**,
- **lead_frame_die**
- **minimally_packaged_device** (ou **MPD**).

D'autres types de **device_form** peuvent être ajoutés à un stade ultérieur (voir la CEI 61360-4:2005, AAD004-001, «code de type de puce», pour de plus amples détails).

Un seul bloc **DEVICE** ayant le nom **device_name** du type **device_form** doit être présent dans un fichier **DDX** mais il est permis de dupliquer **device_name** ou **device_form**.

Exemple d'un agencement type de fichier **DDX** de blocs **DEVICE**:-

```

DEVICE name1 bare_die {
  données pertinentes pour le dispositif «name1» comme puce nue..
}
DEVICE name1 bumped_die {
  données pertinentes pour le dispositif «name1» comme puce à
  bosses..
}
DEVICE name2 mpd {
  données pertinentes pour le dispositif «name2» comme dispositif à
  encapsulation minimale..
}
DEVICE name2 bare_die {
  données pertinentes pour le dispositif «name2» comme puce nue..
}
DEVICE name1 mpd {
  données pertinentes pour le dispositif «name1» comme dispositif à
  encapsulation minimale..
}
DEVICE name3 bare_die {
  données pertinentes pour le dispositif «name3» comme puce nue..
}

```

L'exemple ci-dessus comporte trois occurrences d'un bloc **DEVICE** pour le dispositif «name1», et deux occurrences d'un bloc **DEVICE** pour le dispositif «name2» mais chacun de ces blocs **DEVICE** spécifie un **device_form** différent. L'ordre ou la séquence des blocs **DEVICE** n'a pas d'importance.

7.3 Syntaxe des données DDX

Propriété = valeur [, valeur];

<propriété>[signe égal comme séparateur]<valeur/variable {séparateur <valeur/variable> }>[fin de données][fin de ligne]

<propriété>	::=	Nom du paramètre
[espace]	::=	{caractère espace (20h) ou caractère tabulation (09h)}0+
[séparateur égal]	::=	[espace]{égal =}[espace]
[séparateur]	::=	[espace]{virgule ,}[espace]
[fin de données]	::=	[espace]{point-virgule;}
[fin de ligne]	::=	{CR ou CR/LF}

Par exemple:

Thickness	=	100.0;
Thickness	=	470;
geometric_units	=	micron;
geometricunits	=	micron;
GeometricUnits	=	"millimetres";
terminal_type	=	T1, Circle, 220;
Terminal_Type	=	T2, Rectangle, 200 , 250;
TerminalType	=	T2, O, (200, 250);
TERMINALTYPE	=	T2, O, 200 , 250;

Ainsi, **terminal_type**, **Terminal_Type**, **TerminalType** et **TERMINALTYPE** font tous référence au même nom de paramètre.

8 Définitions des paramètres d'un bloc **DEVICE**

8.0 Notes d'usage général

8.0.1 Notes relatives à la forme du dispositif

Lorsqu'un paramètre est unique au **device_form**, tel que défini dans le bloc **DEVICE**, le paramètre sera précédé par...

- 8.0.1.1** **DIE_** le paramètre de données est unique à la forme de puces nues ou de puces à bosses
- 8.0.1.2** **BUMP_** le paramètre de données est unique aux puces à bosses seulement
- 8.0.1.3** **MPD_** le paramètre de données est unique aux dispositifs à encapsulation minimale, tels qu'un CSP
- 8.0.1.4** **WAFER_** le paramètre de données est unique à une puce nue livrée au niveau tranche
- 8.0.1.5** **LEAD_** le paramètre de données est unique à un dispositif de puce avec une grille de connexion fixée.

8.0.2 Eléments de paramètres de données

Avec la liste suivante de paramètres de données (voir 8.1 et suivants), il apparaît les éléments suivants:

- 8.0.2.1** le nom du paramètre, tel qu'utilisé par la syntaxe au sein d'un fichier **DDX**,
- 8.0.2.2** le type du paramètre, indiquant soit un type variable, soit un type de données de structure,
- 8.0.2.3** la fonction du paramètre, déterminant son utilisation et sa signification,
- 8.0.2.4** la valeur du paramètre indiquant le type de données attendu,
- 8.0.2.5** toute limitation de paramètre, indiquant toute limitation au sein du bloc **DEVICE**,
- 8.0.2.6** les dépendances de paramètre, soulignant les paramètres qu'il est nécessaire de déclarer avant invocation,
- 8.0.2.7** un ou plusieurs exemples pratiques, et
- 8.0.2.8** toute remarque pertinente.

Un bref tableau de paramètres est donné dans l'Annexe F, et un exemple pratique d'un bloc complet **DDX DEVICE** est donné dans l'Annexe A, la sortie graphique attendue étant fournie dans l'Annexe C.

Tous les paramètres doivent être conformes aux codes correspondants de la CEI 61360 du type d'élément de données (DET), tels que définis dans la CEI 61360-4:2005. Se référer à l'Annexe F pour un tableau de références croisées.

8.0.3 Termes et conventions

Un point de connexion électrique s'appelle une borne. Il peut s'agir d'un plot de connexion pour une puce nue et cela peut également se référer à la zone de plaques de contact ou d'empreintes de plots requise par un support d'interconnexion. Par convention, la borne placée au coin supérieur gauche d'une puce a le numéro 1 et la numérotation des bornes ou des broches progresse en séquence dans le sens contraire des aiguilles d'une montre.

Les dimensions en coordonnée X se rapportent à la longueur dans le plan horizontal, avec des valeurs positives augmentant vers la droite. Les dimensions en coordonnée Y se rapportent à la largeur dans le plan horizontal avec des valeurs positives qui augmentent en s'éloignant de

la vue de l'utilisateur. Les dimensions en coordonnée Z se rapportent à la hauteur dans la direction verticale avec des valeurs positives qui augmentent vers le haut (vers l'observateur).

Comme point de référence, tous les composants, y compris les puces à bosses, sont généralement vus de dessus, avec le côté actif vers le haut.

8.0.4 Résumé des règles générales

- 8.0.4.1** Toutes les données valides doivent être contenues dans un bloc **DEVICE** (voir 7.1.1).
- 8.0.4.2** Tout paramètre local ou unique, tel qu'un nom, doit être défini avant son utilisation.
- 8.0.4.3** Tous les paramètres doivent se conformer aux codes DET correspondants de la CEI 61360, tels que définis dans la partie 4 de la CEI 61360 (voir 5.8 et Annexe F).
- 8.0.4.4** Les unités de mesure, **GEOMETRIC_UNITS**, doivent être définies avant qu'une quelconque variable géométrique ne soit définie.
- 8.0.4.5** L'origine géométrique, **GEOMETRIC_ORIGIN**, et la vue géométrique, **GEOMETRIC_VIEW**, doivent être définies avant que de quelconques coordonnées géométriques ne soient définies.
- 8.0.4.6** Le paramètre **TERMINAL_COUNT** doit être défini avant qu'il ne soit fait référence à de quelconques paramètres **TERMINAL** et le nombre de paramètres **TERMINAL** ne doit pas dépasser la valeur de **TERMINAL_COUNT**.
- 8.0.4.7** Le paramètre **TERMINAL_TYPE_COUNT** doit être défini avant qu'il ne soit fait référence à de quelconques paramètres **TERMINAL_TYPE** et le nombre de paramètres **TERMINAL_TYPE** ne doit pas dépasser la valeur de **TERMINAL_TYPE_COUNT**.

8.1 BLOCK DATA (DONNÉES DE BLOC)

8.1.1 Paramètre **DEVICE_NAME**

Il est défini dans l'en-tête de bloc **DEVICE** comme étant le paramètre **device_name**.

Nom de paramètre	device_name
Type du paramètre	Variable, se référer à 7.2 sur les blocs DEVICE
Fonction du paramètre	Définit le numéro de type ou le nom de référence selon le fabricant de dispositif
Valeurs du paramètre	Données de nom textuel, comme en 7.1.3.2
Exemple	SN74LS04
Référence	Voir 7.1.7, 7.2 et Annexe G.

8.1.2 Paramètre **DEVICE_FORM**

Il est défini dans l'en-tête de bloc **DEVICE** par le paramètre **device_form**.

Nom de paramètre	device_form
Type du paramètre	Variable, se référer à 7.2 sur les blocs DEVICE
Fonction du paramètre	Définit la forme physique du dispositif.
Valeurs du paramètre	Données de chaîne textuelle, conformément à 7.1.3.1
Exemple	bare_die, bumped_die, MPD
Référence	Paragraphe 7.2 et Annexe G.

8.1.3 Paramètre **BLOCK_VERSION**

Nom de paramètre	BLOCK_VERSION
Type du paramètre	Variable
Fonction du paramètre	Spécifie le numéro de version et/ou le numéro d'émission du bloc DEVICE .

Valeurs du paramètre	Données de chaîne textuelle, conformément à 7.1.3.1
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemple	<code>BLOCK_VERSION = "1.0A";</code>
Référence	Annexe G.

8.1.4 Paramètre **BLOCK_CREATION_DATE**

Nom de paramètre	BLOCK_CREATION_DATE
Type du paramètre	Variable
Fonction du paramètre	Spécifie la date à laquelle le bloc DEVICE a été créé et modifié pour la dernière fois.
Valeurs du paramètre	Date, conformément à 7.1.3.5
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemples	<code>BLOCK_CREATION_DATE = "1997-12-25";</code>
Référence	Annexe G.

8.1.5 Paramètre **VERSION**

Nom de paramètre	VERSION
Type du paramètre	Variable
Fonction du paramètre	Spécifie le numéro de version de la norme DDX (actuellement à la version 1.3.0), à laquelle ce bloc DEVICE est conforme.
Valeurs du paramètre	Données de chaîne textuelle, conformément à 7.1.3.1
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemple	<code>VERSION = "1.3.0";</code>
Notes	Voir Article 1 pour la version de document de la présente Norme. Remarquer que le présent document peut ne pas être la version la plus récente et donc se référer aux Autorités de normalisation en cas de doute
Référence	Annexe G.

8.2 DONNÉES DE DISPOSITIF

8.2.1 Paramètre **DIE_NAME**

Nom de paramètre	DIE_NAME
Type du paramètre	Variable
Fonction du paramètre	Spécifie le nom du jeu de puce ou de masque ayant servi à produire la puce. Il peut être différent du paramètre DEVICE_NAME.
Valeurs du paramètre	Données de chaîne textuelle, conformément à 7.1.3.1
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemple	<code>DIE_NAME = "XXC345";</code>
Référence	Annexe G.

8.2.2 Paramètre **DIE_PACKAGED_PART_NAME**

Nom de paramètre	DIE_PACKAGED_PART_NAME
Type du paramètre	Variable
Fonction du paramètre	Spécifie le nom de pièce des fabricants pour une pièce emballée équivalente, le cas échéant. Il peut être différent du paramètre DEVICE_NAME.
Valeurs du paramètre	Données de chaîne textuelle, conformément à 7.1.3.1
Exemple	<code>DIE_PACKAGED_PART_NAME = "SN5405JN";</code>
Notes	Utilisé pour se référer à une pièce de puce encapsulée identique, pas une fonction simplement similaire, lorsqu'elle est livrée par le même fabricant sous forme encapsulée.

8.2.3 Paramètre **DIE_MASK_REVISION**

Nom de paramètre	DIE_MASK_REVISION
Type du paramètre	Variable

Fonction du paramètre	Spécifie les détails relatifs à la révision du masque associés à la version particulière en question sur la puce.
Valeurs du paramètre	Données de chaîne textuelle, conformément à 7.1.3.1
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE .
Exemple	<code>DIE_MASK_REVISION = "RTDAC1";</code> <code>DIE_MASK_REVISION = "9033-2-101-M5/2";</code>
Notes	Destiné à s'assurer que les données de puce correspondent à la version géométrique de la puce réelle.
Référence	Annexe G.

8.2.4 Paramètre **MANUFACTURER**

Nom de paramètre	MANUFACTURER
Type du paramètre	Variable
Fonction du paramètre	Spécifie le fabricant ou l'usine de fabrication du dispositif.
Valeurs du paramètre	Données de chaîne textuelle, conformément à 7.1.3.1
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE .
Exemple	<code>MANUFACTURER = "Fuzziwuz Logic Inc.";</code>

8.2.5 Paramètre **DATA_SOURCE**

Nom de paramètre	DATA_SOURCE
Type du paramètre	Variable
Fonction du paramètre	Spécifie la source des données du dispositif, notamment lorsqu'elle diffère du fabricant ou de l'usine de fabrication.
Valeurs du paramètre	Données de chaîne textuelle, conformément à 7.1.3.1
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE .
Exemple	<code>DATA_SOURCE = "AnyChip Technology Ltd.";</code> <code>DATA_SOURCE = "GOOD-DIE database";</code>

8.2.6 Paramètre **DATA_VERSION**

Nom de paramètre	DATA_VERSION
Type du paramètre	Variable
Fonction du paramètre	Spécifie la révision de la source de données utilisée pour déterminer les paramètres au sein du bloc DEVICE . Ce paramètre est lié à 8.2.5, Paramètre DATA_SOURCE
Valeurs du paramètre	Données de chaîne textuelle, conformément à 7.1.3.1
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE .
Exemple	<code>DATA_VERSION = "Initial Issue 1.0";</code>
Référence	Se référer à l'Annexe G.

8.2.7 Paramètre **FUNCTION**

Nom de paramètre	FUNCTION
Type du paramètre	Variable
Fonction du paramètre	Brève description de la fonction des dispositifs
Valeurs du paramètre	Données de chaîne textuelle, conformément à 7.1.3.1
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE .
Exemple	<code>FUNCTION = "16 Bit Microprocessor";</code>
Notes	La CEI 61360-4:2005 spécifie certaines classes fonctionnelles et d'application qui peuvent être utilisées.

8.2.8 Paramètre **IC_TECHNOLOGY**

Nom de paramètre	IC_TECHNOLOGY
Type du paramètre	Variable
Fonction du paramètre	Spécifie la technologie de fabrication du dispositif
Valeurs du paramètre	Données de chaîne textuelle, conformément à 7.1.3.1
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE .
Exemple	<code>IC_TECHNOLOGY = "CMOS";</code> <code>IC_TECHNOLOGY = "bipolar";</code>

```
IC_TECHNOLOGY = "bicmos";
IC_TECHNOLOGY = "GaAs";
```

8.2.9 Paramètre DEVICE_PICTURE_FILE

Nom de paramètre	DEVICE_PICTURE_FILE
Type du paramètre	Variable
Fonction du paramètre	Spécifie le(s) nom(s) du (des) fichiers de graphiques ou d'images représentant le dispositif.
Valeurs du paramètre	Données de nom textuel, comme en 7.1.3.2
Exemple	<pre>DEVICE_PICTURE_FILE = "DIE001.JPG"; DEVICE_PICTURE_FILE = "AA0B0C.SF", "FRED.GIF";</pre>
Notes	Le fichier d'images peut être une photographie réelle ou une représentation graphique du dispositif. Il convient que l'extension du fichier indique le format utilisé. Seuls doivent être utilisés les noms de fichier, sans nom de chemin relatif ou absolu. Plusieurs paramètres (noms de fichier d'images) peuvent être introduits dans une déclaration unique ou bien plusieurs déclarations peuvent être utilisées pour le même effet. Il n'existe aucune exigence de mise à l'échelle ou positionnelle.
Référence	Annexe I, Notes 3 et 4.

8.2.10 Paramètre DEVICE_DATA_FILE

Nom de paramètre	DEVICE_DATA_FILE
Type du paramètre	Variable
Fonction du paramètre	Spécifie le(s) nom(s) d'un ou plusieurs fichiers contenant des données pertinentes, telles que les spécifications techniques, les documents d'approvisionnement ou des fiches signalétiques générales.
Valeurs du paramètre	Données de nom textuel, comme en 7.1.3.2
Exemple	<pre>DEVICE_DATA_FILE = "SpecSheet.PDF"; DEVICE_DATA_FILE = "AA0B0C.DOC", "AA0B0C.TXT";</pre>
Notes	Le fichier de données peut avoir n'importe quel format reconnu. Il convient que l'extension du fichier indique le format utilisé. Seuls doivent être utilisés les noms de fichier, sans nom de chemin relatif ou absolu. Plusieurs paramètres (noms de fichier de données) peuvent être introduits dans une déclaration unique ou bien plusieurs déclarations peuvent être utilisées pour le même effet.
Référence	Annexe I, Notes 3 et 4.

8.3 DONNÉES GÉOMÉTRIQUES

8.3.1 Paramètres GEOMETRIC_UNITS

Nom de paramètre	GEOMETRIC_UNITS
Type du paramètre	Variable
Fonction du paramètre	Spécifie les unités géométriques qui doivent s'appliquer à toutes les valeurs géométriques au sein du bloc DEVICE.
Valeurs du paramètre	Données de chaîne textuelle, conformément à 7.1.3.1. L'une des valeurs suivantes: ▪ micromètre ou micron, ▪ mètre, ▪ millimètre, ▪ pouce ▪ mil (1.0E-3 pouce)
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemple	<pre>GEOMETRIC_UNITS = microns; GEOMETRIC_UNITS = mil;</pre>
Notes	Ce paramètre GEOMETRIC_UNITS doit être déclaré avant d'utiliser une quelconque unité géométrique. Le micron est en général l'unité

dimensionnelle par défaut pour les dimensions des puces tandis que le pouce et le mil sont des unités non préférentielles.
 Référence Paragraphe 7.1.5 et Annexe E.

8.3.2 Paramètre **GEOMETRIC_VIEW**

Nom de paramètre **GEOMETRIC_VIEW**
 Type du paramètre Variable
 Fonction du paramètre Spécifie la vue géométrique qui doit s'appliquer à toutes les formes géométriques au sein du bloc DEVICE.
 Valeurs du paramètre Données de chaîne textuelle, conformément à 7.1.3.1.
 L'une des valeurs suivantes:
 • **TOP** c'est-à-dire côté actif vers le haut, et
 • **BOTTOM** c'est-à-dire côté actif vers le bas.
 Limitations Doit être déclaré une seule fois dans un seul bloc DEVICE.
 Exemple `GEOMETRIC_VIEW = top;`
`GEOMETRIC_VIEW = "bottom";`
 Notes Le paramètre **GEOMETRIC_VIEW** doit être déclaré avant de créer une quelconque forme géométrique. Il est courant de voir une puce nue et une pièce emballée en vue de dessus "TOP" alors que cela sera en vue de dessous "BOTTOM" (c'est-à-dire à travers le substrat) pour une puce à bosses.
 Référence Annexe E.

8.3.3 Paramètre **GEOMETRIC_ORIGIN**

Nom de paramètre **GEOMETRIC_ORIGIN**
 Type du paramètre Variable
 Fonction du paramètre Détermine l'origine géométrique en X et en Y par rapport à laquelle toutes les autres coordonnées sont référencées. L'origine est donnée par rapport au centre géométrique de la puce dans les unités spécifiées par le paramètre **GEOMETRIC_UNITS**.
 Valeurs du paramètre Origine de coordonnée en nombre réel X, origine de coordonnée en nombre réel Y, conformément à 7.1.3.3.
 Dépendances **GEOMETRIC_UNITS, SIZE**
 Limitations Doit être déclaré une seule fois dans un seul bloc DEVICE.
 Exemple `GEOMETRIC_ORIGIN = -6000,-7500;`
 Notes Les valeurs de dimensions sont exprimées en **GEOMETRIC_UNITS**. Les valeurs des paires de coordonnées d'origine se rapportent au centre géométrique (voir Figure 1 pour une explication plus complète).
 Référence Annexe E.




Figure 1 – Relation entre le centre géométrique et l'origine géométrique

Le paramètre GEOMETRIC_ORIGIN est traité comme un décalage pour toutes les données de coordonnées et, de ce fait, les valeurs de GEOMETRIC_ORIGIN sont **ajoutées à toutes** les paires individuelles de coordonnées pour donner la position en X et en Y par rapport au centre géométrique du dispositif.

La principale utilisation du paramètre GEOMETRIC_ORIGIN est de permettre le centrage de l'origine sur une borne ou autre caractéristique géométrique, plutôt qu'en une position géométrique arbitraire car, dans la pratique, SIZE peut être l'objet d'une tolérance asymétrique et, par voie de conséquence, toutes les références liées à ce centre géométrique pourraient elles-aussi être soumises à une erreur de tolérance.

8.3.4 Paramètre SIZE

Nom de paramètre	SIZE
Type du paramètre	Variable
Fonction du paramètre	Détermine les dimensions X et Y du dispositif, et spécifie facultativement sa forme comme étant une ellipse.
Valeurs du paramètre	Dimension X en nombre réel, dimension Y en nombre réel (conformément à 7.1.3.3), {Ellipse}
Dépendances	GEOMETRIC_UNITS, GEOMETRIC_VIEW
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemple	SIZE = 250, 500.5; SIZE = 350, 350, E;
Notes	Les valeurs de dimensions sont exprimées en GEOMETRIC_UNITS. Dans le dernier exemple, le caractère «E» comme 3e paramètre définit une ellipse, dans cette instance une puce circulaire de diamètre 350 GEOMETRIC_UNITS.
Référence	Annexe E.

8.3.5 Paramètre SIZE_TOLERANCE

Nom de paramètre	SIZE_TOLERANCE
------------------	-----------------------

Type du paramètre	Variable
Fonction du paramètre	Spécifier la/les tolérance(s) géométrique(s) des valeurs du paramètre SIZE
Valeurs du paramètre	Réelles en GEOMETRIC_UNITS, conformément à 7.1.3.3.
Dépendances	GEOMETRIC_UNITS, SIZE, GEOMETRIC_VIEW
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemple	<pre>SIZE_TOLERANCE = 0.5; SIZE_TOLERANCE = -0.2, 0.5; SIZE_TOLERANCE = -0.2, 0.5, -0.1, 0.4;</pre>
Notes	Une, deux ou quatre valeurs peuvent être données: Lorsqu'une valeur de tolérance unique est donnée, la tolérance doit être prise comme étant une valeur non signée $\pm$ pour l'axe X et aussi pour l'axe Y. Lorsque deux valeurs de tolérance sont données: la première valeur doit être prise comme étant le minimum pour l'axe X et aussi pour l'axe Y, la seconde valeur doit être prise comme étant le maximum pour l'axe X et aussi pour l'axe Y. Lorsque quatre valeurs de tolérance sont données: la première valeur doit être prise comme étant le minimum pour l'axe X, la deuxième valeur doit être prise comme étant le maximum pour l'axe X, la troisième valeur doit être prise comme étant le minimum pour l'axe Y; la quatrième valeur doit être prise comme étant le maximum pour l'axe Y.

8.3.6 Paramètre THICKNESS

Nom de paramètre	THICKNESS
Type du paramètre	Variable
Fonction du paramètre	Détermine l'épaisseur (dimension Z) du dispositif.
Valeurs du paramètre	Valeur de la dimension Z en nombre réel, conformément à 7.1.3.3
Dépendances	GEOMETRIC_UNITS
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemple	<pre>THICKNESS = 10.5;</pre>
Notes	Les valeurs de dimensions sont exprimées en GEOMETRIC_UNITS.

8.3.7 Paramètre THICKNESS_TOLERANCE

Nom de paramètre	THICKNESS_TOLERANCE
Type du paramètre	Variable
Fonction du paramètre	Spécifie l'une ou les plusieurs tolérances du paramètre THICKNESS qui peuvent être attendues en raison des variations normales de processus.
Valeurs du paramètre	Réelles en GEOMETRIC_UNITS, conformément à 7.1.3.3.
Dépendances	GEOMETRIC_UNITS, THICKNESS
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemple	<pre>THICKNESS_TOLERANCE = 2.5; THICKNESS_TOLERANCE = -1.2, 1.5;</pre>
Notes	Une ou deux valeurs peuvent être données: Lorsqu'une tolérance unique est donnée, la tolérance doit être prise comme étant une valeur non signée $\pm$. Lorsque deux valeurs de tolérance sont données: la première valeur doit être prise comme le minimum et la seconde valeur doit être prise comme le maximum.

8.3.8 Paramètre FIDUCIAL_TYPE

Nom de paramètre	FIDUCIAL_TYPE
------------------	----------------------

Type du paramètre	Structure
Fonction du paramètre	La structure FIDUCIAL_TYPE attribue un nom de type de repère conventionnel et définit le fichier graphique associé et la taille d'un type individuel de repère conventionnel. La structure peut être utilisée pour définir un seul type de repère conventionnel ou une multitude de types de repère conventionnel.
Dépendances	GEOMETRIC_UNITS, GEOMETRIC_VIEW
Notes	Un repère conventionnel existe uniquement comme forme graphique dans un rectangle, les données graphiques pour le repère conventionnel sont contenues dans un fichier graphique externe. Les paires de coordonnées pour ce rectangle sont uniquement rapportées au type de forme de repère conventionnel et sont utilisées comme des références lors du placement de la forme.
Référence	Annexes E et I.

Syntaxe de la définition d'un FIDUCIAL_TYPE unique:

```
FIDUCIAL_TYPE Fiducial_type_name = Fiducial_file_name, X-size, Y-size;
FIDUCIAL_TYPE Fiducial_type_name = Fiducial_file_name, X-size, Y-size;
```

Syntaxe de la définition d'un FIDUCIAL_TYPE multiple:

```
FIDUCIAL_TYPE {
    Fiducial_type_name = Fiducial_file_name, X-size, Y-size;
    Fiducial_type_name = Fiducial_file_name, X-size, Y-size;
    Fiducial_type_name = Fiducial_file_name, X-size, Y-size;
}
```

où:

8.3.8.1 Fiducial_type_name

Nom de référence textuel (conformément à 7.1.3.2) pour un type de repère conventionnel, lequel nom doit être unique dans le bloc DEVICE.

8.3.8.2 Fiducial_file_name

Il s'agit du nom du fichier (conformément à 7.1.3.2) qui contient le repère conventionnel sous forme de données graphiques. Le type des données graphiques doit être indiqué par le code d'extension de fichier, tel que "BMP", "GIF", "DXF" etc. Le type de données n'est pas spécifié dans la présente Norme et il incombe au logiciel de CAO/IAO de décider de ce qui peut ou ne peut pas être affiché. Le graphique doit être traité comme étant contenu dans un rectangle de dimensions X-size et Y-size.

8.3.8.3 X-size, Y-size

Ces paramètres numériques réels (conformément à 7.1.3.3) comprennent une paire de coordonnées et déterminent la taille du rectangle du graphique de repère conventionnel. Le centre géométrique du graphique de repère conventionnel doit être déterminé comme étant en (X-size/2, Y-size/2).

Exemple 1

```
FIDUCIAL_TYPE Fid1 = "tile.bmp", 200, 250;
```

Cet exemple décrit un repère conventionnel, trouvé comme un fichier externe «tile.bmp», appelé de manière unique Fid1, avec un X-size de 200 unités, et un Y-size de 250 unités. Les unités sont définies par le paramètre GEOMETRIC_UNITS.

Exemple 2

```

FIDUCIAL_TYPE {
    fidu1 = "graphic1.bmp", 200, 300;
    fidu2 = "graphic2.dxf", 500, 500;
    fidu3 = "graphic3.gif", 100, 100;
}

```

Cet exemple de plusieurs définitions décrit trois types et tailles séparés de repère conventionnel.

- **fidu1** est contenu dans le fichier «graphic1.bmp», d'une taille de 200 unités par 300 unités.
- **fidu2** est contenu dans le fichier «graphic2.dxf», d'une taille de 500 unités par 500 unités.
- **fidu3** est contenu dans le fichier «graphic3.gif», d'une taille de 100 unités par 100 unités.

8.3.9 Paramètre FIDUCIAL

Nom de paramètre	FIDUCIAL
Type du paramètre	Structure
Fonction du paramètre	La structure FIDUCIAL définit l'emplacement et l'orientation de chaque repère conventionnel graphique. En tant que structure, FIDUCIAL peut être utilisé pour définir un repère conventionnel unique ou une multitude de repères conventionnels.
Dépendances	GEOMETRIC_VIEW, FIDUCIAL_TYPE, GEOMETRIC_UNITS, et GEOMETRIC_ORIGIN.
Notes	Chaque nom de type de repère conventionnel utilisé doit avoir été préalablement déclaré dans une invocation de FIDUCIAL_TYPE et les informations relatives aux paires de coordonnées doivent se rapporter au GEOMETRIC_ORIGIN du dispositif.
Référence	Annexe E.

Syntaxe de la définition d'un **FIDUCIAL** unique:

```

FIDUCIAL F_n = Fiducial_type_name, X-co., Y-co., orientation;
FIDUCIAL F_n = Fiducial_type_name, X-co., Y-co., orientation;

```

Syntaxe de la définition d'un **FIDUCIAL** multiple:

```

FIDUCIAL {
    F_n = Fiducial_type_name, X-co., Y-co., orientation;
    F_n = Fiducial_type_name, X-co., Y-co., orientation;
    F_n = Fiducial_type_name, X-co., Y-co., orientation;
}

```

où:

8.3.9.1 F_n

Identificateur de repère conventionnel unique, où "**n**" est le numéro effectif du repère conventionnel (nombre entier, conformément à 7.1.3.4), numérotation à partir du coin supérieur gauche dans le sens contraire des aiguilles d'une montre. Noter que le trait de soulignement est facultatif, il est utilisé pour la clarté seulement.

8.3.9.2 Fiducial_type_name

Nom textuel (conformément à 7.1.3.2) d'une forme référencée de FIDUCIAL_TYPE (conformément à 8.3.8.1), lequel nom doit avoir été préalablement déclaré (voir 7.1.4).

8.3.9.3 X-co

Valeur numérique réelle de la coordonnée X (comme en 7.1.3.3) pour l'emplacement du centre de la forme de repère conventionnel, en unités définies par le paramètre GEOMETRIC_UNITS. Cette valeur est rapportée à la valeur de la coordonnée X du GEOMETRIC_ORIGIN, et ce paramètre a un fonctionnement identique à celui décrit en 8.4.5.4.

8.3.9.4 Y-co

Valeur numérique réelle de la coordonnée Y (conformément à 7.1.3.3) pour l'emplacement du centre de la forme de repère conventionnel, en unités définies par le paramètre GEOMETRIC_UNITS. Cette valeur est rapportée à la valeur de la coordonnée Y du GEOMETRIC_ORIGIN, et ce paramètre a un fonctionnement identique à celui décrit en 8.4.5.5.

8.3.9.5 Orientation

Valeur d'orientation, en valeurs entières de 0 à 360 (voir 7.1.3.4). Il s'agit de l'angle de rotation dans le sens horaire, exprimé en degrés, autour du centre de référence géométrique de la forme de repère conventionnel. Si les lettres "MX" sont incluses, l'orientation de la forme de repère conventionnel doit être miroitée dans l'axe X; de même, si les lettres "MY" sont incluses, l'orientation de la forme de repère conventionnel doit être miroitée dans l'axe Y. "MX" et "MY" peuvent être présents simultanément (voir Annexe D pour une représentation graphique) et l'ensemble du miroitage doit être effectué autour du centre de référence géométrique de la forme de repère conventionnel. Noter que l'opération de miroitage doit être réalisée en premier lieu puis le repère conventionnel doit être tourné de l'angle d'orientation. Ce paramètre a un fonctionnement identique à celui décrit en 8.4.5.6

Exemple 1

```
FIDUCIAL Fid007 = fidu1, 5000, 7000, MX0;
```

Cet exemple déclare que le repère conventionnel **Fid007**.....

- est situé à X = 5 000 unités, Y = 7 000 unités,
- est un FIDUCIAL_TYPE dénommé "fidu1", miroité sur l'axe X et orienté à 0°.

Exemple 2

```
FIDUCIAL F_18 = fiduX1, 1000, 2200, 90;
```

Cet exemple déclare que le repère conventionnel **F_18**

- est situé à X = 1 000 unités, Y = 2 200 unités,
- est un FIDUCIAL_TYPE dénommé "fiduX1", orienté (tourné) de 90° dans le sens horaire.

Exemple 3

```
FIDUCIAL {
    Fid007=fidu1, 5000, 7000, MX0;
    F_18 = fiduX1, 1000, 2200, 90;
}
```

Cet exemple de définition de repère conventionnel multiple déclare des données conventionnelles identiques à celles montrées dans les Exemples 1 et 2.

8.4 DONNÉES RELATIVES AUX BORNES

8.4.1 Paramètre TERMINAL_COUNT

Nom de paramètre **TERMINAL_COUNT**

Type du paramètre Variable

Fonction du paramètre Spécifie le nombre de bornes électriques ou de points de connexion.

Valeurs du paramètre	Integer, conformément à 7.1.3.4.
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemple	<code>TERMINAL_COUNT = 44;</code>
Notes	La valeur de <code>TERMINAL_COUNT</code> doit être déclarée avant la déclaration ou l'utilisation de tout <code>TERMINAL</code> .

8.4.2 Paramètre `TERMINAL_TYPE_COUNT`

Nom de paramètre	<code>TERMINAL_TYPE_COUNT</code>
Type du paramètre	Variable
Fonction du paramètre	Spécifie le nombre de formes ou types différents de borne de connexion ou de liaison.
Valeurs du paramètre	Integer, conformément à 7.1.3.4.
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemple	<code>TERMINAL_TYPE_COUNT = 4;</code>
Notes	La valeur de <code>TERMINAL_TYPE_COUNT</code> doit être déclarée avant la déclaration ou l'utilisation d'un quelconque <code>TERMINAL_TYPE</code> .

8.4.3 Paramètre `CONNECTION_COUNT`

Nom de paramètre	<code>CONNECTION_COUNT</code>
Type du paramètre	Variable, facultatif
Fonction du paramètre	Spécifie le nombre maximal de connecteurs utilisés par le paramètre <code>TERMINAL</code> . Ce paramètre spécifie en fait la valeur la plus élevée pour le nombre <i>conn_N</i> de connexions utilisées dans la déclaration du paramètre <code>TERMINAL</code> (voir 8.4.5.2).
Valeurs du paramètre	Integer, conformément à 7.1.3.4.
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemple	<code>CONNECTION_COUNT = 4;</code>
Notes	Il convient de déclarer la valeur de <code>CONNECTION_COUNT</code> avant la déclaration ou l'utilisation de tout <code>TERMINAL</code> . Il doit être utilisé comme le contrôle limite pour les nombres <i>conn_N</i> de connexions. Si le paramètre <code>CONNECTION_COUNT</code> n'est pas déclaré, aucun contrôle n'aura lieu.

8.4.4 Paramètre `TERMINAL_TYPE`

Nom de paramètre	<code>TERMINAL_TYPE</code>
Type du paramètre	Structure
Fonction du paramètre	La structure <code>TERMINAL_TYPE</code> attribue un nom de type et définit la forme et la taille d'un type individuel de borne. En tant que structure, <code>TERMINAL_TYPE</code> peut être utilisé pour définir un type de borne unique ou une multitude de types de borne.
Dépendances	<code>GEOMETRIC_UNITS</code> , <code>GEOMETRIC_VIEW</code> , <code>TERMINAL_TYPE_COUNT</code>
Notes	Les paires de coordonnées sont uniquement rapportées au type de forme de borne et sont utilisées comme des références lors du placement de la forme.
Référence	Annexe E.

Syntaxe de la définition d'un `TERMINAL_TYPE` unique:

```
TERMINAL_TYPE Terminal_type_name = Terminal_shape_type, Co-ordinates.,.,;
TERMINAL_TYPE Terminal_type_name = Terminal_shape_type, Co-ordinates.,.,;
```

Syntaxe de la définition d'un `TERMINAL_TYPE` multiple:

```
TERMINAL_TYPE {
    Terminal_type_name = Terminal_shape_type, Co-ordinates .,.,;
    Terminal_type_name = Terminal_shape_type, Co-ordinates .,.,;
```

Terminal_type_name = Terminal_shape_type, Co-ordinates .,.,.,;
}

où:

8.4.4.1 Terminal_type_name

Nom de référence textuel pour un type de borne (conformément à 7.1.3.2), lequel nom doit être unique dans le bloc DEVICE.

8.4.4.2 Terminal_shape_type

Détermine le type de forme de borne (il n'est nécessaire d'utiliser que la première lettre):

Tableau 1 – Types de forme de borne

Carac-tère	Donnée DET	Forme
R	RECT	<u>R</u> ectangle,
C	CIRC	<u>C</u> ercle,
E	ELL	<u>E</u> llipse,
P	POLY	<u>P</u> olygone.

8.4.4.3 Coordonnées (Co-ordinates)

Valeurs de coordonnées en nombre réel (voir Tableau 2), conformément à 7.1.3.3.

Elles spécifient les coordonnées relatives pour la forme de borne et, ce faisant, déterminent le centre de référence géométrique pour la forme. Le centre de référence géométrique pour la forme sera utilisé par les coordonnées TERMINAL (voir 8.4.5.4 et 8.4.5.5) pour placer la forme, et toutes les opérations de rotation et de miroitage seront réalisées autour du centre de référence géométrique. Seule la forme polygonale peut avoir un centre de référence géométrique autre que le «centre de gravité» naturel.

Tableau 2 – Coordonnées de la forme de borne

Forme	Coordonnées	Centre de référence géométrique
<u>R</u> ectangle	X-size, Y-size	Le centre géométrique (0,0) se placera à X-size/2:Y-size/2
<u>C</u> ercle	Diamètre	Le centre géométrique (0,0) se placera à diamètre/2:diamètre/2
<u>E</u> llipse	X-axis, Y-axis	Le centre géométrique (0,0) se placera à X-axis/2:Y-axis/2
<u>P</u> olygone	X-co ₁ , Y-co ₁ , X-co _N , Y-co _N	Un polygone de "N" cotés aura N paires de coordonnées géométriquement centrées sur (0,0), avec l'hypothèse que la forme polygonale sera complétée par le vecteur (Xco _N ,Yco _N - Xco ₁ ,Yco ₁)

Exemple 1

TERMINAL_TYPE ShapeR1 = Rectangle, 200, 250;

Cet exemple décrit un rectangle, appelé de manière univoque «ShapeR1», avec une dimension sur l'axe X de 200 unités et une dimension sur l'axe Y -de 250 unités. Les unités sont définies par le paramètre GEOMETRIC_UNITS.

Exemple 2

```

TERMINAL_TYPE {
    ShapeR1 = R, 200, 300;
    ShapeC2 = C, 250;
    ShapeE3 = E, 400, 200;
    ShapeP4 = P, (150, 200), (-150, 200), (-150, -150), ( 150, -150);
}

```

Cet exemple décrit quatre types et formes distincts de borne:

- ShapeR1 est une borne rectangulaire ayant une dimension sur l'axe X de 200 unités et une dimension sur l'axe Y de 300 unités,
- ShapeC2 est une borne circulaire de 250 unités de diamètre,
- ShapeE3 est une borne elliptique avec un diamètre sur l'axe X de 400 unités et un diamètre sur l'axe Y de 200 unités, et
- ShapeP4 est une forme de borne polygonale à quatre côtés, avec un centre de référence géométrique à (0,0).

Noter que seule la première lettre du descripteur *Terminal_shape_type* est utilisée et que les noms *Terminal_type_name* sont uniques.

8.4.5 Paramètre TERMINAL

Nom de paramètre	TERMINAL
Type du paramètre	Structure
Fonction du paramètre	La structure TERMINAL définit le nom, l'emplacement, l'orientation et la fonction électrique de chaque borne de connexion. En tant que structure, TERMINAL peut être utilisé pour définir une seule borne ou une multitude de bornes.
Dépendances	TERMINAL_COUNT, CONNECTION_COUNT, GEOMETRIC_VIEW, TERMINAL_TYPE, GEOMETRIC_UNITS, GEOMETRIC_ORIGIN.
Notes	Chaque nom de type de repère conventionnel utilisé doit avoir été préalablement déclaré dans une invocation de FIDUCIAL_TYPE et les informations relatives aux paires de coordonnées doivent se rapporter au GEOMETRIC_ORIGIN du dispositif. Se référer à l'Annexe E.

Syntaxe de la définition d'un TERMINAL unique:

```

TERMINAL Tn = conn_N, Terminal_type_name, X-co., Y-co., orient.,
Terminal_name, IO_type;
TERMINAL Tn = conn_N, Terminal_type_name, X-co., Y-co., orient.,
Terminal_name, IO_type;

```

Syntaxe de la définition d'un TERMINAL multiple:

```

TERMINAL {
    Tn = conn_N, Terminal_type_name, X-co., Y-co., orient.,
Terminal_name, IO_type;
    Tn = conn_N, Terminal_type_name, X-co., Y-co., orient.,
Terminal_name, IO_type;
    Tn = conn_N, Terminal_type_name, X-co., Y-co., orient.,
Terminal_name, IO_type;
}

```

où:

8.4.5.1 T_n

Identificateur de borne unique, où "**n**" est le numéro effectif de la borne (nombre entier, conformément à 7.1.3.4), numérotation à partir du coin supérieur gauche dans le sens contraire des aiguilles d'une montre. Noter que le trait de soulignement est facultatif, il est utilisé pour la clarté seulement.

8.4.5.2 conn_N

Numéro de connexion, nombre entier non unique, conformément à 7.1.3.4. Ce numéro de connexion est simplement une référence d'emplacement et peut facultativement se rapporter à une broche de boîtier; peut ne pas être présent ou bien peut être zéro, 0, ou laisser vide si inconnu. L'avantage singulier de ce numéro de connexion est de spécifier et identifier plusieurs bornes qu'il est nécessaire de raccorder ensemble. Il convient de vérifier la valeur de ce numéro de connexion afin de s'assurer qu'il ne dépasse pas la valeur déterminée par CONNECTION_COUNT, lorsqu'elle est spécifiée.

8.4.5.3 Terminal_type_name

Nom textuel (conformément à 7.1.3.2) d'une forme référencée de TERMINAL_TYPE (conformément à 8.4.3.1), lequel nom doit avoir été préalablement déclaré (voir 7.1.4).

8.4.5.4 X-co

Valeur numérique réelle de la coordonnée X (conformément à 7.1.3.3) pour l'emplacement du centre de la forme de borne, en unités définies par le paramètre GEOMETRIC_UNITS. Cette valeur se rapporte à la valeur de la coordonnée X du GEOMETRIC_ORIGIN.

8.4.5.5 Y-co

Valeur numérique réelle de la coordonnée Y (conformément à 7.1.3.3) pour l'emplacement du centre de la forme de borne, en unités définies par le paramètre GEOMETRIC_UNITS. Cette valeur se rapporte à la valeur de la coordonnée Y du GEOMETRIC_ORIGIN.

8.4.5.6 Orient

Valeur d'orientation, en valeurs entières de 0 à 360, conformément à 7.1.3.4. Il s'agit de l'angle de rotation dans le sens horaire, exprimé en degrés, autour du centre de référence géométrique de la forme de borne. Si les lettres "MX" sont incluses, l'orientation de la forme de borne doit être miroitée dans l'axe X; de même, si les lettres "MY" sont incluses, l'orientation de la forme de borne doit être miroitée dans l'axe Y. "MX" et "MY" peuvent être présents simultanément (voir Annexe D pour une représentation graphique) et l'ensemble du miroitage doit être effectué autour du centre de référence géométrique de la forme de borne. Noter que l'opération de miroitage doit être réalisée en premier lieu puis la borne doit être tournée de l'angle d'orientation.

8.4.5.7 Terminal_name

Nom textuel, non unique, conformément à 7.1.3.2. Ce nom de borne sert à la référence utilisateur et à l'affichage graphique seulement et peut être omis.

8.4.5.8 IO_type

Lettre unique indiquant le type de fonction des broches de borne tel que donné au Tableau 3, non obligatoire. D'autres caractères peuvent être ajoutés selon les besoins.

Tableau 3 – Types d'I/O (c'est-à-dire E/S) de borne

Lettre	Fonction des bornes
I	Input (c'est-à-dire Entrée), numérique
O	Output (c'est-à-dire Sortie), numérique
B	Bi-directional (c'est-à-dire Bidirectionnelle), numérique
G	Ground connection (c'est-à-dire Raccordement à la terre)
V	Alimentation, il peut s'agir de n'importe quel type d'alimentation.
A	Broche Analogique, entrée ou sortie
N	No-connect pin (c'est-à-dire broche sans connexion), laisser déconnectée
U	Undetermined (c'est-à-dire Indéterminée), I/O (c'est-à-dire E/S programmable par l'utilisateur
T	Test pin (c'est-à-dire broche d'essai), connecter seulement sur avis des fabricants
X	Raccordée intérieurement, ne pas raccorder
H	Broche d'entrée fonctionnelle numérique, à maintenir au niveau logique Haut
L	Broche d'entrée fonctionnelle numérique, à maintenir au niveau logique Low (c'est-à-dire Bas)

T_n (voir 8.4.5.1) doit toujours être unique alors que le numéro de connexion de broche (Paragraphe 8.4.5.2), **conn_N**, et le nom de borne (voir 8.4.5.7), **Terminal_{name}**, peuvent ne pas être uniques.

Exemple 1

```
TERMINAL Pin007 = 9, ShapeR1, (5000, 7000), MX0, VCC1, V;
```

Cet exemple déclare que la borne "**Pin007**".....

- est raccordée à la connexion arbitraire N° 9,
- est situé à X = 5 000 unités, Y = 7 000 unités,
- est un **TERMINAL_TYPE** dénommé "ShapeR1", miroité sur l'axe X et orienté à 0°, et
- est appelée "VCC1", et
- est une broche d'alimentation électrique.

Exemple 2

```
TERMINAL Conn08 = 17, ShapeP2, 5000, 7300, 90, qd2i, I;
TERMINAL Conn09 = 17, ShapeP2, 5000, 7800, 90, qd2o, O;
```

Ces exemples déclarent que les bornes "**Conn08**" et "**Conn09**".....

- sont toutes deux raccordées à la connexion arbitraire N° 17,
- sont situées respectivement à X = 5000 unités, Y = 7300 unités et à X = 5000 unités, Y = 7800 unités,
- sont toutes deux d'un **TERMINAL_TYPE** dénommé "ShapeP2", orienté (tourné) de 90° dans le sens horaire,
- sont dénommées "qd2i" et "qd2o"
- et constituent une connexion bidirectionnelle I/O numérique "qd2I" étant une entrée (I) et "qd2o" une sortie (O).

Exemple 3

```
TERMINAL Term10 = , ShapeP2, 5000, 7600, 0, , X;
```

Cet exemple déclare que la borne “Term10”.....

- n'est pas raccordée (ou n'a pas de référence de connexion spécifique),
- est située à X = 5000 unités, Y = 7600 unités,
- est d'un TERMINAL_TYPE dénommé “ShapeP2”, orienté à 0°, et
- n'a pas de nom attribué et
- est spécifiée comme une borne à laquelle rien ne doit être relié.

Exemple 4

```
TERMINAL T_44 = , ShapeR2, 25000, 97000, MXMY90, , ;
```

Cet exemple déclare que la borne T_44.....

- n'est pas raccordée (ou n'a pas de référence de connexion spécifique),
- est située à (25000:97000),
- est d'un TERMINAL_TYPE dénommé “ShapeR2”, miroité à la fois dans l'axe X et dans l'axe Y, puis orienté à (tourné dans le sens horaire de) 90°,
- n'a pas de nom attribué, et
- n'a pas de propriétés de connexion électrique spécifiées.

Exemple 5

```
TERMINAL {
  Pin007 = 9, ShapeR1, (5000, 7000), MX0, VCC1, V;
  Conn08 = 17, ShapeP2, (5000, 7300), 90, qd2i, I;
  Conn09 = 17, ShapeP2, (5000, 7800), 90, qd2o, O;
  Term10 = , ShapeP2, (5000, 7600), 0, , X;
  T_44 = , ShapeR2, (25000, 97000), MXMY90, , ;
}
```

Cet exemple de définition de borne multiple déclare des données de borne identiques à celles montrées dans les Exemples 1 à 4.

8.4.6 Paramètre TERMINAL_GROUP

Nom de paramètre TERMINAL_GROUP

Type du paramètre Structure

Fonction du paramètre La structure TERMINAL_GROUP affecte à un groupe de bornes un seul identificateur de groupe de bornes qui peut être utilisé à la place d'une liste de bornes. La structure peut être utilisée pour définir un seul groupe ou une multitude de groupes.
Se référer aux règles de TERMINAL_GROUP (voir 8.4.6.1) pour les détails.

Valeurs du paramètre Deux ou plusieurs identificateurs de borne ou de groupe, tels que définis en 8.4.5.1 et 8.4.6.3

Dépendances TERMINAL (voir 8.4.5)

Limitations Un identificateur de TERMINAL_GROUP doit être unique et peut seulement être référencé après qu'il a été déclaré.

Référence Annexe B.

8.4.6.1 Règles relatives à TERMINAL_GROUP

8.4.6.1.1 Contenu

Les éléments formant un groupe peuvent être des identificateurs de bornes, des identificateurs de groupes ou tout mélange des deux. Un groupe doit contenir au moins deux éléments.

8.4.6.1.2 Unicité

Tous les éléments d'un groupe doivent être uniques. Un groupe ne peut contenir de groupes qui se réfèrent directement ou indirectement au même élément.

8.4.6.1.3 Ordre

L'ordre des éléments dans des groupes peut être important. Lorsque deux ou plusieurs groupes doivent être reliés dans une permutation, les éléments au sein de ces groupes doivent correspondre à travers les groupes.

8.4.6.1.4 Récursivité

Un groupe ne peut se contenir lui-même ni ne peut-il contenir de groupe qui se réfère directement ou indirectement à lui-même.

Syntaxe de la définition d'un `TERMINAL_GROUP` unique:

```
TERMINAL_GROUP G_n = _ Terminal ou Group identifier, ... Terminal or Group identifier;
TERMINAL_GROUP G_n = _ Terminal ou Group identifier, ... Terminal or Group identifier;
```

Syntaxe de la définition d'un `TERMINAL_GROUP` multiple:

```
TERMINAL_GROUP {
    G_n = _ Terminal ou Group identifier, ... Terminal or Group identifier;
    G_n = _ Terminal ou Group identifier, ... Terminal or Group identifier;
}
```

où:

8.4.6.2 G_n

L'identificateur de `TERMINAL_GROUP` unique "*n*" est le numéro réel du `TERMINAL_GROUP` (Nombre entier, conformément à 7.1.3.4). Noter que le trait de soulignement est facultatif, il est utilisé pour la clarté seulement.

8.4.6.3 Identificateur de borne ou de groupe (*Terminal ou Group identifier*)

Deux ou plusieurs noms d'identificateur de borne ou de groupe de bornes

- Tout nom d'identificateur de borne doit être déclaré au préalable dans une déclaration de `TERMINAL` (voir 8.4.4.1). Un nom d'identificateur de borne ne peut apparaître qu'une seule fois dans une affectation de groupe unique.
- Tout nom d'identificateur de groupe de bornes doit être déclaré au préalable dans une déclaration de `TERMINAL_GROUP` (voir 8.4.6.2). Un nom d'identificateur de groupe de bornes peut apparaître une seule fois dans une seule affectation de groupe. et la circularité ou récursivité d'affectation est interdite.

Exemple

```
TERMINAL_GROUP G_1 = T_10, T_11, T_12;
TERMINAL_GROUP G_2 = T_15, T_16, T_12;

TERMINAL_GROUP {
    G_3 = T_1, T_2;
    G_4 = T_4, T_5;
    G_5 = G_1, T_3;
    G_6 = G_3, G_4, T_11;
}
```

Notes

Dans tous les cas, un identificateur de borne unique doit seulement apparaître une seule fois dans un groupe. Cela est également pertinent lorsqu'il s'agit de considérer l'expansion d'un groupe de bornes. Se référer à l'Annexe B.

8.4.7 Paramètre PERMUTABLE

Nom de paramètre	PERMUTABLE
Type du paramètre	Structure
Fonction du paramètre	La structure PERMUTABLE affecte une liste de bornes ou de groupes de bornes qui sont permutable. La liste peut comprendre des identificateurs de bornes (voir 8.4.5.1) ou des identificateurs de groupes de bornes (conformément à 8.4.6.2) mais pas un mélange des deux types d'identificateur. Chaque affectation PERMUTABLE déclare que les bornes ou groupes de bornes énuméré(e)s sont échangeables et/ou permutable en termes de fonctionnalité. Cela sert à faciliter la connexion et le routage alternatifs par un logiciel de CAO. Se référer à Règles de PERMUTABLE (voir 8.4.7.1) pour les détails. Se référer à l'Annexe B pour d'autres explications.
Valeurs du paramètre	La déclaration du paramètre PERMUTABLE doit consister soit en une liste de deux ou plusieurs identificateurs de bornes (voir 8.4.6.1), soit en deux ou plusieurs identificateurs de groupes de bornes (voir 8.4.6.1), mais ne doit pas contenir de mélange d'identificateurs de bornes et d'identificateurs de groupes de bornes.
Dépendances	TERMINAL (voir 8.4.5) TERMINAL_GROUP (voir 8.4.6)
Notes	Dans tous les cas, un identificateur de borne unique doit seulement apparaître une seule fois dans un groupe. Cela est pertinent lorsqu'il s'agit de considérer l'expansion d'un groupe de bornes. Pour la permutation correcte de groupes de bornes dans une affectation de PERMUTABLE unique, il est obligatoire que la séquence de bornes dans chaque groupe corresponde directement à la séquence de bornes des autres groupes de bornes au sein de l'affectation
Référence	Annexe B.

8.4.7.1 Règles relatives à PERMUTABLE

8.4.7.1.1 Contenu

Les éléments formant une permutation peuvent être des identificateurs de bornes ou des identificateurs de groupes mais pas un mélange des deux. Une permutation doit contenir au moins deux éléments.

8.4.7.1.2 Unicité

Tous les éléments d'une permutation doivent être uniques. Une permutation ne peut contenir de groupes qui se réfèrent directement ou indirectement au même élément.
Chaque élément d'une permutation doit contenir le même nombre d'identificateurs de bornes (au sein de groupes de bornes ou non) que les autres.

8.4.7.1.3 Ordre

L'ordre des éléments dans une permutation n'a pas d'importance.

Syntaxe de la définition d'un PERMUTABLE unique:

```
PERMUTABLE P_n = Terminal identifier, ... Terminal identifier;
PERMUTABLE P_n = Terminal identifier, ... Terminal identifier;
PERMUTABLE P_n = Group identifier, ... Group identifier;
PERMUTABLE P_n = Group identifier, ... Group identifier;
```

Syntaxe de la définition d'un PERMUTABLE multiple:

```
PERMUTABLE {
    P_n = Terminal identifier, ... Terminal identifier;
    P_n = Terminal identifier, ... Terminal identifier;
    P_n = Group identifier, ... Group identifier;
    P_n = Group identifier, ... Group identifier;
}
```


Exemple

```

PERMUTABLE P_1 = T_1, T_2, T_3;
PERMUTABLE P_2 = GP1, GP2, GP3, GP5, GP4;

PERMUTABLE {
    P_1 = T_1, T_2;
    P_2 = T_4, T_5;
    P_3 = T_9, T_10;
    P_4 = T_12, T_13;
    P_5 = G_5, G_6, G_7, G_8;
}

```

8.5 DONNÉES RELATIVES AUX MATÉRIAUX**8.5.1 Paramètre `TERMINAL_MATERIAL`**

Nom de paramètre	TERMINAL_MATERIAL
Type du paramètre	Variable
Fonction du paramètre	Spécifie le matériau utilisé pour les terminaisons finales sur le dispositif
Valeurs du paramètre	Données de chaîne textuelle, conformément à 7.1.3.1
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemple	<pre> TERMINAL_MATERIAL = "Al"; TERMINAL_MATERIAL = "Cuivre"; TERMINAL_MATERIAL = "SAC405"; </pre>

8.5.2 Paramètre `TERMINAL_MATERIAL_STRUCTURE`

Nom de paramètre	TERMINAL_MATERIAL_STRUCTURE
Type du paramètre	Variable
Fonction du paramètre	Spécifie la structure séquentielle des matériaux utilisés pour établir les terminaisons sur le dispositif.
Valeurs du paramètre	Données de chaîne textuelle, conformément à 7.1.3.1
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemple	<code>TERMINAL_MATERIAL_STRUCTURE = "Al-Ti-Ni-Au";</code>

8.5.3 Paramètre `DIE_SEMICONDUCTOR_MATERIAL`

Nom de paramètre	DIE_SEMICONDUCTOR_MATERIAL
Type du paramètre	Variable
Fonction du paramètre	Spécifie le matériau semiconducteur qui est utilisé pour la fabrication de la puce.
Valeurs du paramètre	Données de chaîne textuelle, conformément à 7.1.3.1
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemple	<pre> DIE_SEMICONDUCTOR_MATERIAL = "Insulator"; DIE_SEMICONDUCTOR_MATERIAL = "Silicon"; DIE_SEMICONDUCTOR_MATERIAL = "Sapphire"; </pre>
Notes	Ce paramètre est pertinent seulement si le matériau de base de la puce est différent du matériau du substrat de la puce.

8.5.4 Paramètre `DIE_SUBSTRATE_MATERIAL`

Nom de paramètre	DIE_SUBSTRATE_MATERIAL
Type du paramètre	Variable
Fonction du paramètre	Spécifie le matériau de base ou de substrat sur lequel la puce est fabriquée lorsqu'il diffère du <code>DIE_SEMICONDUCTOR_MATERIAL</code> .
Valeurs du paramètre	Données de chaîne textuelle, conformément à 7.1.3.1
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE .
Exemple	<pre> DIE_SUBSTRATE_MATERIAL = "Silicon"; DIE_SUBSTRATE_MATERIAL = "Insulator"; DIE_SUBSTRATE_MATERIAL = "Sapphire"; </pre>

8.5.5 Paramètre DIE_SUBSTRATE_CONNECTION

Nom de paramètre	DIE_SUBSTRATE_CONNECTION
Type du paramètre	Variable
Fonction du paramètre	Spécifie la connexion électrique pour le substrat, s'il en existe. Par fabrication, le substrat peut déjà être connecté électriquement, ce qu'il convient également de déclarer. Lorsqu'il convient d'établir une connexion électrique, le point de potentiel pour la connexion doit aussi être déclaré.
Valeurs du paramètre	Une ou plusieurs données de chaîne textuelle, conformément à 7.1.3.1. Le premier paramètre doit être conforme aux valeurs données dans le Tableau 4.
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemple	<pre> DIE_SUBSTRATE_CONNECTION = "CONN", "Ground"; DIE_SUBSTRATE_CONNECTION = "N/A"; DIE_SUBSTRATE_CONNECTION = "ISOL"; DIE_SUBSTRATE_CONNECTION = "OPT", "Most Negative"; DIE_SUBSTRATE_CONNECTION = "OPT", "Most Positive"; DIE_SUBSTRATE_CONNECTION = "CONN", "Digital Vdd"; DIE_SUBSTRATE_CONNECTION = "OPT", "Analog ground"; </pre>

Tableau 4 – Paramètres de connexion au substrat

Valeur du paramètre	Fonction
CONN	Doit être connecté électriquement.
ISOL	Doit être isolé électriquement
OPT	Peut être connecté facultativement
N/A	Non applicable
N/K	Non connu (inconnu)

Notes	Lorsque "CONN" ou "OPT" est donné comme première valeur de paramètre, la deuxième valeur de paramètre doit être complètement déclarée, de manière suffisamment adéquate pour être comprise pour la connectivité électrique. Les valeurs de paramètre recommandées sont: "Most Positive", "Most Negative", "GND", "AGND", "DGND", "VSS", "VDD", "VEE", "VCC", "AVSS", "AVDD", "AVEE", "AVCC", "DVSS", "DVDD", "DVEE", "DVCC", "VBIAS", ou "SPECIAL". En variante, un nom de TERMINAL spécifique "T_n", tel que décrit en 8.4.5, peut être utilisé comme seconde valeur de paramètre pour la connexion directe au substrat.
-------	---

8.5.6 Paramètre DIE_PASSIVATION_MATERIAL

Nom de paramètre	DIE_PASSIVATION_MATERIAL
Type du paramètre	Variable
Fonction du paramètre	Spécifie le matériau de passivation utilisé pour la surface de la puce.
Valeurs du paramètre	Données de chaîne textuelle, conformément à 7.1.3.1
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemple	<pre> DIE_PASSIVATION_MATERIAL = "Silicon Nitride"; DIE_PASSIVATION_MATERIAL = "Oxy-Nitride"; DIE_PASSIVATION_MATERIAL = "Polyimide"; </pre>

8.5.7 Paramètre DIE_BACK_DETAIL

Nom de paramètre	DIE_BACK_DETAIL
Type du paramètre	Variable
Fonction du paramètre	Spécifie la finition en détail au verso de la puce, pertinente pour différentes méthodes de fixation/différents types de boîtier, afin d'inclure à la fois la finition et le matériau.
Valeurs du paramètre	Données de chaîne textuelle, conformément à 7.1.3.1
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemple	<pre> DIE_BACK_DETAIL = "Sawn"; </pre>

```

DIE_BACK_DETAIL = "Au-Metallized";
DIE_BACK_DETAIL = "Backlapped";
DIE_BACK_DETAIL = "Polished";
DIE_BACK_DETAIL = "Gold Metal";
DIE_BACK_DETAIL = "None";

```

8.6 DONNÉES RELATIVES AUX CARACTÉRISTIQUES ASSIGNÉES ÉLECTRIQUES ET THERMIQUES

8.6.1 Paramètre MAX_TEMP

Nom de paramètre **MAX_TEMP**
 Type du paramètre Variable
 Fonction du paramètre Spécifie la température maximale à laquelle le dispositif peut être exposé au cours d'une partie de la fixation de la puce, du brasage du dispositif ou autre processus de fabrication
 Valeurs du paramètre Real, conformément à 7.1.3.3.
 Unités du paramètre °C, Celsius
 Limitations Doit être déclaré une seule fois dans un seul bloc DEVICE.
 Exemple `MAX_TEMP = 280;`

8.6.2 Paramètre MAX_TEMP_TIME

Nom de paramètre **MAX_TEMP_TIME**
 Type du paramètre Variable
 Fonction du paramètre Spécifie la durée maximale pendant laquelle le dispositif peut être exposé à la température maximale au cours d'une partie de la fixation de la puce, du brasage du dispositif ou autre processus de fabrication.
 Valeurs du paramètre Real, conformément à 7.1.3.3.
 Unités du paramètre Secondes
 Dépendances **MAX_TEMP**
 Limitations Doit être déclaré une seule fois dans un seul bloc DEVICE.
 Exemple `MAX_TEMP_TIME = 10;`

8.6.3 Paramètre POWER_RANGE

Nom de paramètre **POWER_RANGE**
 Type du paramètre Variable
 Fonction du paramètre Spécifie la puissance susceptible d'être dissipée par le dispositif.
 Valeurs du paramètre Real, conformément à 7.1.3.3.
 Unités du paramètre Watts
 Limitations Doit être déclaré une seule fois dans un seul bloc **DEVICE**.
 Exemple `POWER_RANGE = 0.92;`
 Notes Il convient d'utiliser ce paramètre avec prudence car, faute de spécifier complètement toutes les conditions de mesure, l'utilisation de cette valeur peut être mal comprise. Il convient que la valeur indique la puissance maximale vraisemblablement dissipée dans les conditions types de cas le plus défavorable.

8.6.4 Paramètre TEMPERATURE_RANGE

Nom de paramètre **TEMPERATURE_RANGE**
 Type du paramètre Variable
 Fonction du paramètre Spécifie la plage de fonctionnement et de spécification de la puce.
 Valeurs du paramètre Minimum (Réel, en °C), Maximum (Réel, en °C), conformément à 7.1.3.3.
 Unités du paramètre °C, Celsius
 Limitations Doit être déclaré une seule fois dans un seul bloc DEVICE.
 Exemple `TEMPERATURE_RANGE = -40, 90;`
 Notes Dans le cas des puces nues, il convient d'utiliser ce paramètre avec prudence et il est seulement destiné à indiquer le niveau de

température opérationnelle ou spécifiée de la pièce emballée équivalente.

8.7 DONNÉES DE SIMULATION

8.7.1 Paramètre MODEL FILE de simulateur

Nom de paramètre	SIMULATOR_simulator_MODEL_FILE
Type du paramètre	Variable
Fonction du paramètre	Spécifie le nom du fichier modèle à utiliser avec <i>simulator</i> .
Valeurs du paramètre	Données de nom textuel, comme en 7.1.3.2
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE par type de <i>simulator</i> .
Exemple	<pre>SIMULATOR_SPICE_MODEL_FILE = "BC109.MOD"; SIMULATOR_SPECTRE_MODEL_FILE = "RTBAA1.S";</pre>
Notes	Seuls doivent être utilisés les noms de fichier, sans nom de chemin relatif ou absolu.
Référence	Annexe D.

8.7.2 Paramètre MODEL FILE DATE de simulateur

Nom de paramètre	SIMULATOR_simulator_MODEL_FILE_DATE
Type du paramètre	Variable
Fonction du paramètre	Spécifie la date de création ou de validation du fichier modèle.
Valeurs du paramètre	Date, conformément à 7.1.3.5
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE par type de <i>simulator</i> .
Exemple	<pre>SIMULATOR_SPICE_MODEL_FILE_DATE="19951021"; SIMULATOR_VHDL_MODEL_FILE_DATE="1993-05-17";</pre>
Notes	Il convient que cette date coïncide avec la date du fichier modèle réel, pour indiquer que le fichier modèle correct est en cours d'utilisation, et pour une utilisation dans une fonction de création/établissement de bibliothèque.
Référence	Annexe D.

8.7.3 Paramètre NAME de simulateur

Nom de paramètre	SIMULATOR_simulator_NAME
Type du paramètre	Variable
Fonction du paramètre	Spécifie le nom du <i>simulator</i> générique ou spécifique pour lequel le fichier modèle est approprié.
Valeurs du paramètre	Données de chaîne textuelle, conformément à 7.1.3.1
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE par type de <i>simulator</i> .
Exemple	<pre>SIMULATOR_SPICE_NAME = "pSpice"; SIMULATOR_VERILOG_NAME = "Verilog-XL";</pre>
Référence	Annexe D.

8.7.4 Paramètre VERSION de simulateur

Nom de paramètre	SIMULATOR_simulator_VERSION
Type du paramètre	Variable
Fonction du paramètre	Spécifie le numéro de version du <i>simulator</i> tel que spécifié par le paramètre <i>SIMULATOR_simulator_NAME</i> qui avait été utilisé pour vérifier les données de modèle.
Valeurs du paramètre	Données de chaîne textuelle, conformément à 7.1.3.1
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE par type de <i>simulator</i> .
Exemple	<pre>SIMULATOR_SPICE_VERSION = "4.0.1"; SIMULATOR_VERILOG_VERSION = "1.7B";</pre>
Référence	Annexe D.

8.7.5 Paramètre COMPLIANCE de simulateur

Nom de paramètre	SIMULATOR_simulator_COMPLIANCE
Type du paramètre	Variable
Fonction du paramètre	Spécifie le niveau minimal de conformité du <i>simulateur</i> requis pour à la fois reproduire avec précision les résultats de la simulation et se corrélér à ceux-ci.
Valeurs du paramètre	Données de chaîne textuelle, conformément à 7.1.3.1
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE par type de <i>simulator</i> .
Exemple	<pre>SIMULATOR_VHDL_COMPLIANCE = "VHDL '93"; SIMULATOR_SPICE_COMPLIANCE = "2G6";</pre>
Référence	Annexe D.

8.7.6 Paramètre TERM_GROUP de simulateur

Nom de paramètre	SIMULATOR_simulator_TERM_GROUP
Type du paramètre	Variable
Fonction du paramètre	Spécifie le groupe ou les bornes au(x)quel(les) s'applique le modèle de simulateur. S'il est absent, on suppose que le modèle s'applique à l'ensemble du dispositif.
Valeurs du paramètre	Liste de bornes (conformément à 8.4.5.1) et/ou de groupes de bornes (conformément à 8.4.6.2)
Limitations	Les bornes ou groupes de bornes référencé(e)s doivent avoir déjà été déclaré(e)s soit dans un paramètre TERMINAL, soit dans un paramètre TERMINAL_GROUP. Doit être déclaré une seule fois dans un seul bloc DEVICE par type de <i>simulator</i> .
Exemple	<pre>SIMULATOR_SPICE_TERM_GROUP = T_1, T_2, G_1; SIMULATOR_IBIS_TERM_GROUP = G_5, G_8, T_11, T_33;</pre>
Référence	Annexes B et D.

8.8 DONNÉES RELATIVES À LA MANUTENTION, AU CONDITIONNEMENT, AU STOCKAGE ET À L'ASSEMBLAGE

8.8.1 Paramètre DELIVERY_FORM

Nom de paramètre	DELIVERY_FORM
Type du paramètre	Variable
Fonction du paramètre	Spécifie la forme dans laquelle la puce est livrée.
Valeurs du paramètre	Données de chaîne textuelle, conformément à 7.1.3.1
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemple	<pre>DELIVERY_FORM = "Wafer"; DELIVERY_FORM = "Die"; DELIVERY_FORM = "Bare Die in Waffle Tray"; DELIVERY_FORM = "Sawn Wafer"; DELIVERY_FORM = "Tray"; DELIVERY_FORM = "Bandoleer", "Waffle";</pre>

8.8.2 Paramètre PACKING_CODE

Nom de paramètre	PACKING_CODE
Type du paramètre	Variable
Fonction du paramètre	Spécifie la forme du conditionnement primaire utilisé pour la livraison des dispositifs.
Valeurs du paramètre	Données de chaîne textuelle, conformément à 7.1.3.1
Exemple	<pre>PACKING_CODE = "WAFFLE"; PACKING_CODE = "GEL_PACK"; PACKING_CODE = "Bandoleer";</pre>

8.8.3 Paramètres ASSEMBLY

Nom de paramètre	ASSY_text-identif
Type du paramètre	Variable
Fonction du paramètre	Paramètre textuel général, pour permettre à l'utilisateur d'inclure des techniques, paramètres et fonctionnements pertinents et identifiés.
Valeurs du paramètre	Données de chaîne textuelle, conformément à 7.1.3.1
Exemples	ASSY_PROCESS_LIMITATIONS = "NONE";

Notes Les identificateurs **ASSY_identifiers** reconnus sont:

8.8.3.1	ASSY_PROCESS_LIMITATIONS
8.8.3.2	ASSY_STORAGE_LIMITATIONS
8.8.3.3	ASSY_ASSEMBLY_LIMITATIONS
8.8.3.4	ASSY_TEMPERATURE_LIMITATIONS
8.8.3.5	ASSY_BONDING_METHODS
8.8.3.6	ASSY_BONDING_MATERIALS
8.8.3.7	ASSY_ATTACH_METHODS
8.8.3.8	ASSY_ATTACH_MATERIALS
8.8.3.9	ASSY_GENERAL_REQUIREMENTS
8.8.3.10	ASSY_HANDLING_REQUIREMENTS
8.8.3.11	ASSY_PACKING_REQUIREMENTS
8.8.3.12	ASSY_STORAGE_REQUIREMENTS
8.8.3.13	ASSY_SHIPPING_REQUIREMENTS

8.9 DONNÉES SPÉCIFIQUES AUX TRANCHES

8.9.1 Paramètre WAFER_SIZE

Nom de paramètre	WAFER_SIZE
Type du paramètre	Variable
Fonction du paramètre	Spécifie le diamètre de la tranche.
Valeurs du paramètre	Données de chaîne textuelle, conformément à 7.1.3.1
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemple	WAFER_SIZE = "6 inch"; WAFER_SIZE = "150mm";
Notes	Sachant qu'il s'agit d'une valeur dimensionnelle mais reliée à la fabrication et non à la taille de la puce, il est permis d'exprimer le paramètre WAFER_SIZE dans des unités différentes de celles définies par le paramètre GEOMETRIC_UNITS et, donc, les données sont présentées en texte de forme libre.

8.9.2 Paramètre WAFER_THICKNESS

Nom de paramètre	THICKNESS
Type du paramètre	Variable
Fonction du paramètre	Détermine l'épaisseur (dimension Z) de la tranche.
Valeurs du paramètre	Valeur de la dimension Z en nombre réel, conformément à 7.1.3.3.
Dépendances	GEOMETRIC_UNITS
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemple	WAFER_THICKNESS = 10.5; WAFER_THICKNESS = 80;
Notes	Les valeurs de dimensions sont exprimées en GEOMETRIC_UNITS.

8.9.3 Paramètre WAFER_THICKNESS_TOLERANCE

Nom de paramètre	WAFER_THICKNESS_TOLERANCE
Type du paramètre	Variable
Fonction du paramètre	Spécifie l'une ou les plusieurs tolérances du paramètre WAFER_THICKNESS qui peuvent être attendues en raison des variations normales de processus.
Valeurs du paramètre	Réelles en GEOMETRIC_UNITS, conformément à 7.1.3.3.
Dépendances	GEOMETRIC_UNITS, WAFER_THICKNESS
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.

Exemple	<pre> WAFER_THICKNESS_TOLERANCE = 2.5; WAFER_THICKNESS_TOLERANCE = -1.2, 1.5; </pre>
Notes	Une ou deux valeurs peuvent être données: Lorsqu'une tolérance unique est donnée, la tolérance doit être prise comme étant une valeur non signée $\pm$. Lorsque deux valeurs de tolérance sont données: la première valeur doit être prise comme le minimum et la seconde valeur doit être prise comme le maximum.

8.9.4 Paramètre WAFER_DIE_STEP_SIZE

Nom de paramètre	WAFER_DIE_STEP_SIZE
Type du paramètre	Variable
Fonction du paramètre	Détermine les dimensions de taille de pas en X et en Y, en GEOMETRIC_UNITS, pour la puce sur la tranche, telles que requises par le matériel de manutention mécanique.
Valeurs du paramètre	Dimension X en nombre réel, dimension Y en nombre réel (conformément à 7.1.3.3)
Dépendances	GEOMETRIC_UNITS, GEOMETRIC_VIEW
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemple	<pre> WAFER_DIE_STEP_SIZE = 280, 530; WAFER_DIE_STEP_SIZE = 1500, 1500; </pre>
Référence	Annexe H.

8.9.5 Paramètre WAFER_GROSS_DIE_COUNT

Nom de paramètre	WAFER_GROSS_DIE_COUNT
Type du paramètre	Variable
Fonction du paramètre	Spécifie le nombre de puces brutes entières et viables (ayant le type de puce en question) disponibles sur la tranche.
Valeurs du paramètre	Integer, conformément à 7.1.3.4.
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemple	<pre> WAFER_GROSS_DIE_COUNT = 2027; </pre>
Notes	Cette valeur de paramètre est seulement destinée à donner une indication du nombre de puces pertinentes et viables par tranche et ne doit pas avoir d'autre implication.
Référence	Annexe H.

8.9.6 Paramètre WAFER_INDEX

Nom de paramètre	WAFER_INDEX
Type du paramètre	Variable
Fonction du paramètre	Spécifie le type de la caractéristique d'index sur une tranche qui agit comme une caractéristique de référence et son orientation par rapport à l'axe X pour la puce. Le premier paramètre détermine le type de la caractéristique d'index tandis que le second paramètre spécifie la relation angulaire approchée entre l'axe X supposé pour la puce et la caractéristique d'index sur la tranche. L'angle doit être donné, en degrés comptés dans le sens horaire, de la caractéristique d'index, en prenant l'axe X de la puce comme référence.
Valeurs du paramètre	Données en chaîne textuelle, conformément à 7.1.3.1, avec la valeur "Flat" ou "Notch", suivie d'une seule valeur entière, en unités de degrés, de 0 à 359, conformément à 7.1.3.4.
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemple	<pre> WAFER_INDEX = "Flat", 90; WAFER_INDEX = "Notch", 0; </pre>
Notes	Ce paramètre est seulement censé être un guide et, donc, des approximations entières doivent être acceptables. Les angles négatifs sont interdits. S'il existe plus d'un méplat sur la tranche, l'orientation

est par rapport au méplat majeur ou principal. Cela peut aussi indiquer la direction cristallographique [110].

Référence Annexe H.

8.9.7 Paramètre **WAFER_RETICULE_STEP_SIZE**

Nom de paramètre **WAFER_RETICULE_STEP_SIZE**
 Type du paramètre Variable
 Fonction du paramètre Spécifie les dimensions répétées de pas en X et en Y et les dimensions répétées pour un réticule unique.
 Valeurs du paramètre Dimension X en nombre réel, dimension Y en nombre réel (conformément à 7.1.3.3)
 Dépendances GEOMETRIC_UNITS, GEOMETRIC_VIEW
 Limitations Doit être déclaré une seule fois dans un seul bloc DEVICE.
 Exemple `WAFER_RETICULE_STEP_SIZE = 2500, 8000;`
`WAFER_RETICULE_STEP_SIZE = 15000, 27500;`
 Notes Ce paramètre est surtout pertinent pour les tranches MPW (Multi Project Wafers, c'est-à-dire tranches multiprojet), ou des instances où **WAFER_DIE_STEP_SIZE** devient invalide en raison d'une relation non entière entre la taille du réticule et la taille de la puce.
 Référence Annexe H.

8.9.8 Paramètre **WAFER_RETICULE_GROSS_DIE_COUNT**

Nom de paramètre **WAFER_RETICULE_GROSS_DIE_COUNT**
 Type du paramètre Variable
 Fonction du paramètre Spécifie le nombre de puces brutes entières et viables (ayant le type de puce en question) placées dans un réticule unique.
 Valeurs du paramètre Integer, conformément à 7.1.3.4.
 Limitations Doit être déclaré une seule fois dans un seul bloc DEVICE.
 Exemple `WAFER_RETICULE_GROSS_DIE_COUNT = 40;`
 Notes Ce paramètre est surtout pertinent pour les tranches MPW (tranches multiprojet) ou les instances où le réticule contient plus d'un type de puce. Cette valeur de paramètre est seulement destinée à donner une indication du nombre de puces pertinentes et viables par réticule et ne doit pas avoir d'autre implication.
 Référence Annexe H.

8.9.9 Paramètres **WAFER_INK**

Nom de paramètre **WAFER_INK_text-identif**
 Type du paramètre Variable
 Fonction du paramètre Paramètre textuel général, pour permettre à l'utilisateur d'inclure des paramètres pertinents relatifs à la taille et à la couleur des points/encre de la tranche. Cela revêt une importance particulière pour les systèmes visuels de sélection, tri et examen des puces.
 Valeurs du paramètre Données de chaîne textuelle, conformément à 7.1.3.1
 Exemples `WAFER_INK_COLOUR = "BLACK";`
`WAFER_INK_LOCATION = "CENTRAL";`
`WAFER_INK_SIZE_MAX = "0.8mm";`
`WAFER_INK_SORT_COLOUR = "BIN1, RED, UPPER RIGHT";`
`WAFER_INK_SORT_COLOUR = "BIN2, GREEN, LOWER LEFT";`

Notes Les identificateurs **WAFER_INK_identifiers** reconnus sont:

- 8.9.9.1 **WAFER_INK_COLOUR**
- 8.9.9.2 **WAFER_INK_SIZE**
- 8.9.9.3 **WAFER_INK_SIZE_TOL**
- 8.9.9.4 **WAFER_INK_SIZE_MAX**
- 8.9.9.5 **WAFER_INK_LOCATION**
- 8.9.9.6 **WAFER_INK_LOCATION_TOL**
- 8.9.9.7 **WAFER_INK_HEIGHT_MAX**
- 8.9.9.8 **WAFER_INK_SORT_COLOUR**

8.10 DONNÉES SPÉCIFIQUES AUX TERMINAISONS À BOSSES

Toute donnée fournie qui est pertinente pour un dispositif «à bosses» (un dispositif utilisant des structures de connexion à bosses ajoutées) peut seulement refléter les paramètres de bosses au moment de la formation des bosses et pas nécessairement les paramètres finals. En raison de la nature de la connexion à bosses finale, les paramètres de bosse seront altérés et déformés au cours du processus de fixation. Il convient donc de considérer tous les paramètres géométriques et métallurgiques donnés comme relatifs aux bosses «vierges»

8.10.1 Paramètre BUMP_MATERIAL

Nom de paramètre	BUMP_MATERIAL
Type du paramètre	Variable
Fonction du paramètre	Spécifie le matériau métallurgique du plot de contact.
Valeurs du paramètre	Données de chaîne textuelle, conformément à 7.1.3.1
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemple	<pre> BUMP_MATERIAL = "Copper"; BUMP_MATERIAL = "Molybdenum Telluride"; BUMP_MATERIAL = "Au"; BUMP_MATERIAL = "SAC415"; BUMP_MATERIAL = "Pb-Sn"; </pre>
Notes	Requis seulement pour les types de dispositifs avec des structures de connexion à bosses. Lorsqu'un dispositif comporte à la fois des bornes à bosses et sans bosses, il convient d'utiliser TERMINAL_MATERIAL pour décrire les bornes sans bosses et d'utiliser BUMP_MATERIAL pour décrire la borne à bosse.

8.10.2 Paramètre BUMP_HEIGHT

Nom de paramètre	BUMP_HEIGHT
Type du paramètre	Variable
Fonction du paramètre	Spécifie la tolérance sur la hauteur du plot de contact au-dessus de la surface de passivation.
Valeurs du paramètre	Réelles numériques, en GEOMETRIC_UNITS, conformément à 7.1.3.3.
Dépendances	GEOMETRIC_UNITS
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemple	<pre> BUMP_HEIGHT = 150.0; </pre>
Notes	Requis seulement pour les types de dispositifs avec des structures de connexion à bosses. La hauteur de la bosse peut seulement être déclarée avant que la bosse ne soit modifiée par une fixation et/ou une connexion permanente.

8.10.3 Paramètre BUMP_HEIGHT_TOLERANCE

Nom de paramètre	BUMP_HEIGHT_TOLERANCE
Type du paramètre	Variable
Fonction du paramètre	Spécifie la tolérance sur la hauteur du plot de contact au-dessus de la surface de passivation.
Valeurs du paramètre	Réelles numériques, en GEOMETRIC_UNITS, conformément à 7.1.3.3.
Dépendances	GEOMETRIC_UNITS, BUMP_HEIGHT
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemple	<pre> BUMP_HEIGHT_TOLERANCE = 35.0; BUMP_HEIGHT_TOLERANCE = -10.0, 25.0; </pre>
Notes	Une ou deux valeurs peuvent être données: Lorsqu'une tolérance unique est donnée, la tolérance doit être prise comme étant une valeur non signée $\pm$. Lorsque deux valeurs de tolérance sont données: la première valeur doit être prise comme le minimum et la seconde valeur doit être prise comme le maximum.

Requis seulement pour les types de dispositifs avec des structures de connexion à bosses.

8.10.4 Paramètre **BUMP_SHAPE**

Nom de paramètre	BUMP_SHAPE
Type du paramètre	Variable
Fonction du paramètre	Spécifie la forme de bosse du contact en hauteur.
Valeurs du paramètre	Données de chaîne textuelle, conformément à 7.1.3.1
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemple	<code>BUMP_SHAPE="Pyramidical";</code> <code>BUMP_SHAPE="Ball";</code>
Notes	Requis seulement pour les types de dispositifs avec des structures de connexion à bosses. La forme de la bosse peut seulement être déclarée avant que la bosse ne soit modifiée par une fixation et/ou une connexion permanente.

8.10.5 Paramètre **BUMP_SIZE**

Nom de paramètre	BUMP_SIZE
Type du paramètre	Variable
Fonction du paramètre	Spécifie la taille de bosse en coordonnées X et -Y.
Valeurs du paramètre	Réelles numériques, en GEOMETRIC_UNITS, conformément à 7.1.3.3.
Dépendances	GEOMETRIC_UNITS
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemple	<code>BUMP_SIZE= "150,150";</code>
Notes	Requis seulement pour les types de dispositifs avec des structures de connexion à bosses. La taille de la bosse peut seulement être déclarée avant que la bosse ne soit modifiée par une fixation et/ou une connexion permanente.

8.10.6 Paramètre **BUMP_SPECIFICATION_DRAWING**

Nom de paramètre	BUMP_SPECIFICATION_DRAWING
Type du paramètre	Variable
Fonction du paramètre	Spécifie le(s) nom(s) du/des fichier(s) de dessin de spécification des bosses.
Valeurs du paramètre	Données de nom textuel, comme en 7.1.3.2
Exemple	<code>BUMP_SPECIFICATION_DRAWING = "BumpShape1.JPG";</code> <code>BUMP_SPECIFICATION_DRAWING = "BS1.JPG", "BS2.TIF";</code>
Notes	Seuls doivent être utilisés les noms de fichier, sans nom de chemin relatif ou absolu. Requis seulement pour les types de dispositifs avec des structures de connexion à bosses. Tout dessin de la bosse peut seulement refléter l'état de la bosse avant sa modification par une fixation et/ou une connexion permanente. Plusieurs paramètres (fichiers de dessins de spécification) peuvent être introduits dans une déclaration unique ou bien plusieurs déclarations peuvent être utilisées pour le même effet. Il n'existe aucune exigence de mise à l'échelle ou positionnelle
Référence	Annexe I, Note 3 et 4.

8.10.7 Paramètre **BUMP_ATTACHMENT_METHOD**

Nom de paramètre	BUMP_ATTACHMENT_METHOD
Type du paramètre	Variable
Fonction du paramètre	Spécifie le type de méthode de fixation requis ou conseillé pour ce type de bosse.
Valeurs du paramètre	Données de chaîne textuelle, conformément à 7.1.3.1
Limitations	Doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemple	<code>BUMP_ATTACHMENT_METHOD = "Thermocompression";</code> <code>BUMP_ATTACHMENT_METHOD = "Solder Reflow";</code>

Notes Requis seulement pour les types de dispositifs avec des structures de connexion à bosses.

8.11 DONNÉES SPÉCIFIQUES AUX DISPOSITIFS À ENCAPSULATION RÉDUITE (MPD, MINIMALLY PACKAGED DEVICE)

8.11.1 Paramètre MPD_PACKAGE_MATERIAL

Nom de paramètre **MPD_PACKAGE_MATERIAL**
 Type du paramètre Variable
 Fonction du paramètre Spécifie le matériau du corps d'emballage utilisé comme encapsulation finale du MPD.
 Valeurs du paramètre Données de chaîne textuelle, conformément à 7.1.3.1.
 Limitations Doit être déclaré une seule fois dans un seul bloc DEVICE.
 Exemple
 MPD_PACKAGE_MATERIAL = "Plastic";
 MPD_PACKAGE_MATERIAL = "Epoxy";
 MPD_PACKAGE_MATERIAL = "Ceramic";
 MPD_PACKAGE_MATERIAL = "Metal Can";

Notes En général, requis pour des besoins d'assemblage.

8.11.2 Paramètre MPD_PACKAGE_STYLE

Nom de paramètre **MPD_PACKAGE_STYLE**
 Type du paramètre Variable
 Fonction du paramètre Spécifie le code pour le type de boîtier tel que défini dans une norme ou tel que donné par le fabricant.
 Valeurs du paramètre Données de chaîne textuelle, conformément à 7.1.3.1.
 Limitations Doit être déclaré une seule fois dans un seul bloc DEVICE.
 Exemple
 MPD_PACKAGE_STYLE = "SOT-23";
 MPD_PACKAGE_STYLE = "MO";
 MPD_PACKAGE_STYLE = "TSOP-48";

8.11.3 Paramètre MPD_CONNECTION_TYPE

Nom de paramètre **MPD_CONNECTION_TYPE**
 Type du paramètre Variable
 Fonction du paramètre Spécifie une méthode de connexion au MPD, telle que fil conducteur, bosse, etc.
 Valeurs du paramètre Données de chaîne textuelle, conformément à 7.1.3.1.
 Limitations Doit être déclaré une seule fois dans un seul bloc DEVICE.
 Exemple
 MPD_CONNECTION_TYPE = "Bump";
 MPD_CONNECTION_TYPE = "TAB Lead";

8.11.4 Paramètre MPD_MSL_LEVEL

Nom de paramètre **MPD_MSL_LEVEL**
 Type du paramètre Variable
 Fonction du paramètre Spécifie le niveau de sensibilité à l'humidité de l'emballage MPD, conformément à l'IPC/JEDEC J-STD-033B:2007 – Handling, Packing, Shipping and Use of Moisture/Reflow Sensitive Surface Mount Devices, 2005.
 Valeurs du paramètre Données de chaîne textuelle, conformément à 7.1.3.1.
 Limitations Doit être déclaré une seule fois dans un seul bloc DEVICE.
 Exemple
 MPD_MSL_LEVEL = "3";

8.11.5 Paramètre MPD_PACKAGE_DRAWING

Nom de paramètre **MPD_PACKAGE_DRAWING**
 Type du paramètre Variable
 Fonction du paramètre Spécifie le(s) nom(s) du(des) fichier(s) de dessin de spécification des emballages de MPD.

Valeurs du paramètre	Données de nom textuel, conformément à 7.1.3.2
Exemple	MPD_PACKAGE_DRAWING = "PackageOutline.PDF"; MPD_PACKAGE_DRAWING = "PO1.JPG", "PO1A.GIF";
Notes	Seuls doivent être utilisés les noms de fichier, sans nom de chemin relatif ou absolu. Plusieurs paramètres (fichiers de dessins de boîtier) peuvent être introduits dans une déclaration unique ou bien plusieurs déclarations peuvent être utilisées pour le même effet. Il n'existe aucune exigence de mise à l'échelle ou positionnelle
Référence	Annexe I, Notes 3 et 4.

8.12 DONNÉES DE QUALITÉ, FIABILITÉ ET ESSAIS

8.12.1 Paramètres QUALITY

Nom de paramètre	QUAL_identificateur
Type du paramètre	Variable
Fonction du paramètre	Paramètre textuel général, pour permettre à l'utilisateur d'inclure des paramètres pertinents et identifiés de qualité et de fiabilité.
Valeurs du paramètre	Données de chaîne textuelle, conformément à 7.1.3.1
Limitations	Chaque identificateur doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemples	QUAL_OUTGOING_QUALITY_LEVEL = "...";
Notes	Les identificateurs <i>QUAL_identifiers</i> reconnus sont:

- 8.12.1.1 QUAL_OUTGOING_QUALITY_LEVEL
- 8.12.1.2 QUAL_OUTGOING_QUALITY_UNITS
- 8.12.1.3 QUAL_OUTGOING_QUALITY_DESCRIPTION
- 8.12.1.4 QUAL_RELIABILITY_VALUE
- 8.12.1.5 QUAL_RELIABILITY_UNITS
- 8.12.1.6 QUAL_RELIABILITY_REFERENCE
- 8.12.1.7 QUAL_RELIABILITY_CONDITIONS
- 8.12.1.8 QUAL_RELIABILITY_CALC_METHOD
- 8.12.1.9 QUAL_STANDARDS_COMPLIANCE

8.12.2 Paramètres TEST

Nom de paramètre	TEST_identificateur
Type du paramètre	Variable
Fonction du paramètre	Paramètre textuel général, pour permettre à l'utilisateur d'inclure des paramètres pertinents et identifiés relatifs aux essais.
Valeurs du paramètre	Données de chaîne textuelle, conformément à 7.1.3.1
Limitations	Chaque identificateur doit être déclaré une seule fois dans un seul bloc DEVICE.
Exemples	TEST_ADDITIONAL_REQUIREMENTS = "NONE"; TEST_SCREEN_COMPLIANCE = "MIL-883B";
Notes	Les identificateurs <i>TEST_identifiers</i> reconnus sont:

- 8.12.2.1 TEST_ELECTRICAL_CONDITIONS
- 8.12.2.2 TEST_ADDITIONAL_SCREENING
- 8.12.2.3 TEST_TESTABILITY_FEATURES
- 8.12.2.4 TEST_ADDITIONAL_REQUIREMENTS
- 8.12.2.5 TEST_YIELD_CODE
- 8.12.2.6 TEST_FLOW
- 8.12.2.7 TEST_TEMP
- 8.12.2.8 TEST_SCREEN
- 8.12.2.9 TEST_SCREEN_COMPLIANCE